

An ACI Standard

Specification for Repairing Concrete with Epoxy Mortar

Reported by ACI Committee 548

ACI 548.14M-14



American Concrete Institute
Always advancing



Specification for Repairing Concrete with Epoxy Mortar

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided "as is" without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

Order information: ACI documents are available in print, by download, on CD-ROM, through electronic subscription, or reprint and may be obtained by contacting ACI.

Most ACI standards and committee reports are gathered together in the annually revised ACI Manual of Concrete Practice (MCP).

American Concrete Institute
3880 Country Club Drive
Farmington Hills, MI 48331
Phone: +1.248.848.3700
Fax: +1.248.848.3701

Specification for Repairing Concrete with Epoxy Mortar

An ACI Standard

Reported by ACI Committee 548

Bradley Nemunaitis, Chair

Mahmoud M. Reda Taher, Secretary

Ashraf I. Ahmed
Mohammad A. Alhassan
Milton D. Anderson
Jacques A. Bertrand
Constantin Bodea
Chris Davis
David W. Fowler
Quentin L. Hibben
Albert O. Kaeding
John R. Milliron
Myles A. Murray
Joseph A. Nuciforo Jr.
John R. Robinson

Michael L. Schmidt
Joe Solomon
Michael M. Sprinkel
Michael S. Stenko
Michael S. Stenko
Donald P. Tragianese
Wafeek S. Wahby
David White
David P. Whitney
Richard E. Wollmershauser

Consulting Members

Lu Anqi
Craig A. Ballinger

John J. Bartholomew
Shashi P. Bhatnagar
Zhi-Yuan Chen
Inz Lech Czarnecki
Harold (Dan) R. Chahara
Larry J. Farrell
Jack J. Fontana
George J. Goczko
David J. Hu
Bernard J. Kriekemans
John A. Kruger
William Lee
Troy D. Madeley

Henry N. Marsh Jr.
Peter Mendis
Peter J. Moss
Yoshihiko Ohama
Kelly M. Page
Jerzy Pietrzykowski
Hamid Saadatmanesh
Donald A. Schmidt
Meyer Steinberg
Harold H. Weber Jr.

The official version of this ACI document uses inch-pound units. A conversion of an ACI document into SI units is for the convenience of users. Care has been taken to ensure that the conversion is correct; however, ACI does not guarantee its accuracy. Official interpretation of this ACI document shall be based on the U.S. customary units.

This specification describes the work of repairing defects in hardened portland-cement concrete with an epoxy mortar. Included are controls for epoxy resin system labeling, storage, handling, surface evaluation and preparation, mixing and application, inspection, quality control, and testing.

Keywords: adhesion to concrete; aggregate; concrete construction; epoxy; epoxy mortar; hardened concrete; quality control; repairs; resurfacing.

CONTENTS

(mandatory portion follows)

PART 1—GENERAL, p. 2

- 1.1—Scope, p. 2
- 1.2—Interpretation, p. 2
- 1.3—Definitions, p. 2
- 1.4—Referenced standards, p. 2
- 1.5—Submittals, p. 2
- 1.6—Product delivery, storage, and handling, p. 2
- 1.7—Project conditions, p. 3

PART 2—PRODUCTS, p. 3

- 2.1—Materials, p. 3

PART 3—EXECUTION, p. 3

- 3.1—Preparation, p. 3
- 3.2—Inspection of surface prior to epoxy mortar application, p. 3
- 3.3—Epoxy mortar mixtures, p. 3
- 3.4—Epoxy mortar application, p. 3
- 3.5—Field quality control, p. 3
- 3.6—Cleanup, p. 3
- 3.7—Safety, p. 4

(nonmandatory portion follows)

NOTES TO SPECIFIER, p. 4

- General notes, p. 4

ACI 548.14M-14 was adopted December 18, 2014 and published May 2015.

Copyright © 2015, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

FOREWORD TO CHECKLISTS, p. 4**MANDATORY REQUIREMENTS CHECKLIST, p. 5****OPTIONAL REQUIREMENTS CHECKLIST, p. 5**

(mandatory portion follows)

PART 1—GENERAL**1.1—Scope**

1.1.1 This specification covers the repairing of defects in hardened concrete with an epoxy mortar as specified in Contract Documents.

1.1.2 This specification governs for construction within its scope, except the Contract Documents govern if there is a conflict.

1.1.3 Values in this specification are stated in SI units. A companion specification in inch-pound units is also available.

1.1.4 The Notes to Specifier are not part of this specification.

1.2—Interpretation

Unless otherwise explicitly stated, this specification shall be interpreted using the following principles:

(a) Interpret this specification consistent with the plain meaning of the words and terms used.

(b) Definitions provided in this specification govern over the definitions of the same or similar words or terms found elsewhere.

(c) Whenever possible, interpret this specification so that its provisions are in harmony and do not conflict.

(d) Headings are part of this specification and are intended to identify the scope of the provisions or sections that follow. If there is a difference in meaning or implication between the text of a provision and a heading, the meaning in the text governs.

(e) Where a provision of this specification involves two or more items, conditions, requirements, or events connected by the conjunctions “and” or “or” interpret the conjunction as follows:

“and” indicates that all of the connected items, conditions, requirements, or events apply.

“or” indicates that any of the connected items, conditions, requirements, or events apply singularly.

(f) The use of the verbs “may” or “will” indicates that the specification provision is for information to the Contractor.

1.3—Definitions

The following definitions govern in this specification. For definitions not given below, refer to “ACI Concrete Terminology,” <http://www.concrete.org/Tools/ConcreteTerminology.aspx>.

accepted—determined to be satisfactory by Architect/Engineer.

Architect/Engineer—architect, engineer, architectural firm, or engineering firm developing Contract Documents or

administering the Work under Contract Documents, or both.

Contract Documents—a set of documents supplied by the Owner to bidders during bidding phase of a construction project. These documents include general requirements, contract forms, contract conditions, specification, drawings, and addenda.

Contractor—the person, firm, or entity under contract for construction of Work.

defect—an imperfection of sufficient size or magnitude to causes nonconformance from the intended state or performance.

epoxy—a thermosetting polymer that is the reaction product of epoxy resin and hardener.

epoxy mortar—a mixture of epoxy resin, hardener, and fine aggregate.

Owner—the corporation, association, partnership, individual, public body, or authority for whom Work is constructed.

submit—provide to Architect/Engineer for review.

submittal—document or material provided to the Architect/Engineer for review and acceptance.

Work—the entire construction or separately identifiable parts thereof required to be furnished under Contract Documents.

1.4—Reference standards

Standards of ASTM referred to in this standard are listed with serial designations, including year of adoption or revision, and are part of this standard.

1.4.1 ASTM International

ASTM C579-01(2012)—Standard Test Methods for Compressive Strength of Chemical-Resistant Mortars, Grouts, Monolithic Surfacing, and Polymer Concretes

ASTM C881/C881M-13—Standard Specification for Epoxy-Resin-Base Bonding Systems for Concrete

ASTM C1583/C1583M-13—Standard Test Method for Tensile Strength of Concrete Surfaces and the Bond Strength or Tensile Strength of Concrete Repair and Overlay Materials by Direct Tension (Pull-off Method)

1.5—Submittals

1.5.1 Certifications—Submit manufacturer’s certification verifying conformance to material specifications.

1.5.2 Application control—Submit mixing and application procedures for acceptance prior to use.

1.5.3 Data—Submit manufacturer’s technical data sheets and material safety data sheets (MSDS).

1.5.4 Preparation procedures—Submit surface preparation procedures and equipment.

1.6—Product delivery, storage, and handling

1.6.1 Delivery of materials—Deliver all materials in sealed containers with labels legible and intact.

1.6.2 Labeling—Only use materials that are marked with the following information:

- a) Name of manufacturer
- b) Manufacturer’s product identification
- c) Manufacturer’s instructions for mixing