

An ACI Standard

Requirements for Design of a Special Unbonded Post- Tensioned Precast Shear Wall Satisfying ACI 550.6 (ACI 550.7) and Commentary

Reported by Innovation Task Group 5

ACI 550.7-19



American Concrete Institute
Always advancing



Requirements for Design of a Special Unbonded Post-Tensioned Precast Shear Wall Satisfying ACI 550.6 (ACI 550.7) and Commentary

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

Order information: ACI documents are available in print, by download, through electronic subscription, or reprint, and may be obtained by contacting ACI.

ACI codes, specifications, and practices are made available in the ACI Collection of Concrete Codes, Specifications, and Practices. The online subscription to the ACI Collection is always updated, and includes current and historical versions of ACI’s codes and specifications (in both inch-pound and SI units) plus new titles as they are published. The ACI Collection is also available as an eight-volume set of books and a USB drive.

American Concrete Institute
5800 Country Club Drive
Farmington Hills, MI 48331
Phone: +1.248.848.3700
Fax: +1.248.848.3701

Requirements for Design of a Special Unbonded Post-Tensioned Precast Shear Wall Satisfying ACI 550.6 (ACI 550.7) and Commentary

An ACI Standard

Reported by ACI Innovation Task Group 5

Charles W. Dolan
Chair

Attila B. Beres
Ned M. Cleland
Neil M. Hawkins

Ronald Klemencic
Vilas S. Mujumdar
Suzanne Dow Nakaki

Stephen P. Pessiki
Carol K. Shield

John W. Wallace
Loring A. Wyllie, Jr.

Consulting member
S. K. Ghosh

This standard defines procedures that may be used to design special precast concrete shear walls, coupled or uncoupled, composed of discretely jointed precast panels that are vertically post-tensioned to the foundation with unbonded tendons. Such walls are suitable for use in regions of high seismicity and for structures assigned to high seismic design categories. After a major seismic event, these walls can be expected to exhibit minimal damage in the flexural hinging region at the base of the wall as well as negligible permanent displacements. Such walls do not satisfy the prescriptive requirements of Chapter 18 of ACI 318-14 for shear walls of monolithic construction. According to 18.2.1.7 of ACI 318-14, their acceptance requires demonstration by experimental evidence and analysis that the walls have strength and toughness equal to or exceeding those provided by comparable monolithic reinforced concrete walls that satisfy the prescriptive requirements of Chapter 18. This standard describes the procedures that the designer may use to demonstrate, through analysis, that one type of unbonded post-tensioned precast wall has strength and toughness at least equal to that of comparable special reinforced concrete monolithic walls. The standard consists of Design Requirements and a Commentary.

Among the subjects covered in these Design Requirements are requirements for:

1. Materials, including considerations for the coupling or connection devices, that provide the primary source of energy dissipation for the wall system;

2. Individual walls, including considerations to ensure ductility, energy dissipation, integrity, stiffness, and strength; and

3. Coupled walls, including considerations of the roles of the post-tensioning tendons and coupling devices in providing energy dissipation, and strength and stiffness for coupled walls greater than the sum of those provided by the coupled walls acting as separate units.

The Commentary references documentary evidence, additional to the references of ACI 550.6 and Chapter 18 of ACI 318R-14, that supports these Design Requirements. In this standard, however, no comparison is made between the performance of precast test modules satisfying the prescriptive requirements of ACI 318 and modules satisfying these Design Requirements but not satisfying ACI 318. Such comparisons, both experimental and analytical, are available in the cited references.

All references to ACI 318 and ACI 318R in these Design Requirements and Commentary refer to ACI 318-14 unless another edition of ACI 318 is specifically designated. All references to ASCE/SEI 7 in these Design Requirements and Commentary are to ASCE/SEI 7-10, including third printing updates.

In this standard, consistent with the format of ACI 318-14, the word "Section" is not included before a reference to a section of ACI 318-14. To more clearly designate a section in this standard, however, the word "Section" is used before any reference to a section of this standard. Consistent with the format of ASCE/SEI 7-10, the word "Section" is included before a reference to a section of ASCE/SEI 7-10.

Keywords: coupling devices; drift angle; energy dissipation; lateral resistance; post-tensioning; precast concrete; prestressed concrete; seismic design; special shear wall; test module; toughness.

CONTENTS

Chapter 1—General, p. 2

1.1—Introduction

ACI 550.7-19 supersedes ITG-5.2-09, was adopted May 4, 2009, and published September 2019.

Copyright © 2019, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

ACI Committee Reports, Guides, Manuals, Standard Practices, and Commentaries are intended for guidance in planning, designing, executing, and inspecting construction. This document is intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. The American Concrete Institute disclaims any and all responsibility for the stated principles. The Institute shall not be liable for any loss or damage arising therefrom.

Reference to this document shall not be made in contract documents. If items found in this document are desired by the Architect/Engineer to be a part of the contract documents, they shall be restated in mandatory language for incorporation by the Architect/Engineer.

- 1.2—Scope
- 1.3—Drawings

Chapter 2—Notation and definitions, p. 5

- 2.1—Notation
- 2.2—Definitions

Chapter 3—Referenced standards and reports, p. 7

Chapter 4—Materials, p. 8

- 4.1—General
- 4.2—Ducts
- 4.3—Reinforcement
- 4.4—Concrete
- 4.5—Interface grout
- 4.6—Coupling devices
- 4.7—Corrosion protection of prestressing tendons

Chapter 5—Structural system requirements for walls, p. 9

- 5.1—General
- 5.2—Strength
- 5.3—Drift
- 5.4—Wall characteristics
- 5.5—Distribution of walls within structures
- 5.6—Wall system-gravity load frame interactions

Chapter 6—Design requirements for uncoupled wall systems, p. 12

- 6.1—Scope
- 6.2—Materials
- 6.3—Prestress force
- 6.4—Energy-dissipating reinforcement
- 6.5—Shear strength
- 6.6—Flexural strength and drift limits
- 6.7—Detailing of lowermost wall panel
- 6.8—Interface grout

Chapter 7—Design requirements for coupled wall systems, p. 16

- 7.1—Scope
- 7.2—Materials
- 7.3—Coupling devices
- 7.4—Prestress force
- 7.5—Shear strength
- 7.6—Flexural strength and drift limits
- 7.7—Lowermost panel
- 7.8—Interface grout

Chapter 8—Design requirements for coupling devices, p. 18

- 8.1—Scope
- 8.2—General
- 8.3—Materials
- 8.4—Design methodology

Chapter 9—Commentary references, p. 20

CHAPTER 1—GENERAL

1.1—Introduction

For regions of high seismic risk, where structures assigned to Seismic Design Category (SDC) D, E, or F shall be used, 18.2.1.7 of ACI 318 permits the use of structural systems that do not meet the prescriptive requirements of Chapter 18 if certain experimental evidence and analysis are provided (all references to ACI 318 and ACI 318R in this standard refer to ACI 318-14 unless another edition of ACI 318 is specifically designated). The intent of ACI 550.6 is to define the minimum experimental evidence that is deemed sufficient to permit the use of unbonded post-tensioned precast structural wall systems, in accordance with 18.2.1.7 of ACI 318, when those systems do not satisfy fully the prescriptive requirements for wall systems in Chapter 18 of ACI 318.

Before validation testing can be undertaken, ACI 550.6 requires that a design procedure be developed for prototype wall systems having the generic form for which acceptance is sought, and that design procedure be used to proportion the test modules. This standard defines the design procedure for a specific type of wall system that does not satisfy the prescriptive requirements of Chapter 18 of ACI 318, but is validated for use in regions of high seismicity under ACI 550.6. The wall system uses precast concrete panels that are post-tensioned to the foundation and intended to rock on that foundation under seismic actions.

For coupled walls, coupling devices located along the vertical boundaries of adjacent walls provide the required energy dissipation and energy-dissipating reinforcement that cross the wall-foundation interface is unnecessary. During an earthquake, the coupled walls displace as rigid bodies that are tied together. Wall deformations occur primarily at the interface between each individual wall and the foundation, with each wall rocking separately at that interface.

The unbonded post-tensioning has two purposes. First, the post-tensioning steel is deliberately designed to remain essentially elastic during the design basis earthquake (DBE), defined in ASCE/SEI 7, so that it forces the walls to return to their undeformed positions following the event. Second, the friction induced by the post-tensioning and gravity loading on the wall transfers the horizontal shears due to lateral loadings at the interfaces between the wall and the foundation and between the precast panels of the wall.

The detailing procedures described in this standard are for one specific type of unbonded post-tensioned precast shear wall system, coupled or uncoupled. Four statements define key characteristics of uncoupled and coupled unbonded post-tensioned precast concrete cantilever shear walls that satisfy this standard:

- (a) Post-tensioning tendons unbonded from an anchor in the foundation to an anchor at the top of the wall and located in a single duct on the vertical centerline of the wall or, if needed, in two or more ducts positioned symmetrically on either side of that vertical centerline and within 10% of the wall length from that centerline;
- (b) Precast panels one story or more in height; and
- (c) For uncoupled walls, two sets of energy-dissipating reinforcing bars crossing the interface between the lower-