

An ACI Standard

Repair of Concrete in Buildings—Specification

Reported by ACI Committee 563

ACI SPEC 563-25



American Concrete Institute
Always advancing



Repair of Concrete in Buildings—Specification

© 2025 American Concrete Institute. All rights reserved.

This material may not be reproduced or copied, in whole or in part, in any form or by any means, including making copies by any photo process, or by electronic or mechanical device, printed, written, graphic, or oral, or recording for sound or visual reproduction for use in any knowledge or retrieval system or device, without the written consent of ACI. This material may not be used by data mining, robots, screen scraping, or similar data gathering and extraction tools such as artificial intelligence (“AI”) for purposes of developing or training a machine learning or AI model, conducting computer analysis or creating derivatives of this material, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. Despite these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations regarding health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

ACI documents are written via a consensus-based process. The characteristics of ACI technical committee operations include:

- (a) Open committee membership
- (b) Balance/lack of dominance
- (c) Coordination and harmonization of information
- (d) Transparency of committee activities to public
- (e) Consideration of views and objections
- (f) Resolution through consensus process

The technical committee documents of the American Concrete Institute represent the consensus of the committee and ACI. Technical committee members are individuals who volunteer their services to ACI and specific technical committees.

American Concrete Institute®, ACI®, and Always Advancing® are registered trademarks of American Concrete Institute.

Repair of Concrete in Buildings—Specification

An ACI Standard

Reported by ACI Committee 563

John S. Lund, Chair

Karen Polanco*, Secretary

Jason Coleman
Jorge Costa
Peter Emmons
Paul E. Gaudette
Timothy R. W. Gillespie
Matthew R. Hansen

Susan Isble
Jason S. Johnson
Kevin R. Krawiec
Kenneth M. Lozen
Marjorie M. Lynch
Paul A. Noyce

Jose Pacheco
Clyde Porter Jr.
Brian E. Pulver
James A. Ragland
Michael M. Sprinkel†
Kyle Stanish*

Michael S. Tenko
Gene K. Stevens
David J. VanOcker
David W. Whitmore

Consulting Members

Fred R. Goodwin
Kevin A. Michols

Lawrence F. Kahn

Tracy D. Marcotte
Jay H. Paul

*Editorial committee members.

†Michael Sprinkel was a committee member of ACI 563 from its inception in 2007 and chaired the Overlays subcommittee at the time of his death in December 2022. The committee expresses its deepest appreciation for his friendship and leadership.

This is a Reference Specification that the Architect/Engineer can apply to any construction repair and rehabilitation project involving structural concrete by citing it in the Project Specifications. Mandatory requirements and optional requirements checklists are provided to assist the Architect/Engineer in supplementing the provisions of this Specification, as required or needed by designating or specifying individual project requirements. The first section covers general construction requirements for repair work. The second section covers shoring and bracing of the structure or member to be repaired, and addresses sequencing of repair work as the structure is unloaded and reloaded. The third section covers concrete removal and preparation of the concrete substrate for repair and defines common equipment and methods. The next five sections cover materials and proportioning of concrete; proprietary cementitious and polymer-modified materials; reinforcement; production, placing, finishing, and curing of repair materials; formwork performance criteria and construction; treatment of joints; embedded items; repair of surface defects; mockups, and finishing of formed and unformed surfaces. New sections included in this edition of the Specification includes waterproofing cracks by chemical grout injection, architectural concrete repair, structural precast concrete repair, unbonded post-tensioned concrete repair, overlays, protective membranes, and cathodic protection by galvanic anodes. Provisions governing testing, evaluation, and acceptance of repair materials as well as acceptance of the repair work are included. Sections 16, 17 and 18 incorporate by reference other ACI specifications into this ACI Standard: ACI SPEC-503.7 for crack repair by epoxy injection, ACI SPEC-506.2 for shotcrete, and ACI SPEC-440.12 for wet-layup FRP.

Keywords: bracing; cold weather; compressive strength; consolidation; curing; durability; epoxy injection; finish; formwork; grouting; hot weather; inspection; joints; mockups; placing; precast; rehabilitation; repair; reshoring; shoring; shotcrete; slab; steel reinforcement; surface preparation; testing; tolerance; welded wire.

CONTENTS

- SECTION 1—GENERAL REQUIREMENTS, p. 2**
 - 1.1—Scope, p. 2
 - 1.2—Interpretation, p. 2
 - 1.3—Definitions, p. 3
 - 1.4—Referenced standards, p. 4
 - 1.5—General procedures, p. 7
 - 1.6—Preinstallation conference, p. 7
 - 1.7—Submittals, p. 7
 - 1.8—Quality assurance, quality control, testing, and inspection, p. 7
 - 1.9—Acceptance of repair work, p. 10
 - 1.10—Repair material manufacturer’s technical support and field representative, p. 10
- SECTION 2—SHORING AND BRACING, p. 10**
 - 2.1—General, p. 10
 - 2.2—Products, p. 11
 - 2.3—Execution, p. 11

ACI SPEC-563-25 supersedes ACI 563-18 and was approved by the ACI Standards Board for publication January 2025, and published March 2025. This Specification was first published in 2018 and revised in 2018.

Copyright © 2025, American Concrete Institute.

This material may not be reproduced or copied, in whole or in part, in any form or by any means, including making copies by any photo process, or by electronic or mechanical device, printed, written, graphic, or oral, or recording for sound or visual reproduction for use in any knowledge or retrieval system or device, without the written consent of ACI. This material may not be used by data mining, robots, screen scraping, or similar data gathering and extraction tools such as artificial intelligence (“AI”) for purposes of developing or training a machine learning or AI model, conducting computer analysis or creating derivatives of this material, without the written consent of ACI.

SECTION 3—CONCRETE REMOVAL AND PREPARATION FOR REPAIR, p. 11

- 3.1—General, p. 11
- 3.2—Products, p. 12
- 3.3—Execution, p. 12

SECTION 4—FORMWORK, p. 13

- 4.1—General, p. 13
- 4.2—Products, p. 13
- 4.3—Execution, p. 14

SECTION 5—REINFORCEMENT AND REINFORCEMENT SUPPORTS, p. 16

- 5.1—General, p. 16
- 5.2—Products, p. 16
- 5.3—Execution, p. 18

SECTION 6—CONVENTIONAL CONCRETE MIXTURES, p. 20

- 6.1—General, p. 20
- 6.2—Products, p. 21
- 6.3—Execution, p. 25

SECTION 7—HANDLING AND PLACING OF CONVENTIONAL CONCRETE, p. 25

- 7.1—General, p. 25
- 7.2—Products, p. 26
- 7.3—Execution, p. 26

SECTION 8—PROPRIETARY CEMENTITIOUS AND POLYMER REPAIR MATERIALS, p. 30

- 8.1—General, p. 30
- 8.2—Products, p. 31
- 8.3—Execution, p. 31

SECTION 9—WATERPROOFING CRACKS BY CHEMICAL GROUT INJECTION, p. 32

- 9.1—General, p. 32
- 9.2—Products, p. 32
- 9.3—Execution, p. 33

SECTION 10—ARCHITECTURAL CONCRETE REPAIR, p. 33

- 10.1—General, p. 33
- 10.2—Products, p. 34
- 10.3—Execution, p. 35

SECTION 11—STRUCTURAL PRECAST CONCRETE, p. 37

- 11.1—General, p. 37
- 11.2—Products, p. 37
- 11.3—Execution, p. 38

SECTION 12—REPAIR OF UNBONDED POST-TENSIONED CONCRETE, p. 39

- 12.1—General, p. 39
- 12.2—Products, p. 40
- 12.3—Execution, p. 41

SECTION 13—OVERLAYS, p. 43

- 13.1—General, p. 43
- 13.2—Products, p. 43
- 13.3—Execution, p. 44

SECTION 14—PROTECTIVE MEMBRANES, p. 45

- 14.1—General, p. 45
- 14.2—Products, p. 46
- 14.3—Execution, p. 46

SECTION 15—CATHODIC PROTECTION BY GALVANIC ANODES, p. 48

- 15.1—General, p. 48
- 15.2—Products, p. 48
- 15.3—Execution, p. 49

SECTION 16—CRACK REPAIR BY EPOXY INJECTION (ACI SPEC-503.7), p. 49**SECTION 17—SPECIFICATION FOR SHOTCRETE (ACI SPEC-506.2), p. 49****SECTION 18—SPECIFICATION FOR WET-LAYUP FRP (ACI SPEC-540.12), p. 49****NOTES TO SPECIFIER, p. 49**

- General notes, p. 49
- Foreword to checklists, p. 50

SECTION 1—GENERAL REQUIREMENTS**1.1—Scope**

1.1.1 This Specification covers repair of concrete in existing structures.

1.1.2 This Specification is incorporated by Contract Documents and provides requirements for Contractor.

1.1.3 This Specification governs for construction within its scope, except project-specific Contract Documents govern if there is a conflict.

1.1.4 This Specification governs if there is a conflict with referenced material and testing standards.

1.1.5 Contractor is permitted to submit written alternatives to any provision in this Specification for consideration.

1.1.6 Do not use this Specification in conjunction with **ACI SPEC-301**, **ACI SPEC-350.5**, or **ACI CODE-530/530.1-13** unless Contract Documents state that this Specification governs for Work covered by 1.1.1.

1.1.7 Ignore provisions of this specification that are not applicable to Work.

1.1.8 Values in this Specification are stated in inch-pound units. A companion specification in SI units is available.

1.1.9 The Notes to Specifier are not part of this Specification.

1.2—Interpretation

1.2.1 Unless otherwise explicitly stated, this Specification shall be interpreted using the following principles: