



ANSI B109.4
October 29, 2021

**Self-Operated Diaphragm-Type
Natural Gas Service Regulators**

For Nominal Pipe Size 1¼ inches (32 mm) and smaller
with outlet pressures of 7 psi (13.8 kPa) and less

Secretariat



400 North Capitol Street, NW 4th Floor
Washington, DC 20001
U.S.A.

Catalog No. X62104

First Edition–1998
Second Edition–2016
Third Edition–2021

Copyright © 2021, American Gas Association
All rights reserved

Currently in preview, click buy full version

Table of Contents

TABLE OF CONTENTS	i
DISCLAIMERS AND COPYRIGHT	ii
PREFACE	iv
HISTORY OF DEVELOPMENT OF THE STANDARD	v
ACCREDITED STANDARDS COMMITTEE B109	vi
1.0 Scope	1
2.0 Definitions	1
3.0 General	4
4.0 Design Requirements	5
4.1 Regulator Valve Body.....	5
4.2 Diaphragm Casing Assembly.....	6
4.3 Diaphragm.....	7
4.4 Loading Spring.....	7
4.5 Valve Linkage and Disk.....	7
4.6 Orifice.....	8
4.7 Exterior Surface.....	8
4.8 Vent.....	9
4.9 Markings.....	10
5.0 Qualification Test for Service Regulator Performance	11
5.1 General.....	11
5.2 Test Equipment.....	11
5.3 Regulator Test Procedures.....	12
5.4 Slam Shut Test Procedures.....	21
APPENDIX A: GUIDELINES FOR PRESENTATION OF REGULATOR PERFORMANCE DATA	26
APPENDIX B: SI/METRIC SYMBOLS	31
APPENDIX C: U.S. (INCH-POUND) SYMBOLS	32
APPENDIX D: REFERENCE STANDARDS	33
FORM FOR PROPOSAL TO ANSIB109.4	34

AMERICAN GAS ASSOCIATION (AGA) NOTICE AND DISCLAIMER

This document was developed through a voluntary consensus standards development process via the American National Standards Institute (ANSI) essential requirements for due process for American National Standards (Edition January 2014). While the American Gas Association (AGA) administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document, and it does not independently test, evaluate or verify the accuracy or completeness of any information or the soundness of any judgments contained in this publication.

The AGA disclaims liability for any personal injury, property damages or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from this publication, the use of or reliance on this publication. The AGA also makes no guarantee or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the AGA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the AGA undertaking to perform a duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The AGA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the AGA list, certify, test or inspect products, designs or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the AGA and is solely the responsibility of the certifier or maker of the statement.

The AGA does not take any position with respect to the validity of any patent rights asserted in connection with any items that are mentioned in or are the subject of this publication, and the AGA disclaims liability for the infringement of any patent resulting from the use of or reliance on it. Users of this publication are expressly advised that determination of the validity of any such patent rights and the risk of infringement of such rights is entirely their own responsibility.

Users of this publication should consult applicable federal, state, and local laws and regulations. The AGA does not, through this publication, provide legal advice for any purpose or intend to urge action that is not in compliance with applicable laws and this publication may not be construed as doing so.

Changes to this document may become necessary from time to time. If changes are believed appropriate by any person or entity, such suggested changes should be communicated to AGA in writing using the form found at the end of the document titled, Form For Proposals on ANSI B109.4 and sent to: American Gas Association, ATTN: Secretariat B-09, 400 North Capitol Street, NW, Suite 450, Washington, DC 20001, U.S.A. Suggested changes must include: contact information, including name, address and any corporate affiliation; full name of the document; suggested revisions to the text of the document; the rationale for the suggested revisions; and permission to use the suggested revisions in an amended publication of the document.

Copyright © 2021 American Gas Association, All Rights Reserved.

Permission is granted to republish material herein in laws or ordinances as well as regulations, administrative orders or similar documents issued by public authorities. Those desiring permission for other publication should consult the American Gas Association, ATTN: ANSI B109.4 Secretariat, 400 N. Capitol St., NW, Washington, DC, U.S.A.

Currently in preview, click buy full version

PREFACE

This publication presents a basic standard for the safe and reliable operation and the substantial and durable construction of self-operated diaphragm-type natural gas service regulators for nominal pipe size of 1¼ inches (32 mm) and smaller with outlet pressure of 2 psig (3.48 kPa) and less. This work is the result of years of experience that has been supplemented by extensive research. The standard is intended to meet the minimum design, material, performance and testing requirements for efficient use of service regulators.

It is recognized that during any transition period to the metric system, sizes and dimensions need to be expressed in either the metric system or the inch-pound system or both. In this document, both systems are used with the inch-pound units given preference. In most cases, a soft conversion from existing inch-pound values is shown. Soft conversion implies a change in nomenclature only. In this document, the alternative nomenclatures (metric and inch-pound) are shown by using parentheses and can be used interchangeably.

Nothing in this standard is to be considered as in any way indicating a measure of quality beyond compliance with the provisions it contains. It is designed to allow the construction and performance of service regulators that may exceed the various provisions specified in any respect. In this standard's preparation, recognition was intended to be given to the possibility of improvement, through the ingenuity of design or otherwise. As progress takes place, revisions may become necessary. Whenever such revisions are believed desirable, recommendations should be forwarded to the Chairman of ANSI B109 Committee, American Gas Association, 400 N. Capitol St., NW, Washington, DC 20001

Users of this document should consult applicable federal, state and local regulations. The AGA does not, by the publication of this document, intend to present specifications that are not in compliance with applicable rules, and this document may not be construed as doing so.

NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute Inc. (ANSI) require that action is taken to reaffirm, revise or withdraw this standard no later than five years from the date of publication. Whenever any revisions are deemed advisable, recommendations should be forwarded to the **American Gas Association**. A form is included for that purpose at the end of this standard. Purchasers of American National Standards may receive current information on all standards by writing to the **American National Standards Institute Inc.**, 11 West 42nd Street, New York, NY 10036, U.S.A. by calling (212) 642-4900; by faxing ANSI at (212) 398-0023; or by visiting ANSI's website at <http://www.ansi.org>. To purchase additional copies, visit Techstreet's website at <http://www.techstreet.com/aga>.

HISTORY OF DEVELOPMENT OF THE STANDARD FOR SELF-OPERATED DIAPHRAGM-TYPE GAS SERVICE REGULATORS

In December 1989 at an ad hoc meeting, representatives of the ANSI Z223.1 and Z21 committees, AGA, Gas Appliance Manufacturers Association (GAMA) and several other industry organizations recommended that an ANSI standard for service regulators be developed. It was recognized that a systems approach to pressure control and over-pressure protection was necessary to ensure consistency between the ANSI standards that cover the houseline and the utilization equipment. In April 1990, a revision that added service regulators to the scope of ANSI B109 ASC was approved.

The AGA Operating Section assembled a service regulator standard development task group with representatives from the AGA Distribution Measurement Committee, Customer Service and Utilization Committee, Distribution Engineering Committee and the major service regulator manufacturers. A representative from the Committee on Canadian Gas Service Regulator Standard was also included. Throughout the development, consideration was given to harmonizing the new standard with the Canadian standard. A first draft was completed in 1993. The draft was revised a number of times and was approved by the AGA Operating Section before it was presented to the ANSI B109 Accredited Standard Committee in January 1996.

The ANSI B109 Accredited Standard Committee requested comments on the proposed service regulator standard in May 1996. During a public meeting on Jan. 30, 1997, the committee addressed the comments and approved the standard for submittal to ANSI for endorsement as an American National Standard. The first edition was approved in April 1998.

The B109 Committee reaffirmed the existing standard in 2003. In 2009 the Committee submitted a Project Initiation Notification (PINS) to begin the revision process. Begun in 2010, the revision of the standard included deliberation on topics like salt spray test and high-density polyethylene (HDPE). The revision process concluded in December 2016 with the publication of the second edition incorporating setpoints up to 2 psig and recommended maximum allowable operating pressures (MAOP) downstream.

The third edition addresses the use of integral slam shut valves used to shut off the supply of gas from the service regulator as another means of over-pressure protection (OPP). The slam shut device is commonly used outside of North America as a primary means of OPP. In some installations, venting of gas through an internal relief valve may not be allowed due to clearance issues and population density in the immediate area of the regulator. The committee added language to accommodate slam shut valves and testing criteria used to validate their design and performance.

**ACCREDITED STANDARDS COMMITTEE B109
2021**

CHAIR

Pat Donnelly, NiSource

REPRESENTING USERS

Michael Avery, National Grid
Daniel Bustamante, Southern California Gas
Patrick Donnelly, NiSource
Melissa Fearing, Xcel Energy
Matt Holsten, Black Hills Energy
James Sherrod, Liberty Utilities
John Valdez, CenterPoint Energy

REPRESENTING PRODUCERS

Max Ambrosi, Pietro Fiorentini
John Anderson, Emerson
Jon Fickinger, Iron
Scott Laplante, Mulcare
Phil Silius, Honeywell
Ron Strong, Dresser Natural Gas Solutions
Chris Wykle, Sensus

REPRESENTING GENERAL INTEREST

Ardis Bartle, APEX Measurement & Controls
Ray Deatherage, Gas Technology Institute
Winston Meyer, Consultant
Damon Myers, Colorado Engineering Experiment Station
Ralph Richter, National Institute of Standards & Technology
John Skinner, CSA Group
Bruce Swiecicki, National Propane Gas Association

SECRETARY

Luis Romeo Escobar, Secretariat

1.0 Scope

This standard shall apply to the minimum design, material, performance and testing requirements of 1¼ inches (32 mm) and smaller self-operated diaphragm-type natural gas service regulators operating at inlet pressures up to 125 psig (861.8 kPa). These regulators are used to control the gas delivery pressure (also referred to as set pressure or P_2) to pressures at 2 psig or less (13.8 kPa). This standard shall apply only to regulators manufactured after the approval date of this standard.

This standard includes overpressure protection options including internal relief valves (IRVs) and self-operated integral slam shut valves.

2.0 Definitions

Regulator Accuracy: The deviation in outlet pressure from the set point.

Slam-Shut Accuracy Group: The deviation in outlet pressure from the set point measured as a percentage.

Bypass: A device, usually internal to the slam shut, that allows the equalization of pressure across the slam shut valve in order to reset it from a closed position.

Casings: The casing is a pressure retaining part of the regulator which encloses either the spring and/or diaphragm assembly.

Diaphragm: A flexible element used to sense the outlet pressure and, in combination with the loading spring and linkage, to position the valve to control the downstream pressure.

Diaphragm Case or Casing: The housing for the diaphragm usually consists of an atmospheric or ambient casing and a gas or fuel casing. The gas or fuel casing and the diaphragm form the gas or fuel chamber. The atmospheric or ambient casing and the diaphragm form the atmospheric or ambient chamber. The diaphragm seals and separates the gas or fuel chamber from the atmospheric or ambient chamber. The atmospheric or ambient chamber houses the loading spring and vents into the atmosphere.

Diaphragm Plate: A rigid disk in contact with the diaphragm, which transmits the force of the loading mechanism (weights, springs, etc.) to the diaphragm.

Droop: The drop in outlet pressure from set point with respect to increasing gas flow rate.

Fixed-Factor Regulation: Regulator accuracy held to typically +/- 1% absolute (ABS) of set pressure or P_2 , which will allow a utility to meter gas without doing pressure correction at the meter.

Hysteresis: Characteristic used to describe a deviation in the regulator performance based on internal friction, the diaphragm material and flow. This may also be referred to as regulator deadband.

Inlet Pressure, Rated: The highest inlet pressure allowed to be supplied to the regulator.

Inlet Pressure, Maximum: The highest inlet pressure to which tests have been conducted to determine that the regulator will control the outlet pressure within acceptable limits.