



ANSI B109.5

April 2024

Self-Operated Diaphragm Type Natural Gas Service Regulators

For Nominal Pipe Size up to and including 2 inches (50 mm) and inlet pressures up to 125 psig (861.8 kPa) with outlet pressure of 20 psig (138 kPa) or less not covered in ANSI B109.4

Secretariat



400 North Capitol Street, NW 4th Floor
Washington, DC 20001
U.S.A.

Catalog No. X62405

First Edition—2024

American Gas Association
400 North Capitol St., NW, Suite 405
Washington, DC 20001

Catalog No. X62405

AMERICAN NATIONAL STANDARDS INSTITUTE, INC.
Copyright © 2024, American Gas Association

Table of Contents

TABLE OF CONTENTS.....	i
DISCLAIMERS AND COPYRIGHT.....	ii
PREFACE	iv
HISTORY OF DEVELOPMENT OF THE STANDARD	v
ACCREDITED STANDARDS COMMITTEE B109.....	vi
1.0 Scope.....	7
2.0 Definitions	7
3.0 General	11
4.0 Design Requirements.....	12
4.0 Diaphragm Casing Assembly.....	13
4.1 Diaphragm	14
4.2 Loading Spring.....	14
4.3 Valve Linkage and Disk.....	14
4.4 Orifice	15
4.5 Exterior Surface.....	15
4.6 Vent.....	16
4.7 Markings.....	17
5.0 Qualification Test for Service Regulator Performance.....	18
5.1 General	18
5.2 Test Equipment.....	18
5.3 Regulator Test Procedures	19
5.4 Slam Shut Test Procedures	27
5.5 Internal Monitor Test Procedure	29
5.6 Integral Monitor Test Procedure.....	31
APPENDIX A: GUIDELINES FOR PRESENTATION OF REGULATOR PERFORMANCE DATA.....	34
APPENDIX B: SI/METRIC SYMBOLS	39
APPENDIX C: U.S. (INCH-POUND) SYMBOLS.....	40
APPENDIX D: REFERENCED STANDARDS	41
FORM FOR PROPOSAL ON ANSIB109.4.....	42

AMERICAN GAS ASSOCIATION(AGA) NOTICE AND DISCLAIMER

This document was developed through a voluntary consensus standards development process via the American National Standards Institute (ANSI) essential requirements for due process for American National Standards (Edition January 2014). While the American Gas Association (AGA) administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document, and it does not independently test, evaluate or verify the accuracy or completeness of any information or the soundness of any judgment contained in this publication.

The AGA disclaims liability for any personal injury, property damages or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from this publication, the use of or reliance on this publication. The AGA also makes no guarantee or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the AGA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the AGA undertaking to perform a duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The AGA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the AGA list, certify, test or inspect products, designs or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the AGA and is solely the responsibility of the certifier or maker of the statement.

The AGA does not take any position with respect to the validity of any patent rights asserted in connection with any items that are mentioned in or are the subject of this publication, and the AGA disclaims liability for the infringement of any patent resulting from the use of or reliance on it. Users of this publication are expressly advised that determination of the validity of any such patent rights and the risk of infringement of such rights is entirely their own responsibility.

Users of this publication should consult applicable federal, state, and local laws and regulations. The AGA does not, through this publication, provide legal advice for any purpose or intend to urge action that is not in compliance with applicable laws and the publication may not be construed as doing so.

Changes to this document may become necessary from time to time. If changes are believed appropriate by any person or entity, such suggested changes should be communicated to AGA in writing using the form found at the end of the document titled, Form For Proposals on ANSI B109.5 and sent to: American Gas Association, ATTN: Secretariat B-09, 400 North Capitol Street, NW, Suite 450, Washington, DC 20001, U.S.A. Suggested changes must include: contact information, including name, address and any corporate affiliation; full name of the document; suggested revisions to the text of the document; the rationale for the suggested revisions; and permission to use the suggested revisions in an amended publication of the document.

Copyright © 2024 American Gas Association, All Rights Reserved.

Permission is granted to republish material herein in laws or ordinances as well as regulations, administrative orders or similar documents issued by public authorities. Those desiring permission for other publication should consult the American Gas Association, ATTN: B109 Secretary, 400 N. Capitol St., NW, Washington, DC, U.S.A.

Currently in preview, click buy full version

PREFACE

This publication presents a basic standard for the safe and reliable operation and the substantial and durable construction of self-operated diaphragm-type natural gas service regulators for nominal pipe size up to and including 2 inches (50 mm) and smaller with outlet pressure up to 20 psig (138 kPa) and less. This work is the result of years of experience that has been supplemented by extensive research. The standard is intended to meet the minimum design, material, performance and testing requirements for efficient use of service regulators.

It is recognized that during any transition period to the metric system, sizes and dimensions need to be expressed in either the metric system or the inch-pound system or both. In this document, both systems are used with the inch-pound units given preference. In most cases, a soft conversion from existing inch-pound values is shown. Soft conversion implies a change in nomenclature only. In this document, the alternative nomenclatures (metric and inch-pound) are shown by using parentheses and can be used interchangeably.

Nothing in this standard is to be considered as in any way indicating a measure of quality beyond compliance with the provisions it contains. It is designed to allow the construction and performance of service regulators that may exceed the various provisions specified in any respect. In this standard's preparation, recognition was intended to be given to the possibility of improvement, through the ingenuity of design or otherwise. As progress takes place, revisions may become necessary. Whenever such revisions are believed desirable, recommendations should be forwarded to the Chairman of ANSI B109 Committee, American Gas Association, 400 N. Capitol St., NW, Washington, DC 20001

Users of this document should consult applicable federal, state and local regulations. The AGA does not, by the publication of this document, intend to present specifications that are not in compliance with applicable rules, and this document may not be construed as doing so.

NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute Inc. (ANSI) require that action is taken to reaffirm, revise or withdraw this standard no later than five years from the date of publication. Whenever any revisions are deemed advisable, recommendations should be forwarded to the **American Gas Association**. A form is included for that purpose at the end of this standard. Purchasers of American National Standards may receive current information on all standards by writing to the **American National Standards Institute Inc.**, 11 West 42nd Street, New York, NY 10036, U.S.A., by calling (212) 642-4900; by faxing ANSI at (212) 398-0023; or by visiting ANSI's website at <http://www.ansi.org>. To purchase additional copies, visit Techstreet's website at <http://www.techstreet.com/aga>.

HISTORY OF DEVELOPMENT OF THE STANDARD FOR SELF-OPERATED DIAPHRAGM-TYPE GAS SERVICE REGULATORS

The first edition of the ANSI B109.4 Standard for Self-Operated Diaphragm-Type Natural Gas Regulators (nominal pipe size 1-1/4 inches and smaller with outlet pressure of 2 psi and less) was approved in April 1998. The standard was subsequently revised in December 2016 (second edition) and October 2021 (third edition).

In early-2020 the B109 Committee began discussion of the need for a new standard for regulators not covered by the B109.4 Standard, i.e., commercial and industrial regulators. In May 2020 the Committee submitted a Project Initiation Notification (PINS) to begin development of a new standard project to address self-operated diaphragm-type regulator with nominal pipe size up to 2 inches (50 mm). This new standard would be designated as B109.5 Standard.

The B109 Committee established the B109.5 Task Group at their virtual Fall 2020 meeting. This new B109.5 Task Group began meeting virtually in early-2021 and continued development throughout 2021 and 2022.

The B109 Committee approved the standard for submittal to ANSI for endorsement as an American National Standard on April 15, 2024. The first edition was approved on April 16, 2024.

**ACCREDITED STANDARDS COMMITTEE B109
2024**

B109 Committee Officers	Pat Donnelly, Chair Scott Laplante, Vice Chair
Members Representing Users	Michael Avery, National Grid Maz Bijan, Pacific Gas and Electric Daniel Bustamante, Southern California Gas Company Patrick Donnelly, NiSource Mat Holsten, Black Hills Energy
Members Representing Producers	Max Ambrosi, Pietro Fiorentini Jon Fickinger, Itron Danny Fields, USG Scott Laplante, PERC/Murphy Steve Schamber, Lancaster Gas Phil Silvius, Honeywell Ron Strong, Dresser Natural Gas Solutions Chris Wykle, Sensus
Members Representing General Interest	Ardis Bartle, APFX Measurement & Controls Joe Carlstrom, GTI Energy Winston Meyer, Consultant Ralph Rickert, National Institute of Standards & Technology John Skinner, CSA Group Bruce Swiecicki, National Propane Gas Association
Secretariat	Luis Romeo Escobar, American Gas Association

B109 Task Group		
Task Group Lead: Max Ambrosi, Pietro Fiorentini		
Matt Holsten, Black Hills Energy Winston Meyer, Consultant John Todd, Control Southern Ron Strong, Dresser Brian Weaver, EC John Anderson, ret. Emerson Tony Durant, Emerson Isaac Dresser, prev. Emerson Abu Aljabouri, Honeywell	Gavin Steele, Enbridge Tod Bradley, Equipment Controls Peter Klock, ESC Engineering Phil Silvius, Honeywell Jon Fickinger, Itron James Sherrod, prev. Liberty Utilities Paul Gugliotta, National Grid Patrick Donnelly, NiSource Joe Carlstrom, GTI	Max Ambrosi, Pietro Fiorentini Collin Bozzarello, ProconexDirect Kevin Burke, ProconexDirect Robbie Swigert, ROOTS Regulators Jennifer Voekler, ROOTS Regulators Eric Burgett, ROOTS Regulators Melissa Fearing, Xcel Energy Danny Fields, USG

1.0 Scope

This standard shall apply to the minimum design, material, performance, and testing requirements of natural gas service regulators up to and including 2 inches (50 mm) not covered in ANSI B109.4 and inlet pressures up to 125 psig (861.8 kPa). These regulators are used to control the gas delivery pressure (also referred to as set pressure or P2) to pressures at 20 psig or less (138 kPa). This standard shall apply only to regulators manufactured after the approval date of this standard.

This standard includes overpressure protection options including internal relief valves (IRVs), self-operated integral slam shut valves, integral monitors, and internal monitors.

2.0 Definitions

Regulator Accuracy: The deviation in outlet pressure from the set point.

Slam-Shut Accuracy Group: The deviation in outlet pressure from the setpoint measured as a percentage.

Bypass: A device, usually internal to the slam shut, that allows the equalization of pressure across the slam shut valve in order to reset it from a closed position.

Casings: The casing is a pressure retaining part of the regulator which encloses either the spring and/or diaphragm assembly.

Diaphragm: A flexible element used to sense the outlet pressure and, in combination with the loading spring and linkage, to position the valve to control the downstream pressure.

Diaphragm Case or Casing: The housing for the diaphragm usually consists of an atmospheric or ambient casing and a gas or fuel casing. The gas or fuel casing and the diaphragm form the gas or fuel chamber. The atmospheric or ambient casing and the diaphragm form the atmospheric or ambient chamber. The diaphragm seals and separates the gas or fuel chamber from the atmospheric or ambient chamber. The atmospheric or ambient chamber houses the loading spring and vents into the atmosphere.

Diaphragm Plate: A rigid disk in contact with the diaphragm, which transmits the force of the loading mechanism (weights, springs, etc.) to the diaphragm.

Droop: The drop in outlet pressure from set point with respect to increasing gas flow rate.

Fixed-Factor Regulation: Regulator accuracy held to typically +/- 1% absolute (ABS) of set pressure or P2, which will allow a facility to meter gas without doing pressure correction at the meter.

Full relief: A relief valve with sufficient capacity to provide a full layer of over pressure protection for the regulator's full capacity at specified conditions.

Hysteresis: Characteristic used to describe a deviation in the regulator performance based on internal friction of the diaphragm material and flow. This may also be referred to as regulator dead band.

Inlet Pressure, Rated: The highest inlet pressure allowed to be supplied to the regulator.

Inlet Pressure, Maximum: The highest inlet pressure to which tests have been conducted to determine that the regulator will control the outlet pressure within acceptable limits.