



**ANSI B109.3**  
Approved  
Revised February 5, 2019

**ROTARY-TYPE  
GAS DISPLACEMENT METERS**

**Secretariat**



400 North Capitol Street, NW, 4<sup>th</sup> Floor  
Washington, DC 20001  
U.S.A.

**Catalog No. XM1901**

First Edition–1973  
Second Edition–1986  
Third Edition–1992  
Fourth Edition–2000  
Fifth Edition–2019

American Gas Association  
400 North Capitol St., NW, 4<sup>th</sup> Floor  
Washington, DC 20001  
U.S.A.

Catalog No. XM1901

Approved  
February 5, 2019  
AMERICAN NATIONAL STANDARDS INSTITUTE, INC.

Copyright © 2019, American Gas Association  
All rights reserved

Currently in preview, click buy full version

# Contents

<b>PREFACE</b> .....	<b>5</b>
<b>HISTORY OF THE DEVELOPMENT OF THIS STANDARD</b> .....	<b>6</b>
<b>ACCREDITED STANDARDS COMMITTEE B109</b> .....	<b>7</b>
<b>SCOPE</b> .....	<b>8</b>
<b>PART I</b> .....	<b>9</b>
<b>DEFINITIONS</b> .....	<b>9</b>
<b>PART II</b> .....	<b>14</b>
<b>CONSTRUCTION REQUIREMENTS FOR QUALIFYING NEW-TYPE METERS</b> .....	<b>14</b>
2.1 SCOPE .....	14
2.2 DIMENSIONS .....	14
2.3 MAXIMUM ALLOWABLE OPERATING PRESSURE (MAOP) .....	14
2.4 STRENGTH OF METER CONNECTIONS .....	15
2.5 METER INDEX WINDOW IMPACT RESISTANCE TESTS .....	16
2.6 DESIGN SAFETY FACTOR .....	16
2.7 DIFFERENTIAL PRESSURE TAPS .....	17
2.8 METER IDENTIFICATION .....	17
2.9 FLOW DIRECTION IDENTIFICATION .....	17
2.10 METER OUTPUT REGISTRATION IDENTIFICATION .....	17
2.11 PROTECTION OF METERS .....	18
2.12 MECHANICAL METER INDEX .....	18
2.13 CORROSION AND CHEMICAL RESISTANCE OF INTERNAL PARTS .....	19
2.14 CORROSION AND CHEMICAL RESISTANCE OF EXTERNAL PARTS .....	19
2.15 TEMPERATURE RESISTANCE TEST .....	19
<b>PART III</b> .....	<b>20</b>
<b>PERFORMANCE REQUIREMENTS FOR QUALIFYING NEW METERS AND NEW-TYPE METERS</b> .....	<b>20</b>
3.1 SCOPE .....	20
3.2 RATED CAPACITY .....	20
3.3 ACCURACY .....	20
3.4 NOISE AND VIBRATION .....	20
3.5 STARTING RATE TEST FOR NEW-TYPE METERS .....	20
3.6 PRESSURE AND LEAK TEST CONDITIONS FOR NEW METERS .....	21
3.7 DIFFERENTIAL PRESSURE TEST CONDITIONS .....	21
<b>PART IV</b> .....	<b>22</b>
<b>IN-SERVICE PERFORMANCE</b> .....	<b>22</b>
4.1 SCOPE .....	22
4.2 TEST CONDITIONS .....	22
4.3 IN-SERVICE PERFORMANCE PROGRAMS .....	22
<b>PART V</b> .....	<b>23</b>
<b>METER INSTALLATION</b> .....	<b>23</b>

5.1 SCOPE.....	23
5.2 GENERAL .....	23
5.3 LOCATION .....	23
5.4 INSTALLATION .....	23
5.5 METER SHUT OFF .....	24
5.6 METER SUPPORT .....	24
5.7 METER SIZING .....	24
5.8 SPACING OF METERS.....	24
5.9 IDENTIFICATION .....	24
5.10 ON-SITE INSPECTION .....	24
5.11 SPECIAL SERVICE .....	24
5.12 DUAL METER INSTALLATIONS .....	24
<b>PART VI.....</b>	<b>25</b>
<b>AUXILIARY DEVICES FOR GAS METERS .....</b>	<b>25</b>
6.1 SCOPE.....	25
6.3 TEMPERATURE SYSTEM .....	27
6.4 VOLUME INDICATOR .....	29
6.5 INSTRUMENT CHART DRIVES .....	29
6.6 CIRCULAR CHARTS.....	30
6.7 RECORDERS.....	31
6.8 AUTOMATIC INTEGRATORS .....	33
6.9 CONSTANT-PRESSURE-COMPENSATING INDEX .....	33
6.10 REMOTE METER READING DEVICES .....	34
6.11 INSTRUMENT ADAPTOR PLATES .....	35
6.12 INSPECTION AND TESTING CLASSIFICATION .....	35
<b>PART VII.....</b>	<b>38</b>
<b>TEST METHODS AND EQUIPMENT .....</b>	<b>38</b>
7.1 SCOPE.....	38
7.2 MEASUREMENT REFERENCE BASE .....	38
7.3 UNITS OF MEASURE .....	38
7.4 BASE CONDITIONS.....	38
7.5 METER TESTING SYSTEMS .....	39
7.6 CALIBRATION OF METER TESTING SYSTEMS .....	41
<b>APPENDIX A.....</b>	<b>43</b>
<b>DIFFERENTIAL TESTING .....</b>	<b>43</b>
<b>APPENDIX B – METER ACCURACY .....</b>	<b>44</b>
<b>APPENDIX C .....</b>	<b>47</b>
<b>APPENDIX D – PROVER BELL CALIBRATION BY PHYSICAL MEASUREMENT.....</b>	<b>48</b>
<b>FORM FOR PROPOSALS ON ANSI B109.3 .....</b>	<b>51</b>

## AMERICAN GAS ASSOCIATION (AGA) NOTICE AND DISCLAIMER

This document was developed through a voluntary consensus standards development process via the American National Standards Institute (ANSI) essential requirements for due process for American National Standards (Edition January 2018). While the American Gas Association (AGA) administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate or verify the accuracy or completeness of any information or the soundness of any judgments contained in this publication.

The AGA disclaims liability for any personal injury, property damages or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, the use of or reliance on this publication. The AGA also makes no guarantee or warranty as to the accuracy or completeness of any information published herein. The information contained therein is provided on an "as is" basis and AGA makes no representations or warranties including any expressed or implied warranty of merchantability or fitness for a particular purpose.

In issuing and making this document available, the AGA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the AGA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The AGA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the AGA list, certify, test or inspect products, designs or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the AGA and is solely the responsibility of the certifier or maker of the statement.

The AGA does not take any position with respect to the validity of any patent rights asserted in connection with any items that are mentioned in or are the subject of this publication, and the AGA disclaims liability for the infringement of any patent resulting from the use of or reliance on it. Users of this publication are expressly advised that determination of the validity of any such patent rights and the risk of infringement of such rights is entirely their own responsibility.

Users of this publication should consult applicable federal, state, and local laws and regulations. The AGA does not, through this publication, provide legal advice for any purpose or intend to urge action that is not in compliance with applicable laws and this publication may not be construed as doing so.

Changes to this document may become necessary from time to time. If changes are believed appropriate by any person or entity, such suggested changes should be communicated to AGA in writing using the form found at the end of the document titled, Form For Proposals on ANSI B109.3 and sent to: American Gas Association, ATTN: Secretariat B109, 400 North Capitol Street, NW, Suite 450, Washington, DC 20001, U.S.A. Suggested changes must include: contact information, including name, address and any corporate affiliation; full name of the document; suggested revisions to the text of the document; the rationale for the suggested revisions; and permission to use the suggested revisions in an amended publication of the document.

**Copyright © 2019 American Gas Association, All Rights Reserved.**

Permission is granted to republish material herein in laws or ordinances as well as regulations, administrative orders or similar documents issued by public authorities. Those desiring permission for other publication should consult the American Gas Association, ATTN: ANSI B109.3 Secretariat, 400 N. Capitol St., NW, Washington, DC, U.S.A.

Currently in preview, click buy full version

## PREFACE

This publication represents a basic standard for operation, substantial and durable construction, and acceptable performance for rotary-type gas displacement meters. This work is the result of years of experience that has been supplemented by extensive research. The standard is intended to meet the minimum design, material, performance and testing requirements for efficient use of rotary displacement meters

It is recognized that during any transition period to the metric system, sizes and dimensions need to be expressed in either the metric system or the inch-pound system or in both. In this document, both systems are used, with the inch-pound units given preference. In most cases, a soft conversion from existing inch-pound values is shown. Soft conversion implies a change in nomenclature only; in this document, the alternative nomenclatures (metric and inch-pound) are shown by using parentheses and can be used interchangeably. Hard conversion is used to express metric values in (closely equivalent) round inch-pound units. Bracketed values are not to be used interchangeably with the corresponding metric values.

Nothing in this standard is to be considered as in any way indicating a measure of quality beyond compliance with the provisions it contains. It is designed to allow the construction and performance of displacement meters that may exceed the various provisions specified in any respect. In its preparation, recognition was intended to be given to the possibility of improvement through ingenuity of design. As progress takes place, revisions may become necessary. When they are believed desirable, recommendations should be forwarded to the Chairman of ANSI Z39 Committee, Operating and Engineering Section, American Gas Association, 400 North Capitol Street, NW, 4<sup>th</sup> Floor, Washington, DC 20001, U.S.A.

Users of this document should consult applicable federal, state and local regulations. The American Gas Association (AGA) does not, by the publication of this document, intend to present specifications that are not in compliance with applicable rules, and this document may not be construed as doing so.

**NOTICE:** This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc. (ANSI) require that action be taken to reaffirm, revise or withdraw this standard no later than five years from the date of publication. When any revisions are deemed advisable, recommendations should be forwarded to the **American Gas Association**. A form is included for that purpose at the end of this standard. Purchasers of American National Standards may receive current information on all standards by writing to the American National Standards Institute, Inc., 25 West 43<sup>rd</sup> Street, 4<sup>th</sup> Floor, New York, NY 10036, U.S.A.; by calling (212) 642-4900; by faxing ANSI at (212) 398-0023; or by visiting ANSI's World Wide Web site at <http://www.ansi.org>. To purchase additional copies of this standard, visit Techstreet's website at <http://www.techstreet.com/aga>, or go to AGA's web page at <https://www.aga.org/news/publications-store/>

## HISTORY OF THE DEVELOPMENT OF THIS STANDARD

Following approval of the Standard for Gas Displacement Meters (Under 500 Cubic Feet per Hour Capacity), ANSI B109.1, in 1973, a subcommittee was appointed to develop a standard covering rotary-type gas displacement meters.

Five drafts of the standard were prepared and reviewed by the subcommittee before a final draft was prepared and submitted to American National Standards Committee B109 for its consideration on June 20, 1979. Subsequent to adoption by the committee, the first edition of the standard for rotary-type gas displacement meters was approved as American National Standard by the American National Standards Institute, Inc., on April 14, 1980.

The second edition was approved as American National Standard by the American National Standards Institute, Inc., on January 9, 1987. Major changes included the additions of Part VI on Auxiliary Devices for Gas Meters; Part VII on Test Methods and Equipment; and Informative Appendices for bar coding of meters and auxiliary devices, and prover calibration.

In the third edition, minor editorial changes were made. The third edition was approved on November 12, 1992.

In the fourth edition of standard B109.3, several additions/deletions were made to avoid any ambiguity, to make it more consistent and to improve upon some requirements. The fourth edition was approved on April 13, 2000.

This is the fifth edition of standard B109.3, in which several additions/deletions have been made to avoid any ambiguity, to provide more consistency with other B109 standards, to improve upon some requirements and to allow more leeway for future innovation and developments. Substantive changes have been shown by a bar [ | ] in the margin.

## ACCREDITED STANDARDS COMMITTEE B109

### CHAIR

WINSTON MEYER, CenterPoint Energy

### VICE- CHAIR

RALPH RICHTER, National Institute of Standards & Technology

### REPRESENTING USERS

Mike Avery, National Grid  
Daniel Bustamante, SoCal Gas  
Patrick Donnelly, NiSource Gas  
Melissa Fearing, Xcel Energy  
Matt Holston, Black Hills Energy  
Winston Meyer, CenterPoint Energy

### REPRESENTING PRODUCERS

John Anderson, Emerson Automated Solutions  
Robert Bennett, Honeywell Process & Control  
Jon Fickinger, Itron Inc.  
Ron Strong, Dresser Metering & Instruments  
Chris Wykle, Senson USA Inc.

### REPRESENTING GENERAL INTEREST

Ardis Bartle, Ameren Measurement & Controls LLC  
Ray DeMeyer, Gas Technology Institute  
Terrence G. Gentry, Southwest Research Institute  
Thomas Kessler, Colorado Engineering Experiment Station, Inc  
Ralph Richter, National Institute of Standards & Technology  
Bruce Swiecicki, National Propane Gas Association

### SECRETARY

Jeffrey Meyers, Secretariat

ANSI B109.3 would like to recognize individuals who are not part of the ANSI B109.3 voting membership but contributed to the development of the standard -- Andre Nel, IMAC Systems, Inc; Andrew Smich, Romet; Brian Lee, Romet; Dennis Chapman Consumers Energy; Eddy Collins, ONE Gas, Inc; Fernando De Los Riscos Garcia, Gas Natural; Glen Heard, Romet; Jeff Webb, Avista; Jerre Kilroy, Honeywell (American Meter); Mark Witherspoon, IMAC Systems, Inc.; Ramesh Konduri, Baker Hughes, a GE Company; Stephen Wenford, CenterPoint Energy; Tony Miller, Ameren Illinois Company