



ANSI/NEMA C119.1-2016

American National
Standard
for Electric
Connectors—
Sealed Insulated
Underground
Connector Systems
Rated 600 Volts



National Electrical Manufacturers Association
1300 North 17th Street, Suite 900 • Rosslyn, VA 22209
www.NEMA.org

Currently in preview, click buy full version





ANSI C119.1-2013

*American National Standard
for Electric Connectors—
Sealed Insulated Underground Connector Systems
Rated 600 Volts*

Secretaria

National Electrical Manufacturers Association

Approved: March 16, 2017

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

ANSI standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by The American National Standards Institute, Inc. (ANSI) that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer. An American National Standard implies a consensus of those substantially concerned with its scope and provisions. Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The existence of an American National Standard does not in any respect preclude anyone, whether s/he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards. It is intended as a guide to aid the manufacturer, the consumer, and the general public.

The American National Standards Institute, Inc., does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute, Inc. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on this title page.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc. require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, Inc.

Published by:

National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, VA 22209

© 2016 National Electrical Manufacturers Association

All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America.

CONTENTS

Foreword	iv
1 Scope and Purpose.....	1
1.2 Purpose.....	1
2 Referenced Standards	1
3 Definitions	1
4 Performance Requirements	2
4.1 General	2
4.2 Mechanical Tests.....	2
4.3 Electrical Tests	3
4.4 Sealing Tests	4
4.5 Reusability—Optional (Required for Connectors Designated as Reusable Only)	4
5 Sampling	4
5.1 General	4
5.2 Mechanical.....	5
5.4 Sealing Tests	5
5.5 Reusability	5
6 Test Methods	6
6.2 Sealing Tests	7
6.4 Reusability	9
7 Test Report	9
8 Marking	10
8.1 Connector System Marking	10
8.3 Assembly Instructions.....	10
Annexes	
Annex A.....	13
Annex B.....	14
Annex C.....	15
Annex D.....	16
Annex E.....	17

Figures

Figure 1 Impact 11

Figure 2 Flexing and Twisting 12

Currently in preview, click buy full version

Foreword (This foreword and the informative annexes are not part of American National Standard C119.1)

The standard covers electrical, mechanical, and sealing requirements of connectors rated 600 V and installed underground.

This standard was initially developed by an EEI-NEMA Joint Committee on Underground Distribution Connectors and Connector Systems and published by the American National Standards Institute in 1974.

This revision has been reorganized to follow international formatting and improve the organization of information throughout the document when compared to the previous version.

Substantive changes to the standard have been made in the C119.1-2016 version of the standard. A substantive change is one that directly and materially affects performance of a product and which requires testing or retesting to meet the current edition of a standard. The substantive changes to the standard are:

This revision includes the addition of spreadsheet files in Annex B which can be used to collect current cycle test data, calculate connector stability, generate graphs of the data and print the data to provide test results as part of the test report. The spreadsheets are provided to give test laboratories a standardized method to collect, calculate and report test data and prepare test reports. These spreadsheets were not part of earlier editions.

This revision also includes the addition a spreadsheet file for Integrity of Seal Data in Annex C and a spreadsheet file for Impact Data in Annex D. The spreadsheets are provided to give a standardized format to collect, calculate and report test data and test results. These spreadsheets were not part of earlier editions.

Addition of torque strength requirements for set screws, impact test (for direct burial qualification), re-sealability test, reusability test and current cycle temperature stability calculation.

Suggestions for improvement of this standard are welcome.

They should be sent to:

Senior Technical Director, Operations
National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, VA 22209

This standard was processed and approved for submittal to ANSI by the Accredited Standards Committee on Connectors for Electrical Utility Applications, C119. Committee approval of this standard does not necessarily imply that all committee members voted for its approval. At the time it approved this standard, the ANSI ASC C119 Committee had the following members:

Harry Hayes, Chairman
Michael Molina, Vice Chairman
Paul C. Secretary

Organizations Represented

Electric Utility Industry

Zachary Anderson
Michael Dyer
Warren Hadley
Douglas Harms
Kenneth McKinney
Cory Morgan
Wilson Peppard

Angelo Rodriguez
Curt Schultz
Ryan Stargel
Giovanni Velazquez
Gerald Wasielewski
William Winge
Larry Witteck

National Electrical Manufacturers Association

Enes Basic
Scott Casler
Matt Cawood
Peter Chan
David Coulombe
Jeff Door
Matt Gaertner
Waymon Goch
Luke Hill
David Hughes
Kevin Jenkins
Barry Johnson
Eyass Khansa
Ron Kmiecik
Colin McCullough

Jonathon Olszewski
Alejandro Pineda
Kevin Puccini
Walter Romanko
Gary Schrader
David Shibilila
Gary Sibilant
Ben Sparks
Dan Stanton
Ryan Strough
Carl Tamm
Justin Tuchscherer
Robert Westbrook
Andrew Zwit

Rural Utilities Service (RUS)

Trung Hiu

General Interest

Joe Goldenburg
Chris Morton
Dmitry Ladin
Tip Goodwin
Joe Renowden
Allen Wilcox
Craig Pon

The C119.1 Subcommittee on Sealed Underground Connector Systems, which developed the revisions of this standard, had the following members:

Matt Cawood, Chairman
Mike Dyer, Vice Chairman
Paul C... Secretary

Zachary Anderson
Enes Basic
Scott Casler
Constantino Dangelo
Coulombe, David
Seydou Diop,

Jeff Door
Waymon Goch
Warren C. Hadley
Douglas P. Harms
Harry Hayes
Luke Hill

Trung Hiu
David Hughes
Kevin Jenkins
Barry Johnson
Alan Kasanow
Clint Mason
Colin McCullough
Kenneth McKinney
Richard Morin
Johnnothen Olszewski
Chan, Peter
Alejandro Pineda
Kevin Puccini
Angelo Rodriguez
Jesus Rodriguez
Walter Romanko

Curt Schultz
David Shibilila
Paul Springer
Ryan Stough
Stanley Szyszko
Carl R. Tamm
Carl Taylor
Neil Vandermeulen
Giovanni Velazquez
Richard (Jeff) J. Waidelich
Gerald Wasielewski
Robert Westbrook
Allen Wilcox
Larry Witteck
Michael Zaffina
James Zahnen

Currently in preview, click buy full version

1 Scope and Purpose

1.1 Scope

This standard covers sealed, insulated underground connector systems rated at 600 V for utility applications and establishes electrical, mechanical, and sealing requirements for sealed insulated underground connector systems.

1.2 Purpose

The purpose of this standard is to give reasonable assurance to the user that sealed, insulated underground connector systems meeting the requirements of this standard will perform in a satisfactory manner, provided they have been properly selected for the intended application and are installed in accordance with the manufacturer's recommendations.

2 Referenced Standards

This standard is intended to be used in conjunction with the following standards. When a referenced standard is superseded by a revision approved by the American National Standards Institute, the referenced revision shall apply. Standards that are referenced by inference are shown in Annex A.

ANSI C119.0 *American National Standard for Electrical Connectors—Testing Methods and Equipment Common to the ANSI C119 Family of Standards*

3 Definitions

CCST: Current cycle submersion test where current cycle heating is done in air and cooling is done using water submersion.
cycle test

CCT: Current where current cycle heating and cooling are done in air.

connector: A device joining two or more conductors to provide a continuous electrical path.

connector assembly: The connector system installed on the conductor(s).

connector system: A connector and its associated insulating and sealing components.

control conductor: A conductor in the current cycle loop that serves as a reference for setting test current and monitoring temperature

guarded circuit: A circuit used to eliminate or to minimize the current flow between the insulation and conductor ends, caused by surface leakage currents.

input conductor: Conductor on the supply side of the connector.

output conductor: Conductor on the load side of the connector.

re-sealable connector: One in which the cable or cables may be removed, and the port resealed in accordance with the manufacturer's instructions.

reusable connector: One in which the cable or cables may be removed, reinserted and resealed in accordance with the manufacturer's instructions.

seal: An interface preventing the ingress of moisture and foreign matter into the connector assembly.

underground: Below grade application, including direct burial.