



ANSI C12.20-2010

---

American National  
Standard for Electricity  
Meters - 0.2 and 0.5  
Accuracy Classes





**ANSI C12.20-2010**

**American National Standard**

**for Electricity Meters—  
0.2 and 0.5 Accuracy Classes**

Currently in preview, click buy full version

Currently in preview, click buy full version



**ANSI C12.20-2010**  
Revision of ANSI C12.20-2002

**American National Standard  
for Electricity Meters—  
0.2 and 0.5 Accuracy Classes**

**NOTICE OF ADOPTION**

ANSI C12.20 was adopted and is approved for use by the Department of Defense (DoD). The National Electrical Manufacturers Association has furnished the clearance required by existing regulations. Copies of the document are stocked at the Standardization Documents Order Desk, Building 4D, 700 Robbins Avenue, Philadelphia, PA 19111-5094, for issue to DoD activities only. All other requestors must obtain copies from NEMA.

Secretary

**National Electrical Manufacturers Association**

Approved August 31, 2010

**American National Standards Institute, Inc.**

## NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly, resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstance. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

## **AMERICAN NATIONAL STANDARD**

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary, and their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

**National Electrical Manufacturers Association  
1300 North 17th Street, Rosslyn, VA 22209**

© Copyright 2010 by National Electrical Manufacturers Association.

All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

**This page intentionally left blank.**

## Contents

<b>1</b>	<b>SCOPE .....</b>	<b>1</b>
<b>2</b>	<b>DEFINITIONS .....</b>	<b>1</b>
<b>3</b>	<b>REFERENCES .....</b>	<b>1</b>
<b>4</b>	<b>REQUIREMENTS .....</b>	<b>1</b>
4.1	Mounting .....	1
4.2	Voltage and frequency .....	1
4.3	Current classes and test amperes .....	1
4.4	Form designations .....	2
4.5	Displays .....	2
4.5.1	Viewing requirements .....	2
4.5.2	Size of digits .....	2
4.5.3	Direction of energy flow .....	3
4.6	Provisions for testing of calibration .....	3
4.6.1	Test output that is proportional to energy .....	3
4.6.2	Test mode .....	3
4.6.3	Delivered and received energy .....	3
4.6.4	Other measurements .....	3
4.7	Nameplate .....	3
4.7.1	Nameplate additions .....	3
4.7.2	Nameplate deletions .....	3
<b>5</b>	<b>ACCEPTABLE PERFORMANCE OF NEW TYPES OF ELECTRICITY METERING DEVICES AND ASSOCIATED EQUIPMENT .....</b>	<b>3</b>
5.1	General .....	3
5.1.1	Acceptable meters .....	3
5.2	Selection of metering devices for approval tests .....	4
5.3	Conditions of test .....	4
5.4	Rules governing the acceptance of types .....	4
5.5	Performance requirements .....	4
5.5.1	Test conditions .....	4
5.5.2	Loading for accuracy tests .....	4
5.5.3	List of type tests .....	5
5.5.4	Accuracy tests .....	7
5.5.4.1	Test number 1: No load .....	7
5.5.4.2	Test number 2: Starting load .....	7
5.5.4.3	Test number 3: Load performance .....	7
5.5.4.4	Test number 4: Effect of variation of power factor .....	7
5.5.4.5	Test number 5: Effect of variation of voltage .....	9
5.5.4.6	Test number 6: Effect of variation of frequency .....	11
5.5.4.7	Test number 7: Equality of current circuits for multi-element meters .....	11
5.5.4.8	Test number 8: Internal meter losses .....	12
5.5.4.9	Test number 9: Temperature rise .....	12
5.5.4.10	Test number 10: Effect of register friction .....	12
5.5.4.11	Test number 11: Effect of internal heating .....	12
5.5.4.12	Test number 12: Effect of tilt .....	14
5.5.4.13	Test number 13: Stability of performance .....	14
5.5.4.14	Test number 14: Effect of polyphase loading .....	14
5.5.5	External influences .....	14

5.5.5.1	Performance verification .....	14
5.5.5.2	Test number 15: Insulation .....	15
5.5.5.3	Test number 16: Voltage interruptions test .....	15
5.5.5.4	Test number 17: Effect of high voltage line surges .....	15
5.5.5.5	Test number 18: Effect of external magnetic field .....	15
5.5.5.6	Test number 19: Effect of variation of ambient temperature .....	15
5.5.5.7	Test number 20: Effect of temporary overloads .....	17
5.5.5.8	Test number 21: Effect of current surge in ground conductor .....	17
5.5.5.9	Test number 22: Effect of superimposed signals .....	18
5.5.5.10	Test number 23: Effect of voltage variation-secondary time base .....	18
5.5.5.11	Test number 24: Effect of variation of ambient temperature-secondary time base .....	18
5.5.5.12	Test number 25: Effect of electrical fast transient/burst test .....	18
5.5.5.13	Test number 26: Effect of radio frequency interference .....	18
5.5.5.14	Test number 27: Radio frequency conducted and radiated emission test .....	18
5.5.5.15	Test number 28: Effect of electrostatic discharge (ESD) .....	18
5.5.5.16	Test number 29: Effect of storage temperature .....	18
5.5.5.17	Test number 30: Effect of operating temperature .....	18
5.5.5.18	Test number 31: Effect of relative humidity .....	18
5.5.5.19	Test number 32: Mechanical shock .....	18
5.5.5.20	Test number 33: Transportation drop .....	18
5.5.5.21	Test number 34: Mechanical vibration .....	18
5.5.5.22	Test number 35: Transportation vibration .....	18
5.5.5.23	Test number 36: Weather simulation test .....	19
5.5.5.24	Test number 37: Salt-spray test .....	19
5.5.5.25	Test number 38: Raintightness .....	19
<b>6</b>	<b>STANDARDS FOR IN-SERVICE PERFORMANCE .....</b>	<b>19</b>
<b>7</b>	<b>REQUIREMENTS APPLICABLE TO DETACHABLE MATH HOUR METERS .....</b>	<b>19</b>
<b>8</b>	<b>REQUIREMENTS APPLICABLE TO BOTTOM-CONNECTED ELECTRICITY METERS .....</b>	<b>19</b>
<b>9</b>	<b>PROCEDURE FOR ASSIGNING FORM DESIGNATIONS .....</b>	<b>19</b>
<b>ANNEX A</b>	<b>.....</b>	<b>20</b>
A.1	Foreword to Second Edition (2002) .....	20
A.2	Foreword to First Edition (1998) .....	22

**Foreword** (This Foreword is not part of American National Standard C12.20-2010.)

This American National Standard establishes acceptable performance criteria for electricity meters. Accuracy class designations, current class designations, voltage and frequency ratings, test current values, service connection arrangements, pertinent dimensions, form designations, and environmental tests are covered.

The existing C12.20 Standard has been revised with the intent to bring it up to date in an industry that is changing dramatically because of both technology and regulatory matters. This American National Standard establishes acceptable performance criteria for electricity meters.

The existing standard was broadened to allow three phase current and voltage sources as an optional test method to the existing single phase, series, parallel method.

In memoriam to Glenn Mayfield and Ed Malemezian: both had a passion for standards and members of SC16 felt fortunate to know and learn from them.

Suggestions for improvement to this standard are welcome. They should be sent to:

National Electrical Manufacturers Association  
Vice President, Technical Services  
1300 North 17th Street  
Suite 1752  
Rosslyn, VA 22209

This standard was processed and approved for submittal to ANSI by Accredited Standards Committee for Electricity Metering, C12. At the time the committee approved this standard, the C12 Committee had the following members:

**Herman Millican, Chairperson ANS C12/SC12**  
**Tom Nelson, Chairperson ANS C12**  
Paul Orr, Secretary

**ANS C12 Main Committee**

<i>Organization Represented:</i>	<i>Name of Representative:</i>	<i>Organization Represented:</i>	<i>Name of Representative:</i>
<b><u>General Interest</u></b>			
Austin Energy	H. Millican	Center for Neighborhood Technology	L. Kotewa
EnerNex Corporation	A. Snyder	Future DOS R&D Inc.	A. Moise
NIST	T. Nelson	Tucker Engineering	R. Tucker
Underwriters Laboratories Inc.	R. Breschini		
<b><u>Processor</u></b>			
Electric Electricity Corporation, Inc.	S. Weikel	GE Energy	C. Crittenden
Schweitzer Engineering Laboratories	B. Cain	Landis+Gyr Inc.	J. Voisine
Sensus	B. Hughes	Technology for Energy Corp.	W. Hardy
Trillant Networks	G. Steiner	Watthour Engineering Co.	L. Wren
	M. Veillette		

**User**

Baltimore Gas & Electric	J. Thurber	Duke Energy	T. Morgan
Florida Power and Light	J. DeMars	Pacific Gas & Electric	D.Y. Nguyen
Georgia Power	L. Barto		
Public Service Electric & Gas	D. Ellis	Xcel Energy EMC	D. Nordell

**ANS C12 C12.16 Subcommittee**

*Organization Represented:*

*Name of Representative:*

Ameren Services	West, J.
Austin Energy	Millican, H.
Baltimore Gas & Electric	Thurber, J.
Central Hudson Gas & Electric Co	Lokys, R.
Duke Energy	Morgan, T.
Ed Malemezian Consulting, Inc.	Malemezian, E.*
Elster Electricity	Weikel, S.
EnerNex Corporation	Snyder, A.
Florida Power & Light	McEvoy, J.
Florida Power & Light	DeMars, J.
General Electric	Crittenden, C.
Georgia Power	Barto, L.
Itron, Inc.	Cain, B.
Landis+Gyr	Anderson, M.
Landis+Gyr	Voisine, J.
NIST	Nelson, T.
NIST	Thompson, A.
Oncor	Johnson, B.
Pacific Gas & Electric	Nguyen, D. Y.
Pacific Gas & Electric	Yan, A.
Powermetrix	Hardy, W.
Public Service Electric & Gas	Ellis, D.
Radian Research Inc.	Everidge, T.
Radian Research Inc.	Mayfield, G.
Schweitzer Engineering Laboratories	Hughes, R.
Sensus Metering Systems	Steiner, G.
Watthour Engineering Co.	Weimer, C.
Xcel Energy EMC	Nordell, D.

\*Deceased

**For Electricity Meters—0.2 and 0.5 Accuracy Classes****1 SCOPE**

This standard establishes the physical aspects and acceptable performance criteria for 0.2 and 0.5 accuracy class electricity meters meeting Blondel's Theorem. Where differences exist between the requirements of this Standard and C12.1 and C12.10, the requirements of this Standard shall prevail.

**2 DEFINITIONS**

See clause 2 of ANSI C12.1-2008.

**3 REFERENCES**

ANSI C12.1 *American National Standard for Electric Meters, Code for Electricity Metering*

ANSI C12.10 *American National Standard for Physical Aspects of Watthour Meters—Safety Standard*

Where the date of the referenced document is not shown, the latest published version of the document applies.

**4 REQUIREMENTS****4.1 Mounting**

Mounting arrangements may include detachable socket, type "S," bottom-connected, type "A," or any other arrangement agreed upon between the manufacturer and user.

**4.2 Voltage and frequency**

Typical voltage ratings are 120, 240, 277, and 480 volts with a frequency rating of 50 or 60 Hz.

**4.3 Current classes and test amperes**

The current classes and test amperes shall be as listed in Table 1.

**Table 1 – Current classes and test amperes**

<b>Current Class</b>	<b>Test Amperes</b>
2	0.25
10	2.5
20	2.5
100	15
200	30
320	50

NOTE—Other values of test amperes may be used as recommended by the manufacturer.