



ANSI C12.22-2012 (R2020)

American National
Standard for Protocol
Specification for
Interfacing to Data
Communication
Networks



National Electrical Manufacturers Association
1300 North 17th Street, Suite 900 • Rosslyn, VA 22209
www.NEMA.org

Currently in preview, click buy full version





ANSI C12.22-2012 (R2020)

American National Standard
Protocol Specification for
Interfacing to Data Communication Networks

Secretariat:

National Electrical Manufacturers Association

IEEE Number: 1703-2012

Measurement Canada Number: MC12.22-2013

Approved: June 18, 2020

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by the American National Standards Institute, Inc. (ANSI) that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether or not he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute, Inc., does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute, Inc. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc. require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, Inc.

Published by

National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

© 2020 National Electrical Manufacturers Association

All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior written permission from the publisher.

Printed in the United States of America

Foreword (This foreword is not part of American National Standard C12.22)

This Standard is intended to accommodate the network messaging requirements of an advanced metering infrastructure such as that identified by the Office of Electricity Delivery and Energy Reliability of the US Department of Energy; the Smart Metering Initiative of the Ontario Ministry of Energy (Canada) and the stated requirements of Measurement Canada for the approval of a metering device for use in Canada.

The Standard describes four different but related communication modes of operation. One is the operation of an End Device (Node) over any network, a feature that all C12.22 compliant nodes need to implement. The second is an exposed point-to-point interface between a C12.22 Device, e.g., a meter, and a C12.22 Communication Module, e.g., a network adaptor. The third is the capture, translation and transmission of one-way messages (blurts). The fourth is communication with the End Device over a dedicated ANSI C12.18 ANSI Type 2 optical local port.

The Standard assigns roles to all of the Utility AMI network assets to enable the automated deployment and configuration of network nodes in a distributed AMI enterprise system. The roles provide for Relays, Master Relays and Gateways; simple Hosts, Authentication Hosts, and Notification Hosts and sensory End Devices. These devices work together to realize a Utility enterprise network in a manner that provides for a universal application framework that can operate any compliant appliance so that it can be deployed, accessed and communicated with seamlessly over any network infrastructure, hardware and available bandwidth. This is accomplished through the provision of well defined network management services (e.g., trace, resolve, register, de-register), data access services (e.g., read, write), session management (e.g., logon, logoff, terminate, disconnect), message segmentation and assembly, message playback rejection, security and privacy.

All registration authorities that recognize registrars are governed by ANSI C12 and IEEE SCC31. To be recognized, any registration authority is expected to adhere to the requirements specified in this Standard. See Annex D(normative) Universal Identifier.”

The protocol is well suited for two-way and one-way communication using an extremely wide network address space (using ApTitles). It implements subscription and Node discovery services so that any Utility enterprise (e.g., MDMS, DA, DR, or any other willing network appliance, such as a home energy monitoring system, or a thermostat) can register itself as a Notification Host so that it can receive advisory messages and alerts about network asset changes or changes in the state of the network. Network subscription services can be managed through distributed Authentication Hosts.

Altogether, this Standard was designed to be simple and small. Therefore, it can meet the requirements of the smallest of AMI networks, while providing well-defined capacities that can grow and adapt to the largest of enterprise AMI networks and operations as needed. As such, this Standard together with ANSI C12.19 addresses the end-to-end distributed AMI network needs from the smallest to the largest of enterprise AMI systems.

The second release of this Standard is a minor release in that it establishes a new baseline document that includes all the corrections that were applied in Annex K, “Listing of Editorial Errors and Errors of Omission in ANSI C12.22-2008” of the first release of IEEE Std 1703-2012. Readers who are acquainted with ANSI C12.22-2008 should review the notable differences and corrections that exist in this release of the standard relative to its predecessor. These are listed below:

1. New clauses “1 Overview” and “1.1 Introduction” were introduced ahead of old clause “1 Scope.”
2. Old clause “1 Scope” was revised as clause “1.3 Purpose.”
3. New clause “1.3 Purpose” was introduced.
4. Moved clause “2.2 Other” to “Annex K, Bibliography” and adopted IEEE-style citations and references.

5. Added reference to the "IEEE-SA Standards Definitions Database" in clause "3.1 Definitions."
6. Corrected Note 1 of clause "5.2.4 "Universal Identifiers Canonical Encoding,"
7. Added new response error code <nete> in clause "5.3.2.2 Response Codes."
8. Added new response error code <nete> in clause "5.3.2.4.1 Identification Service."
9. Corrected <octet-count> in clause "5.3.2.4.2 Read Service."
10. Corrected <data> in clause "5.3.2.4.3, "Write Service."
11. Corrected request description in clause "5.3.2.4.5 Security Service."
12. Added new response error code <nete> in clause "5.3.2.4.5 "Security Service."
13. Added new response error code <nete> in clause "5.3.2.4.8 "Disconnect Service."
14. Added new response error code <nete> in clause "5.3.2.4.9 "Wait Service."
15. Documented description of domain pattern in clause "5.3.2.4.10 "Registration Service."
16. Corrected <reg-info> in clause "5.3.2.4.10 Registration Service."
17. Corrected description of clause "5.3.2.4.12 "Resolve Service."
18. Corrected description of <epsem-control> of clause "5.3.3 EPSEM Envelope Structure."
19. Corrected Use of Assigned Subbranches in Relative ApTitle in clause "5.3.4.12 Use of Subbranches of a Registered ApTitle."
20. Inserted "A.1 Description" into Annex A, and renumbered all subclauses in Annex A.
21. Corrected clause "A.6 C12.22 Master Relay ApTitle Auto-assignment."
22. Inserted "C.1 Overview" into Annex C, and renumbered all subclauses in Annex C.
23. Added Element PATTERN_LEN_MULT to clause "C.3.1 Table 130 Relay Network Control Dimension Limits Table."
24. Added Element PATTERN_LEN_MULT to clause "C.3.2 TABLE 131 Actual Network Relay Limiting Table."
25. Corrected definition of END_DEVICE_FLAG of clause "C.3.3 Table 132 Registration List Table."
26. Updated size of APTITLE_PATTERN of clause "C.3.4 Table 133 Static Routing Table."
27. Updated size of NOTIFICATION_PATTERN of clause "C.3.5 Table 134 Host Notification Table."
28. Updated size of SERIAL_NUMBER_PATTERN of clause "C.2.6 Table 135 Master Relay Assignment Table."
29. Corrected description of CIPHER_MODE of clause "C.7 Table 47 Host Access Security Table."
30. Corrected examples of clause "Annex G, Communication Examples."
31. Added note on buffering to clause "1.1 EAX' description."

Suggestions for improvement to this Standard are welcome. They should be sent to:

National Electrical Manufacturers Association
Vice President, Technical Services
1300 North 17th Street
Suite 900
Rosslyn, VA 22209

This Standard was processed and approved for submittal to ANSI by Accredited Standards Committee for Electricity Metering C12.22 at the time the committee approved this Standard, the C12 Committee had the following Members:

Tom Nelson, Chairman
Paul Orr, Secretary—NEMA Staff

Name of Representative:

Kerry Barnette
Fran Boudreau
Brent Cain
Joel Canine
Curt Crittenden
Andrew Dudding

Organization Represented:

Duke Energy
Landis+Gyr
Itron, Inc.
Radian Research
Aclara
Sensus, A Xylem Brand

David Ellis
Shawn Glasgow
Sean Gorman
Scott Holdsclaw
Steve Hudson
Zach Hughes
Scott Hunter
Bob Kiessling
Larry Kotewa
Tom Lawton
Bin Lu
Don MacArthur
Avy Moise
Tom Nelson
D. Young Nguyen
Dan Nordell
Piotr Przydatek
Jim Reed
Derl Rhoades
Jean-Luc Sabourin
Aaron Snyder
Eduardo Sotolongo
Kostas Tolios
Don Tucker
Lea Wren

Public Service Electric & Gas
Milbank Manufacturing Company
Baltimore Gas & Electric Company
Honeywell Smart Energy
Technology for Energy Corporation
Oncor Electric Delivery Company LLC
UL LLC
Brooks Utility Products
Elevate Energy
TESCO – The Eastern Specialty Company
Sask Power
Schweitzer Engineering Laboratories
Future DOS R&D Inc.
NIST
Pacific Gas & Electric Company
Xcel Energy
Schneider Electric
Eurofins MET Labs
Alabama Power Company
Hydro Quebec
EnerNex
Florida Power & Light Company
Independent
Ercot
Watt-hour Engineering Company, Inc.

Working Group 1 of Subcommittee 17 that developed the Standard consisted of:

Ed Beroset, Chairman
Richard Tucker, Vice Chairman
Avygdor Moise, Editor
Paul Orr, Secretary—NEMA Staff

Name of Representative:

Ed Beroset
Brent Cain
Larry Kotewa
Bob Lee
Avy Moise
Richard Morris
Tom Nelson
Vlad Panucol
Terry Penn
Aaron Snyder
Kostas Tolios
Richard Tucker

Organization Represented:

EPRI
Itron, Inc.
Elevate Energy
Aclara Metes LLC
Future DOS R&D Inc.
Landis+Gyr
NIST
Honeywell Smart Energy
Southern Company
EnerNex
Independent
Tucker Engineering

Contents

	Page
1 Overview	1
1.1 Introduction	1
1.2 Scope	1
1.3 Purpose	2
2 Normative references.....	3
3 Definitions and syntax	5
3.1 Definitions	5
3.2 Document syntax	9
3.3 Table syntax.....	10
4 Reference topology.....	10
5 C12.22 Node to C12.22 Network Segment details	12
5.1 C12.22 Node to C12.22 Network Segment reference.....	12
5.2 Data encoding rules	13
5.2.1 Data order	13
5.2.2 Length fields encoding.....	14
5.2.3 Universal identifiers encoding	14
5.2.4 Universal identifiers canonical encoding.....	16
5.3 Layer 7—application layer	16
5.3.1 Data structure—utility industry data tables	17
5.3.2 EPSEM	17
5.3.2.1 Request codes.....	17
5.3.2.2 Response codes	18
5.3.2.3 Time-out.....	21
5.3.2.3.1 Session time-out	21
5.3.2.3.2 Application layer response time-out	21
5.3.2.4 Services.....	22
5.3.2.4.1 Identification service	22
5.3.2.4.2 Read service	25
5.3.2.4.3 Write service.....	27
5.3.2.4.4 Logon service	28
5.3.2.4.5 Security service	29
5.3.2.4.6 Logoff service.....	30
5.3.2.4.7 Terminate service	31
5.3.2.4.8 Disconnect service.....	31
5.3.2.4.9 Wait service	32
5.3.2.4.10 Registration service	33
5.3.2.4.11 Unregistration service	40
5.3.2.4.12 Resolve service	41
5.3.2.4.13 Trace service.....	42
5.3.2.5 Service sequence state control.....	43
5.3.2.6 Partial table access using index/element-count method	44
5.3.2.7 Partial table access using offset/octet-count method.....	46
5.3.3 EPSEM envelope structure	47
5.3.4 Association control—Association Control Service Element (ACSE)	48
5.3.4.1 Application Context Element (A1H).....	50
5.3.4.2 Called AP Title Element (A2H).....	50
5.3.4.3 Calling AP Title Element (A6H).....	50
5.3.4.4 Universal Identifier of Called and Calling AP Title Element (06H)	51
5.3.4.5 Relative Universal Identifier of Called and Calling AP Title Element (80H)	51
5.3.4.6 Calling Application Entity Qualifier Element (A7H).....	51

5.3.4.7	Mechanism Name Element (8B _H).....	52
5.3.4.8	Calling Authentication Value Element (AC _H).....	53
5.3.4.8.1	C12.22 Security Mechanism (<application-context-oid>.2.1).....	54
5.3.4.8.2	C12.21 Security Mechanism (<application-context-oid>.2.0).....	57
5.3.4.8.3	C12.22 Other security mechanisms.....	59
5.3.4.9	Called AP invocation ID element (A4 _H).....	60
5.3.4.10	Calling AP invocation ID element (A8 _H).....	60
5.3.4.11	User information element (BE _H).....	62
5.3.4.12	Use of subbranches of a registered ApTitle.....	63
5.3.4.13	C12.22 Security Mechanism.....	67
5.3.4.13.1	C12.22 Security Mechanism (<application-context-oid>.2.1).....	67
5.3.4.13.1.1	Security modes.....	67
5.3.4.13.1.2	Rules for responses.....	68
5.3.4.13.1.3	Key ID.....	68
5.3.4.13.1.4	Access privileges.....	69
5.3.4.13.1.5	Initialization Vector.....	69
5.3.4.13.1.6	Calling AP Invocation ID.....	69
5.3.4.13.1.7	Syntax mapping.....	69
5.3.4.13.1.8	Cleartext with Authentication.....	70
5.3.4.13.1.9	Ciphertext with Authentication.....	72
5.3.4.13.1.10	Validating messages.....	74
5.3.5	Application Segmentation Sub-layer.....	74
5.3.5.1	APDU segmentation.....	75
5.3.5.2	APDU Segment.....	75
5.3.5.2.1	Called AE Qualifier Element (A3 _H).....	75
5.3.5.2.2	Segment User Information Element (BE _H).....	76
5.3.5.2.2.1	Segment Association Information Element.....	77
5.3.5.2.2.2	Segment Data Elements.....	77
5.3.5.3	Segmentation and Reassembly.....	77
5.3.5.3.1	Segmentation Algorithm.....	77
5.3.5.3.2	Reassembly Algorithm.....	79
5.4	Layer 6—presentation layer.....	80
5.5	Layer 5—session layer.....	80
5.6	Layer 4—transport layer.....	80
5.7	Layer 3—network layer.....	80
5.8	Layer 2—data link layer.....	80
5.9	Layer 1—physical layer.....	80
6	Protocol Details: C12.22 Device to C12.22 Communication Module interface.....	81
6.1	Interface architecture.....	81
6.2	Interface diagram.....	81
6.3	Implementation guidelines.....	82
6.3.1	C12.22 Communication Module.....	82
6.3.2	C12.22 Device.....	83
6.4	Layer 7—application layer.....	84
6.5	Layer 6—presentation layer.....	84
6.6	Layer 5—session layer.....	84
6.7	Layer 4—transport layer.....	84
6.7.1	Negotiate Service.....	84
6.7.2	Get Configuration Service.....	86
6.7.3	Link Control Service.....	89
6.7.4	Send Message Service.....	91
6.7.5	Get Status Service.....	93
6.7.6	Get Registration Status Service.....	94
6.7.7	Service Time Sequence Diagrams.....	96
6.7.8	Service Sequence States.....	101
6.8	Layer 3—network layer.....	103
6.9	Layer 2—data link layer.....	103

6.9.1	Basic data information	104
6.9.1.1	Fixed settings	104
6.9.1.2	Variable settings.....	104
6.9.2	Packet definition	104
6.9.3	CRC selection	106
6.9.4	Acknowledgment.....	106
6.9.5	Retry attempts.....	107
6.9.6	Timeouts	107
6.9.6.1	Traffic Time-out.....	107
6.9.6.2	Inter-character Time-out	107
6.9.6.3	Response Time-out	107
6.9.7	Turn Around Delay.....	107
6.9.8	Collision.....	108
6.9.9	Duplicate packets.....	108
6.9.10	Transparency.....	108
6.9.11	Supervision of the communications link.....	108
6.9.12	Local routing.....	109
6.9.13	Service sequence states.....	110
6.10	Layer 1—physical layer.....	111
6.10.1	Signal definition.....	111
6.10.2	Electrical properties of the connection.....	111
6.10.3	Mechanical and environmental properties	112
6.10.4	Supervision of the communications link.....	113
7	Local Port communication protocol details.....	113
7.1	Protocol definition	113
7.1.1	Layer 7—Application layer	113
7.1.2	Layer 6—Presentation layer	114
7.1.3	Layer 5—Session layer.....	114
7.1.4	Layer 4—Transport layer.....	114
7.1.5	Layer 3—Network layer	114
7.1.6	Layer 2—Data link layer	114
7.1.7	Layer 1—Physical layer.....	115
7.2	C12.22 Local Port communication using a C12.18 Optical Port	115
7.2.1	Establishment of ANSI C12.18 protocol compatibility mode	115
7.2.2	Establishment of ANSI C12.22 protocol compatibility mode	116
8	Backward compatibility.....	116
9	Compliance.....	116
Annex A	(normative) Relays.....	117
A.1	Description.....	117
A.2	Hierarchical topology	117
A.3	C12.22 Master Relays.....	117
A.4	Registration notification	118
A.5	Registration algorithm details.....	118
A.6	C12.22 Node ApTitle auto-assignment.....	119
A.7	C12.22 Master Relay ApTitle auto-assignment.....	119
A.8	Obsolete routes	119
A.9	Multiple routes.....	120
A.10	Application layer supervision	120
A.11	Routing	120
Annex B	(informative) Routing examples	120
B.1	C12.22 Relays with a single Service Provider.....	120
B.2	C12.22 Relays shared by multiple Service Providers.....	121

Annex C	(normative) Modifications and extensions to ANSI C12.19.....	122
C.1	Overview	122
C.2	Decade 12: Node Network Control Tables.....	122
C.2.1	Table 120 Node Network Control Dimension Limits Table.....	123
C.2.2	Table 121 Actual Node Network Control Limiting Table.....	126
C.2.3	Table 122 Interface Control Table.....	129
C.2.4	Table 123 Exception Report Configuration Table.....	131
C.2.5	Table 124 Filtering Rules Table	133
C.2.6	Table 125 Interface Status Table	135
C.2.7	Table 126 Registration Status Table.....	139
C.2.8	Table 127 Network Statistics Selections Table.....	140
C.2.9	Table 128 Network Statistics Table.....	141
C.3	Decade 13: Network Relay Control Tables	143
C.3.1	Table 130 Relay Network Control Dimension Limits Table.....	143
C.3.2	Table 131 Actual Network Relay Limiting Table.....	145
C.3.3	Table 132 Registration List Table.....	146
C.3.4	Table 133 Static Routing Table	149
C.3.5	Table 134 Host Notification Table	151
C.3.6	Table 135 Master Relay Assignment Table.....	153
C.3.7	Table 136 Dynamic Routing Report Table.....	155
C.4	Universal ID pattern description of ApTitles.....	155
C.5	Additions to TABLE 07—Procedure Initiate Table	156
C.5.1	Procedure 23 Register.....	156
C.5.2	Procedure 24 Deregister.....	156
C.5.3	Procedure 25 Network Interface Control.....	157
C.5.4	Procedure 26 Exception Report	158
C.6	Table 46: Extended Key Table	159
C.7	Table 47: Host Access Security Table.....	160
Annex D	(normative) Universal Identifier	163
Annex E	(normative) One-way devices.....	165
Annex F	(informative) APDU Response Time-out algorithm.....	166
Annex G	(informative) Communication examples	168
G.1	Example #1: Unsecured session	168
G.2	Example #2: Unsecured sessionless.....	169
G.3	Example #3: Unsecured notification.....	170
G.4	Example #4: Authenticated session	170
G.5	Example #5: Authenticated sessionless	173
G.6	Example #6: Authenticated notification	174
G.7	Example #7: Encrypted session	175
G.8	Example #8: Encrypted sessionless	178
G.9	Example #9: Encrypted notification	180
Annex H	(informative) CRC examples	180
H.1	Trace.....	180
H.2	CRC code example	181
Annex I	(normative) The EAX' Cryptographic Mode.....	182
I.1	EAX' description	182
I.2	Justifications for selection of EAX rather than CCM	188
I.3	Justifications for the EAX' optimizations	189
I.4	EAX' C code example (informative)	191
I.5	AES C code example (informative).....	195

Annex J (informative) Connectionless-ACSE-1 equivalent reduced syntax for C12.22 Message transmission . 199
Annex K (informative) Bibliography201
Annex L (informative) Historical Background201
L.1 Foreword of American National Standard C12.22-2008201

Figures

Figure 4-1 Reference Topology 11
Figure 4-2 C12.22 Node Implementation Examples 11
Figure 5-1 C12.22 Reference Network Model 13
Figure 5-2 C12.22 Host Application Layer State Diagram 44
Figure 5-3 Unsegmented APDU Segmentation and Reassembly Algorithm 79
Figure 5-4 Segmented APDU Resegmentation and Partial Assembly Algorithm..... 80
Figure 6-1 C12.22 Communication Module Implementation Model 82
Figure 6-2 Transport Layer State Diagram for C12.22 Communication Module..... 102
Figure 6-3 Transport Layer State Diagram for C12.22 Device 103
Figure 6-4 Data Link Layer State Diagram 111
Figure 6-5 Jack and Cable Plug Wiring Diagram 113
Figure 7-1 Transport Layer State Diagram 114
Figure B-1 C12.22 Relays and Routing Tables 121
Figure B-2 C12.22 Relays and Routing Tables for Multiple Service Providers 122

1 Overview

1.1 Introduction

This Standard defines network Application Services for the exchange of Table data and control elements. These services must be implemented by all C12.22 Nodes, including “back-office” or “head-end” systems.

1.2 Scope

Initially, communications with electronic devices consisted of transporting memory data via proprietary protocols that were unique to each manufacturer. The desire for interoperability and support for multiple manufacturers by reading and programming systems created a need for standardization of data formats and transport protocols.

The first step was to standardize data formats. Internal data was abstracted as a set of Tables. A set of standard Table contents and formats were defined in ANSI C12.19/MC12.19/IEEE 1377, “Utility Industry End Device Data Tables.”¹

In the “Protocol Specification for ANSI Type 2 Optical Port” Standard (ANSI C12.18/MC12.18/IEEE 1701), a point-to-point protocol was developed to transport table data over an optical connection. The ANSI C12.18/ MC12.18/IEEE 1701 protocol include an application language called Protocol Specification for Electric Metering (PSEM) that allows applications to read and write Tables. The “Protocol Specification for Telephone Modem Communication” (ANSI C12.21/MC12.18/IEEE 1702) was then developed to allow devices to use PSEM to transport Tables over telephone modems.

This Standard extends the concepts of ANSI C12.18/MC12.18/IEEE 1701, ANSI C12.21/MC12.18/IEEE 1702, and ANSI C12.19/MC12.19/ IEEE 1377 Standards to allow transport of Table data over any reliable networking communications system. Note that in this use of the word, “reliable” means that for every message sent, the sender receives a response at its option: either a positive acknowledgment or an error message. That is, messages cannot fail silently in a reliable network (see discussion of Reliable Stream Transport Service in IPPA [B1]).²

In addition, this Standard describes an optionally exposed point-to-point interface between a C12.22 Device and a C12.22 Communications Module designed to attach to “any” network. The terms “C12.22 XXXX” (e.g., C12.22 Device) were introduced by ANSI C12.22-2008. These terms can be interchangeably replaced with the terms “IEEE 1703 XXXX”; i.e., the IEEE 1703 Device is the same as the ANSI C12.22 Device and the IEEE 1703 Communication Module is the same as the C12.22 Communication Module. However, since this Standard was originally developed under the auspice of ANSI C12 SC17 WG1, the document terminology is based on C12.22 terms.

Furthermore, this Standard defines a methodology to capture, translate, and transmit one-way device messages (blurts).

This Standard defines interfaces between IEEE 1377 Devices (ANSI C12.19 Devices) and network protocols.

Specific goals identified by the committee in the creation of this Standard were:

- a) Defining a Datagram that can convey ANSI C12.19 data Tables through any network

¹ Information on references can be found in clause 2.

² Numbers in brackets correspond to those of the bibliography in Annex K.