



ANSI C136.2-2023
A Revision of ANSI C136.2-2016

*American National Standard for
Roadway and Area Lighting Equipment—
Dielectric Withstand and Electrical Transient
Immunity Requirements*

Secretariat:

National Electrical Manufacturers Association

Approved: September 26, 2023

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

American National Standards Institute (ANSI) Standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus Standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its Standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this Standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other Standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by The American National Standards Institute, Inc. (ANSI) that the requirements for due process, consensus, and other criteria for approval have been met by the Standards developer. An American National Standard implies a consensus of those substantially concerned with its scope and provisions. Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly, and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered and that a concerted effort be made toward their resolution.

The existence of an American National Standard does not in any respect preclude anyone, whether s/he has approved the Standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the Standards. It is intended as a guide to aid the manufacturer, the consumer, and the general public.

The American National Standards Institute, Inc., does not develop Standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute, Inc. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on this title page.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc. require that action be taken periodically to reaffirm, revise, or withdraw this Standard. Purchasers of American National Standards may receive current information on all Standards by calling or writing the American National Standards Institute, Inc.

Published by

National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, VA 22209

www.nema.org

© 2024 National Electrical Manufacturers Association All rights reserved including translation into other languages reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, and without the prior written permission of the publisher.

Printed in the United States of America.

Preface

In order to minimize overlapping requirements and to streamline compliance with standards, a joint effort between the C136 and C82 committees has been undertaken to align some of the requirements of the following documents:

- ANSI C136.2-2018 *American National Standard for Roadway and Area Lighting Equipment — Dielectric Withstand and Electrical Transient Immunity Requirements*
- ANSI C82.77-5-2017 *American National Standard for Lighting Equipment — Voltage Surge Requirements*

While both standards cover voltage surge limits and testing requirements, ANSI C136.2 specifically focuses on roadway and area lighting applications while ANSI C82.77-5 covers all types of lighting applications. Along with other updates and corrections, the latest edition of ANSI C82.77-5 incorporates the requirements and methods previously contained in Sections 7.1 through 7.3 and Tables 3 through 5 of ANSI C136.2-2018 specifically for roadway and outdoor area lighting to align the requirements.

Furthermore, the following clarifications and additions were made in ANSI C82.77-5-2023:

- Addition of Clause 1.6, “Test Methods and Requirements,” to standardize test methodology across all luminaire applications
- Addition of Clause 2.1, “General,” to standardize Ring Wave and Combination Wave surge tests
- Tables 5 through 18 were rearranged for better clarity

Contents

Preface..... ii
Foreword..... iv
1 General..... 1
1.1 Scope 1
1.2 Limitations 1
1.3 Compliance Reporting..... 1
2 Normative References..... 2
3 Informative References 2
4 Insulation Requirements..... 3
4.1 General..... 3
4.2 Insulation Voltage Rating 3
5 General Testing Requirements 3
5.1 Test Samples 3
5.1.1 Optional Modular Devices 3
5.1.2 Control Device Receptacles..... 3
5.2 Test Setup 4
5.2.1 General..... 4
5.2.2 Temperature Measurements..... 4
6 Dielectric Withstand Test..... 4
6.1 General Requirements 4
6.1.1 Test Potential Generator 4
6.1.2 Electrical Connections..... 4
6.1.3 Electrical Disconnections 5
6.2 Test Procedure..... 5
6.3 Pass/Fail Criteria..... 5
7 Electrical Transient Immunity Tests 6
7.1 Shorting Cap Failure During Testing..... 6

Tables

Table 1 Recommended Electrical Transient Immunity Levels for Common Outdoor Lighting Applications 2
Table 2 Dielectric Withstand Test Specification..... 5

Foreword

At the time this standard was approved, the ANSI C136 committee was composed of the following members:

Acuity Brands, Inc.	Intertek
Alabama Power Company	Itron, Inc.
Amphenol Canada Corp	JEA
Atlas Lighting Products, Inc	Kauffman Consulting, LLC
Brainer Consulting	LED Roadway Lighting Ltd.
Caltrans	Legrand North America
City of Kansas City, Missouri	Light Smart
ClearWorld LLC	Littelfuse, Inc.
Cree Lighting	Lumispec Consulting
Current	Mississippi Power
DesignLights Consortium	National Grid
DimOnOff Inc.	Pacific Northwest National Laboratory
Dominion Energy SC	PSEG Power
Dominion Energy VA	Realterm Energy
Duke Energy	Signify North America Corporation
Duke Energy Progress	Solais Lighting Group
EPRI	Stresscrete/King Luminaire
Excellence Opto, Inc.	Sunrise Technologies, Inc.
FlexSol Lighting Solutions B.V.	Tampa Electric Company
Florida Power & Light Company	TE Connectivity
Georgia Power	Telera Networks Wireless
Gootroo Consulting	TECCO – The Eastern Specialty Company
Hancock Consulting	Utility Metals Division of Fabricated Metals, LLC
Hapco Aluminum Pole Products	Walshour Engineering Company, Inc.
Intermatic Incorporated	Xcel Energy

1 General

1.1 Scope

This standard covers luminaires and control devices classified for up to 600-volt operation¹ and intended for use in roadway and area lighting applications.

This standard contains the minimum performance requirements and test procedures for evaluating luminaire and control equipment under test (EUTs) for the following:

- a. Dielectric withstand
- b. Electrical transient immunity

1.2 Limitations

The test procedures contained in this standard are designed to evaluate the performance of luminaires, control devices, and (as applicable) combinations of luminaires and control devices, for the purpose of facilitating consistent performance reporting of such equipment. The results of a given test procedure, including whether or not the EUT achieved the minimum performance requirements specified in this standard, are only valid for the EUT configuration evaluated.

Users are warned that different combinations of luminaires and control devices may perform differently, and specification or knowledge of the independent performance of both a specific luminaire and a specific control device does not necessarily predict or guarantee any level of performance for the specific combination of luminaire and control device. While EUT manufacturers may attempt to identify and report test results for combinations of luminaires and control devices that represent typical, or perhaps worst-case, conditions according to some logic, these results should be viewed as informative only, as specific combinations of a luminaire and control device may perform better or worse.

The test procedures contained in this standard are not designed to evaluate the performance of components, such as surge protective devices (SPDs) or other varistor-based modules. Test procedures for components are contained in other standards (e.g., UL 1449) that evaluate parameters related to electrical transient immunity performance and, importantly, require over-voltage testing.

1.3 Compliance Reporting

EUT manufacturers that choose to claim compliance with this standard in their literature shall note the EUT configuration and environmental conditions in the test reporting, including the following:

- a. Three-wire (hot, neutral, protective earth) or two-wire (hot, neutral) electrical configuration²
- b. Permanently installed (not intended to be removed) in-line fuses
- c. Lamp, light engine, or other modular light source part number, if applicable
- d. Modular ballast or driver part number, if applicable
- e. Optional modular device part number(s), as applicable
- f. Ambient temperature and relative humidity

¹ Previous versions of ANSI C136.2 included separate requirements for luminaires classified for 250-volt and 5-kV operation. Luminaires classified for 250-volt operation are considered to be under the purview of this standard. For recommendations and/or requirements for 5-kV (i.e., series wired) luminaires, see other ANSI C136 standards, as appropriate, or continue to refer to ANSI C136.2-2004 (R2009).

² An EUT designed or otherwise intended for two-wire operation typically either does not have a protective earth connection or electrically shorts the protective earth and neutral connections within the EUT.