



ANSI/NEMA C80.5-2005

American National
Standard for
Electrical Rigid
Aluminum
Conduit (ERAC)



National Electrical Manufacturers Association
1300 North 17th Street, Suite 900 • Rosslyn, VA 22209
www.NEMA.org

Currently in preview, click buy full version





ANSI C80.5-2005

American National Standard

for Electrical Rigid Aluminum
Conduit (ERAC)

Currently in preview, click buy full version



ANSI C80.5-2005
Revision of
ANSI C80.5-1994

**American National Standard
For Electrical Rigid Aluminum Conduit (ERAC)**

Secretariat:

National Electrical Manufacturers Association

Approved August 18, 2005

American National Standards Institute, Inc.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

National Electrical Manufacturers Association
1300 North 17th Street, Rosslyn, VA 22209

© Copyright 2005 by National Electrical Manufacturers Association.

All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

This page intentionally left blank.

Contents

		Page
	Foreword	iv
1	Scope	1
2	Normative References	1
3	Definitions	1
4	Units of Measurements	2
5	General Requirements	2
5.1	Circular cross section	2
5.2	Wall thickness	2
5.3	Interior surface	2
5.4	Alloy	2
6	Detailed Requirements	2
6.1	Threading and chamfering	2
6.2	Identification	2
6.3	Dimensions	2
6.4	Threads	2
6.5	Couplings	3
6.6	Elbows and nipples	3
7	Ductility Test	3
8	Examination of Product	3
8.1	Place of inspection	3
8.2	Visual inspection	3
8.3	Retests	3
9	Marking	4
9.1	Product marking	4
9.2	Nipples	4
 Tables		
1	Dimensions of threads for rigid aluminum conduit	4
2	Dimensions and weights for rigid aluminum conduit	5
3	Dimensions of couplings	6
4	Dimensions of 90-degree elbows and weights of nipples per hundred	7

Foreword (This Foreword is not part of American National Standard C80.5-2005.)

This standard was developed by the Accredited Standards Committee on Raceways for Electrical Wiring Systems, C80. The objective of the committee is to produce a comprehensive specification that would establish uniform dimensions and standard construction requirements for Electrical Rigid Steel Conduit, Steel Electrical Metallic Tubing, Electrical Intermediate Metal Conduit and Electrical Aluminum Rigid Conduit raceway products and their associated components.

The standard was originally approved in 1950 and revised in 1953, 1959, 1963, 1966, 1977, 1983, 1990, 1994 and 2005.

Suggestions for improvement of this standard will be welcome. They should be sent to:

National Electrical Manufacturers Association
1300 North 17th Street, Suite 1847
Rosslyn, Virginia 22209

This standard was processed and approved for submittal to ANSI by the Accredited Standards Committee on Raceways for Electrical Wiring Systems, C80. Committee approval of the standard does not necessarily imply that all committee members voted for its approval. At the time it approved this standard, the C80 Committee had the following members:

J. A. Gruber, Chairman
J. P. Collins, Jr., Secretary

Organization Represented:

Aluminum Association
American National Standards Institute
American Iron and Steel Institute
American Iron and Steel Institute
American Iron and Steel Institute
American Pipe Fittings Association
International Association of Electrical Insulators
International Brotherhood of Electrical Workers
National Electrical Contractors Association
National Electrical Manufacturers Association
National Electrical Manufacturers Association
National Electrical Manufacturers Association
National Electrical Manufacturers Association
National Electrical Manufacturers Association
Steel Tube Institute
Steel Tube Institute
Underwriters Laboratories, Inc
Unaffiliated
Unaffiliated
Unaffiliated

Name of Representative:

P. Pollak
H. Benko
J. A. Gruber
M. J. Brett, Jr.
J. Robbins
D. Thompson
W. Lilly
H. Hickman
B. Stauffer
A. W. Ballard
S. Blais
T. McNeive
E. Thompson
J. Dodds
K. Carroll
G. Scartozzi
G. Walbrecht
D. Gearing
R. Loyd
H. E. Harper, Jr.

For Electrical Rigid Aluminum Conduit (ERAC)—

1 Scope

This standard covers the requirements for porthole-extruded aluminum-alloy conduit for use as a raceway for the wires or cables of an electrical system. The finished conduit is produced in nominal 10 ft. (3.05 m) lengths, threaded on each end with one coupling attached.

This standard also covers aluminum conduit couplings, elbows, nipples and conduit lengths other than 10 ft (3.05 m).

Properly assembled systems of conduit, couplings, elbows and nipples manufactured in accordance with this standard, and other identified fittings, provide for the electrical continuity required of an equipment grounding conductor.

2 Normative References

The following standard contains provisions which, through reference in this text, constitute requirements of this American National Standard. All standards are subject to revision, and parties to agreements based on this American National Standard are encouraged to investigate the possibility of applying the most recent edition of the standard indicated below.

ANSI/ASME B1.20.1, *Pipe Threads, General Purpose (Inch)*

UL 6A, *Electrical Rigid Metal Conduit – Aluminum, Red Brass and Stainless Steel*

3 Definitions

3.1 electrical rigid aluminum conduit (ERAC): A threadable aluminum raceway of circular cross-section designed for the physical protection and routing of wire conductors and cables and for use as an equipment grounding conductor.

3.2 threaded coupling: An internally threaded aluminum cylinder for joining together the components of an ERAC system.

3.3 elbow: A manufactured curved section of ERAC threaded on each end.

3.4 nipple: A straight length of ERAC not more than 2 ft (0.61 m) long and threaded on each end.

3.5 straight conduit: A straight length of ERAC without a coupling.

3.6 finished conduit: A straight length of ERAC with one coupling attached.