

Identification, Repair, and Mitigation of Cracking of Steel Equipment in Fuel Ethanol Service

API BULLETIN 939-E
SECOND EDITION, AUGUST 2013



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Classified areas may vary depending on the location, conditions, equipment, and substances involved in any given situation. Users of this Bulletin should consult with the appropriate authorities having jurisdiction.

Users of this Bulletin should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

Copyright reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Currently in preview, click buy full version

Contents

	Page
1 Scope	1
2 Normative References	1
3 Terms, Definitions, Acronyms, and Abbreviations	3
3.1 Terms and Definitions	3
3.2 Acronyms and Abbreviations	4
4 Background on SCC in Fuel Ethanol	5
4.1 Description of Fuel Ethanol	5
4.2 Relevant Standards for Fuel Ethanol	5
4.3 Supply Chain for Fuel Ethanol	6
4.4 Significance of SCC in Fuel Ethanol	7
4.5 Factors Related to SCC	10
5 Guidelines for Fabrication of Equipment	13
5.1 Materials of Construction	13
5.2 Tank Foundations	15
5.3 Fabrication of Tanks	15
5.4 Fabrication Guidelines to Minimize SCC	16
5.5 Specific Guidelines for Minimizing SCC in Various Components	16
5.6 Guidelines for PWHT	17
5.7 Organic Coatings for Internal Protection of Tanks	18
6 Inspection of Existing Equipment	19
6.1 General	19
6.2 Inspection Intervals	19
6.3 Inspection After Leakage Caused by SCC	20
6.4 Initial Inspection Without Leakage	20
6.5 Examination Procedures for Identification of SCC	20
7 Repair of SCC Damaged Equipment	23
7.1 General	23
7.2 Assessment of Fitness for Service and Risk	23
7.3 Temporary Repair by Clamps and Patches	23
7.4 Crack Repair	24
7.5 Stress Relief Heat Treatment Applied to Piping and Components	24
7.6 Coatings	25
8 Monitoring of Fuel Ethanol	25
8.1 Sampling and Analysis of Fuel Ethanol	25
8.2 Methods for Monitoring and Testing for Corrosion and SCC	25
Annex A (informative) Listing of Reported Cases of SCC in Fuel Ethanol and Remedial Measures	26
Annex B (informative) Form to Submit New Information on SCC in Fuel Ethanol Systems	32
Annex C (informative) Examples of Typical SCC in Fuel Ethanol	34
Bibliography	42

Contents

	Page
Figures	
C.1 SCC in Steel Tank Bottom	35
C.2 SCC in Steel Air Eliminator Vessel	36
C.3 Leak in Piping Resulting from a Crack Adjacent to the Weld	36
C.4 Characteristics of SCC in Steel Exposed to Fuel Ethanol, Showing Multiple Crack Initiations and Through-thickness Propagation in Piping	36
C.5 SCC in Steel Tank Bottom Showing Highly Branched, Intergranular Cracks at 100X	37
C.6 SCC in Steel Metallographically Prepared with Grain Boundary Etch at 500X	37
C.7 SCC in Steel Pipe from a Loading Rack Supply Line	38
C.8 Cracking of Another Pipe Sample from Same Situation as Noted in the Previous Figure	39
C.9 SCC of Steel Piping in a Fuel Ethanol System Return Line/Tank Transfer Line	40
C.10 Same SCC Incidence Shown in Previous Figure	41
Tables	
1 Quality Specification for Fuel Ethanol per ASTM D4806	6
2 Generally Compatible and Incompatible Polymeric Materials	15

Identification, Repair, and Mitigation of Cracking of Steel Equipment in Fuel Ethanol Service

1 Scope

Usage of fuel ethanol as an oxygenate additive in gasoline blends is increasing both in the United States and internationally. This document discusses stress corrosion cracking (SCC) of carbon steel tanks, piping, and equipment exposed to fuel ethanol as a consequence of being in the distribution system, at ethanol distribution facilities, or ethanol (EU) facilities where the fuel ethanol is eventually added to gasoline. Such equipment includes but is not limited to:

- storage tanks,
- piping and related handling equipment, and
- pipelines

that are used in distribution, handling, storage, and blending of fuel ethanol. However, data for pipelines in ethanol service is limited and caution should be used when applying guidelines from this document that have been derived mainly from applications involving piping and tanks in ethanol storage and blending facilities. SCC of other metals and alloys is beyond the scope of this document, as is the corrosion of steel in this service.

It is realized that SCC of steel in fuel ethanol is a topic where knowledge of the subject is actively growing through documentation of recent experience and through research in progress. This document deals with handling of cracks in existing equipment and reduction of SCC occurrence in new equipment as a result of exposure to fuel ethanol per ASTM D4806 (or other international specifications), ethanol fuel blends, and pipeline transmises involving fuel ethanol and conventional hydrocarbon fuels (gasoline, diesel, or jet fuel). It includes guidelines for carbon steel construction materials, including their fabrication, inspection, and repair to help assure safe and reliable operations.

This document is based on current engineering practice and insights from recent industrial experience and research. Older equipment may not conform exactly to the information contained herein, but this does not imply that such equipment is being operated in an unsafe or unreliable manner. It is also recognized that facilities may vary and may need to be modified depending on specific operating conditions, inspection, and maintenance experience. Each user company is ultimately responsible for its own safe and reliable operations.

The steels referred to in this document are defined by the ASTM or API designation systems or equivalent steel grades contained in other recognized codes or standards. Welded construction is considered the primary method of fabrication in equipment exposed to fuel ethanol.

Terminology used herein is given in Section 3.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Specification 5L, *Specification for Line Pipe*

API Publication 327, *Aboveground Storage Tank Standards: A Tutorial*

API 570, *Piping Inspection Code: Inspection, Repair, Alteration, and Rerating of In-service Piping Systems*

API Recommended Practice 574, *Inspection Practices for Piping System Components*