

Manual of Petroleum Measurement Standards Chapter 7—Temperature Determination

Section 2—Portable Electronic Thermometers

THIRD EDITION, MAY 2018

ERRATA 1, JANUARY 2021

ERRATA 2, JUNE 2023

REAFFIRMED, OCTOBER 2023



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Classified areas may vary depending on the location, conditions, equipment, and substances involved in any given situation. Users of this standard should consult with the appropriate authorities having jurisdiction.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Where applicable, authorities having jurisdiction should be consulted. Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the standard. At all times users should employ sound business, scientific, engineering, and judgment safety when using this standard.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Washington, DC 20001

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patents.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually and updated quarterly by API, 200 Massachusetts Avenue, NW, Washington, DC 20001.

This standard, API *MPMS* Chapter 7.2, Third Edition, supersedes the following sections of API *MPMS* Chapter 7, *Temperature Determination*, First Edition (2001) which has been withdrawn:

- 5.2—Portable Electronic Thermometers (PETs)
- 5.4—Electronic Temperature Devices
- 5.5—Thermowells
- 5.6—Data Collection, Data Transmission, and Receiving Equipment
- 6.1—Ambient Temperature
- 6.4—Portable Electronic Thermometers
- 8.2—Portable Electronic Thermometers (PETs)

API *MPMS* Chapter 7.1, *Temperature Determination—Liquid-in-Glass Thermometers*, Second Edition (2017) supersedes the following sections of API *MPMS* Chapter 7, First Edition (2001), which has been withdrawn:

- 5.3—Glass Thermometers
- 5.5—Thermowells

5.6—Data Collection, Data Transmission, and Receiving Equipment

6.1—Ambient Temperature

6.5—Mercury-in-Glass Thermometers

8.3—Glass and Mercury-in-Glass Thermometer Verification

API MPMS Chapter 7.3, *Temperature Determination—Fixed Automatic Tank Temperature Systems*, Second Edition (2011) superseded the following sections of API MPMS Chapter 7, First Edition (2001), which has been withdrawn:

5.1—Fixed Automatic Tank Thermometers (ATTs)

5.5—Thermowells

5.6—Data Collection, Data Transmission, and Receiving Equipment

6.1—Ambient Temperature

6.3—Fixed Automatic Tank Thermometers

8.1—Fixed Automatic Tank Thermometers (ATTs)

9.1—Fixed Automatic Tank Thermometers

API MPMS Chapter 7.4, *Temperature Determination—Dynamic Temperature Measurement*, Second Edition (2018) superseded the following sections of API MPMS Chapter 7, First Edition (2001), which has been withdrawn:

5.5—Thermowells

5.6—Data Collection, Data Transmission, and Receiving Equipment

7—Dynamic Temperature Measurement

8.4—Dynamic Verification and Calibration

9.2—Dynamic Temperature Equipment

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Washington, DC 20001, standards@api.org.

Contents

	Page
1 Scope	1
2 Normative References	1
3 Terms, Definitions, and Acronyms	2
3.1 Terms and Definitions	2
4 General Precautions	3
4.1 Safety	3
4.2 Mercury Warning	3
4.3 Equipment Precautions	3
5 Units of Measure	4
6 Equipment and Design Requirements	4
6.1 Environment	4
6.2 Accuracy, Resolution, and Discrimination	4
6.3 Stabilization	5
6.4 Cable and Probe	5
6.5 Voltage Indicator	5
6.6 Additional Functionality	5
6.7 Thermowells	5
7 Procedures for Temperature Determination	6
7.1 General	6
7.2 Static Temperature Determination	7
7.3 Dynamic Temperature Determination	12
8 Accuracy Requirements	12
8.1 PET Specification	12
8.2 PET Verification	13
8.3 Requirements for a Reference Standard Thermometer	13
8.4 Requirements for a Dry Block	14
9 Inspection, Verification, and Calibration Requirements	14
9.1 General	14
9.2 Inspection	14
9.3 Calibration	16
9.4 Record Keeping	16
Annex A (informative) Mercury-in-Glass Thermometer Alternative Testing Phase II—Calibration Devices ..	18
Bibliography	21
Tables	
1 Positioning of Horizontal Thermowells in Pressurized Tanks	6
2 Minimum Number of Temperature Measurements for Various Depths of Hydrocarbon Liquid in Storage, Lease, Ship, and Barge Tanks	8
3 Temperature Measurements for Horizontal Cylindrical Tanks	9
4 Typical Immersion Times for PETs	11
5 PET Specification	13
6 Allowable Tolerances for Operating PET versus Reference Standard Thermometer	13
7 Verification and Calibration Requirements for PETs	15

Currently in preview, click buy full version

Introduction

The purpose of this standard is to describe methods and practices that may be used to obtain accurate temperature measurements of petroleum and petroleum products in storage tanks, ships, and barges under static conditions by the use of a portable electronic thermometer (PET). The use of PETs for dynamic measurement applications is primarily covered in API *MPMS* Ch. 7.4; however, guidance is provided in this standard on the device itself, including practices to ensure accuracy.

Previous versions of this standard described various temperature methods and apparatuses. They did not give much guidance on specific applications or methods of verification and certification, and were oriented toward crude oil. This version will include guidance on calibration, verification, and certification of equipment used in liquid petroleum products, refinery feedstocks, and renewable fuel products. Annex A is reference material for the user that synthesizes the methods described in this standard.

Temperature has a significant impact on the volumetric determination of liquid quantities when correcting observed volume to volume at standard conditions. As a result, the most accurate means for temperature determination should be used. For custody transfer, the means of temperature determination should be agreed among the parties involved.

Temperature Determination—Portable Electronic Thermometers

1 Scope

This chapter describes the methods, equipment, and procedures for manually determining the temperature of liquid petroleum and petroleum products by use of a portable electronic thermometer (PET).

This chapter discusses temperature measurement requirements in general for custody transfer, inventory control, and marine measurements. The actual method and equipment selected for temperature determination are left to the agreement of the parties involved.

The manual method covers:

- nonpressurized tanks and nonpressurized marine vessel;
- gas-blanketed tanks and gas-blanketed marine vessels.

It does not cover hydrocarbons under pressures in excess of 21 kPa (3 psia gauge) or cryogenic temperature measurement unless the tank is equipped with a thermowell.

The requirements of this chapter are based on practices for crude oil and petroleum products covered by API MPMS Ch. 11.1 (ASTM D1250). Requirements in this chapter may be used for other fluids and other applications. However, other applications may require different performance and installation specifications.

2 Normative References

API

Manual of Petroleum Measurement Standards

Chapter 1, *Terms and Definitions*

Chapter 3, *Tank Gauging* (all sections)

Recommended Practice 500, *Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities Classified as Class I, Division 1, and Division 2*

Recommended Practice 2003, *Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents*

Recommended Practice 3000, *Classifying and Loading of Crude Oil into Rail Tank Cars*

ASTM

E2877, *Standard Guide for Digital Contact Thermometers*

E777, *Standard Test Method for Inspection and Verification of Thermometers*

E344, *Terminology Relating to Thermometry and Hydrometry*