

# Pipeline SCADA Alarm Management

API RECOMMENDED PRACTICE 1167  
SECOND EDITION, JUNE 2016



AMERICAN PETROLEUM INSTITUTE

## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe on privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

*Copyright © 2016 American Petroleum Institute*

## Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.  
Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the Director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Currently in preview, click buy full version

# Contents

1	Scope	1
2	Normative References	1
3	Terms, Definitions, and Abbreviations	2
3.1	Definitions	2
3.2	Abbreviations	5
4	Alarm Management Plan	6
5	Alarm Philosophy	6
5.1	Alarm Philosophy Purpose	6
5.2	Alarm Philosophy Use and Contents	7
6	Alarm Application and Determination	8
6.1	General Considerations	8
6.2	Alarm Determination	9
6.3	Purpose and Use of Alarm Priority	9
6.4	Diagnostic Alarm Priority	10
6.5	Safety-related Alarms	10
6.6	Other Uses of the Alarm System	11
7	Alarm Documentation and Rationalization	11
7.1	General	11
7.2	Documentation & Rationalization Process	11
7.3	Documentation & Rationalization Methodology	11
7.4	Documentation & Rationalization Preparation	12
7.5	Determination and Assignment of Alarm Priority	13
7.6	Determination of Alarm Setpoint	13
7.7	Staged Approaches to Alarm Rationalization	14
7.8	Recommended Storage of Documentation & Rationalization Information	14
8	SCADA System Alarm Functionality and Alarm Design	14
8.1	General	14
8.2	Point Types and Alarm Types	15
8.3	Alarm Priority	16
8.4	Alarm Settings and Alarm Occurrences	16
8.5	Other Alarm-related Electronic Records	17
8.6	Alarm Logs/Alarm Summaries	17
8.7	Event Logs/Event Summaries	17
8.8	Alarm Summary Display	18
8.9	Alarm Deadband	18
8.10	Alarm On-Delay and Off-Delay	18
8.11	Alarm Suppression and Alarm Shelving	19
8.12	Alarm System Reliability	19
8.13	Defined Alarm Design Cases	20
9	Roles and Responsibilities	21
9.1	Overview and Introduction	21
9.2	Management	21
9.3	Technical	21
9.4	Operations	21

## Contents

10	Alarm Handling	22
10.1	General	22
10.2	Nuisance Alarms	22
10.3	Alarm Shelving	22
10.4	Designed Alarm Suppression	23
10.5	State-based or State-dependent Alarms	23
10.6	Alarm Flood Suppression	23
10.7	Alarm Audit and Enforcement	24
10.8	Special-purpose Priorities and Alarm Routing	24
10.9	Controller-adjustable Alarms	24
11	Controller Alert Systems	25
12	Nonannunciated Events	25
13	Alarm Audits and Performance Monitoring	26
13.1	Overview and Introduction	26
13.2	Audits of Managerial and Work Practices	26
13.3	Alarm System Performance Metrics	27
13.4	Alarm System Key Performance Indicators	27
13.5	Reporting of Alarm System Analyses	29
13.6	Regulatory Requirements for Alarm System Monitoring	30
14	Management of Change	30
14.1	Purpose and Use	30
14.2	Testing	30
14.3	Documentation	30
14.4	Notification and Training	31
14.5	Emergency Management of Change	31
14.6	Temporary Management of Change	31
14.7	Regulatory Requirements for Management of Change	31
	Annex A (informative) Determination of Alarm Priority	32
	Annex B (informative) Priority Distribution for Alarm Configuration and Occurrence	36
	Annex C (informative) Guidelines for Determining Possible Alarm System Key Performance Indicators	37
	Bibliography	39
	Tables	
A.1	EXAMPLE Areas of Impact and Severity of Consequences Grid	33
A.2	EXAMPLE Maximum Time Available for Response and Correction Grid	34
A.3	EXAMPLE Severity of Consequences and Time to Respond Grid for Alarm Priority Determination	34
B.1	Recommended Priority Distribution for Alarm Configuration and Occurrence	36
C.1	Alarm KPI Summary	38

## Introduction

This publication was created by an API subcommittee. The members of this subcommittee were predominantly pipeline operators of liquid pipelines, but included participation from pipeline operators of gas pipelines, as well as members from the alarm management and control systems communities and U.S. Department of Transportation Pipeline and Hazardous Materials Safety Administration representatives.

With the technological advances of SCADA systems within the pipeline industry over the past two decades, it has become relatively simple to supply pipeline controllers with a wealth of information regarding the pipeline systems that they are operating. As the amount of information available to a controller increases, the importance of having a program in place to manage this information also increases. Alarm information should be presented to the controller in a manner that allows for easy identification and clear expectations as to the response required.

# Pipeline SCADA Alarm Management

## 1 Scope

This document is intended to provide pipeline operators with recommended industry practices in the development, implementation, and maintenance of an alarm management program. It provides guidance on elements that include, but are not limited to, alarm definition, philosophy, documentation, management of change, and auditing.

This document is not intended to be a step-by-step set of instructions on how to build an alarm management system. Each pipeline operator has a unique operating philosophy and will therefore have a unique alarm philosophy as well. This document is intended to outline key elements for review when building an alarm management system.

SCADA systems used within the pipeline industry vary in their alarm-related capabilities. There are also many different software systems available to aid in alarm management. It is the responsibility of the pipeline operator to determine the best method to achieve their alarm management goals.

This document uses industry best practices to help to illustrate aspects of alarm management. The scope is intended to be broad. There are several publications and standards listed in Section 2 and the Bibliography that provide greater detail on the various elements of alarm management. Pipeline operators are encouraged to consult these publications.

## 2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Recommended Practice 1165, *Recommended Practice for Pipeline SCADA Displays*

ANSI/ISA<sup>1</sup> 18.2-2009, *Management of Alarm Systems for the Process Industries*

49 CFR Part 192<sup>2</sup>, *Transportation of Natural Gas and Other Gas by Pipeline: Minimum Federal Safety Standards*

49 CFR Part 195, *Transportation of Hazardous Liquids by Pipeline*

---

<sup>1</sup>The Instrumentation, Systems, and Automation Society, 67 Alexander Drive, Research Triangle Park, North Carolina, 22709, [www.isa.org](http://www.isa.org)

<sup>2</sup>U.S. Department of Transportation, Pipeline and Hazardous Materials Safety Administration, East Building, 2nd Floor, 1200 New Jersey Ave., SE, Washington, DC 20590, [www.phmsa.dot.gov](http://www.phmsa.dot.gov)