

Pipeline SCADA Alarm Management

Pipeline Segment

API RECOMMENDED PRACTICE 1167
FIRST EDITION, DECEMBER 2010



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Copyright reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Copyright © 2010 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Currently in preview, click buy full version

Contents

	Page
1 Scope	1
1.1 Purpose	1
1.2 Scope Limitations	1
2 Normative References	1
3 Definitions and Abbreviations	2
3.1 Definitions	2
3.2 Abbreviations	5
4 Alarm Definition and Determination	5
4.1 General Considerations	5
4.2 Alarm Determination	6
4.3 Purpose and Use of Alarm Priority	6
4.4 Diagnostic Alarm Priority	7
4.5 Safety-related Alarms	7
4.6 Other Uses of the Alarm System	8
5 Alarm Philosophy	8
5.1 Alarm Philosophy Purpose	8
5.2 Alarm Philosophy Use and Contents	8
6 Alarm Documentation and Rationalization	10
6.1 General	10
6.2 Documentation & Rationalization Process	10
6.3 Documentation & Rationalization Methodology	10
6.4 Documentation & Rationalization Preparation	11
6.5 Determination and Assignment of Alarm Priority	12
6.6 Determination of Alarm Setpoint	12
6.7 Staged Approaches to Alarm Rationalization	13
6.8 Recommended Storage of D&R Information	13
7 SCADA System Alarm Functionality and Alarm Design	13
7.1 General	13
7.2 Point Types and Alarm Types	13
7.3 Alarm Priority	15
7.4 Alarm Settings and Alarm Occurrences	15
7.5 Other Alarm-related Electronic Records	16
7.6 Alarm Logs/Alarm Summaries	16
7.7 Event Logs/Event Summaries	16
7.8 Alarm Summary Display	17
7.9 Alarm Deadband	17
7.10 Alarm On-Delay and Off-Delay	17
7.11 Alarm Suppression and Alarm Shelving	17
7.12 Leak or Possible Leak Alarms	18
7.13 Alarm System Reliability	18
7.14 Defined Alarm Design Cases	19
8 Roles and Responsibilities	20
8.1 Overview and Introduction	20
8.2 Management	20
8.3 Technical	20

Contents

	Page
8.4 Operations	20
9 Alarm Handling	21
9.1 General	21
9.2 Nuisance Alarms	21
9.3 Alarm Shelving	21
9.4 Designed Alarm Suppression	22
9.5 State-based or State-dependent Alarms	22
9.6 Alarm Flood Suppression	22
9.7 Alarm Audit and Enforcement	23
9.8 Special-purpose Priorities and Alarm Routing	23
9.9 Controller-adjustable Alarms	23
9.10 Controller Alert Systems	24
10 Alarm Audits and Performance Monitoring	25
10.1 Overview and Introduction	25
10.2 Audits of Managerial and Work Practices	25
10.3 Alarm System Performance Metrics	26
10.4 Alarm System Key Performance Indicators	26
10.5 Reporting of Alarm System Analyses	28
10.6 Regulatory Requirements for Alarm System Monitoring	29
11 Management of Change	29
11.1 Purpose and Use	29
11.2 Testing	29
11.3 Documentation	30
11.4 Notification and Training	30
11.5 Emergency MOCs	30
11.6 Temporary MOCs	30
11.7 Regulatory Requirements for Change Management	30
Annex A (informative) Alarm Philosophy Document Example Table of Contents	31
Annex B (informative) Determination of Alarm Priority	34
Annex C (informative) Priority Distribution for Alarm Configuration and Occurrence	38
Annex D (informative) Summary of Alarm System Key Performance Indicators (KPIs)	39
Bibliography	41
Tables	
B-1 EXAMPLE Areas of Impact and Severity of Consequences Grid	35
B-2 EXAMPLE Maximum Time Available for Response and Correction Grid	36
B-3 EXAMPLE Severity of Consequences and Time to Respond Grid for Alarm Priority Determination ...	36
C-1 Recommended Priority Distribution for Alarm Configuration and Occurrence	38
D-1 Alarm KPI Summary	40

Introduction

This publication was created by an API subcommittee. The members of this subcommittee were predominantly operators of liquids pipelines, but included participation from operators of gas pipelines, as well as members from the alarm management and control systems communities and U.S. Department of Transportation Pipeline and Hazardous Materials Safety Administration representatives.

With the technological advances of SCADA systems within the pipeline industry over the past two decades, it has become relatively simple to supply pipeline controllers with a wealth of information regarding the pipeline systems that they are operating. As the amount of information available to a controller increases, the importance of having a program in place to manage this information also increases. Alarm information should be presented to the controller in a manner that allows for easy identification and with clear expectations as to the response required.

Currently in preview, click buy full version

Pipeline SCADA Alarm Management

1 Scope

1.1 Purpose

This document is intended to provide pipeline operators with recommended industry practices in the development, implementation, and maintenance of an alarm management program. It provides guidance on elements that include, but are not limited to, alarm definition, alarm philosophy, documentation, management of change, and auditing.

1.2 Scope Limitations

This document is not intended to be a step by step set of instructions on how to build an alarm management system. Each pipeline operator has a unique operating philosophy and will therefore have a unique alarm philosophy as well. This document is intended to outline key elements that should be considered when building an alarm management system.

SCADA systems and similar technologies used within the pipeline industry vary in their alarm related capabilities. There are also many different software systems available to aide in alarm management. It is the responsibility of the operator to determine the best method to achieve their alarm management goals.

This document uses industry best practices to help illustrate aspects of alarm management. The scope is intended to be broad. There are several publications and standards listed in Section 2 (Normative References) and the Bibliography that provide greater detail on the various elements of alarm management. Operators are encouraged to consult these publications.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Recommended Practice 1165, *Recommended Practice for Pipeline SCADA Displays*

ANSI/ISA 18.2-2009, *Management of Alarm Systems for the Process Industries*

49 CFR Part 192², *Transportation of Natural Gas and Other Gas by Pipeline: Minimum Federal Safety Standards*

49 CFR Part 195, *Transportation of Hazardous Liquids by Pipeline*

¹ The Instrumentation, Systems, and Automation Society, 67 Alexander Drive, Research Triangle Park, North Carolina, 22709, www.isa.org

² U.S. Department of Transportation, Pipeline and Hazardous Materials Safety Administration, East Building, 2nd Floor, 1200 New Jersey Ave., SE, Washington, DC 20590, www.phmsa.dot.gov/.