

**Design, Installation, and
Maintenance of Electrical Systems
for Fixed and Floating Offshore
Petroleum Facilities for
Unclassified and Class 1, Division 1
and Division 2 Locations**

Upstream Segment

API RECOMMENDED PRACTICE 14F
FIFTH EDITION, JULY 2008



Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.

Copyright © 2008 American Petroleum Institute

Foreword

This recommended practice (RP) contains information for use primarily by engineers with a working knowledge of electrical systems and production operations. Some of the information may be useful to experienced electrical maintenance and operating personnel. The intent of the document is to identify important features of offshore electrical systems and to present generally accepted practices for electrical design and installation that experience in the offshore petroleum industry has shown results in safe, reliable, efficient, and maintainable operations. Nothing in this RP is to be construed as a fixed rule without regard to sound engineering judgment, nor is it intended to supersede or override any federal, state, or local regulation where applicable.

The First Edition of API 14F was published in July 1978 as API 14F, *Design and Installation of Electrical Systems for Offshore Production Platforms*, under the jurisdiction of the API Production Department. The Second Edition was published on July 1, 1985. The Third Edition was published September 1, 1991. The Fourth Edition was published June 1999, with a new title, *Recommended Practice for Design and Installation of Electrical Systems for Fixed and Floating Offshore Petroleum Facilities for Unclassified and Class I, Division 1 and Division 2 Locations*. A related document, API 14FZ, *Recommended Practice for Design and Installation of Electrical Systems for Fixed and Floating Offshore Petroleum Facilities for Unclassified and Class I, Zone 0, Zone 1 and Zone 2 Locations*, was published in 1999 to address wiring methods introduced in Article 505 of the 1999 *National Electrical Code*.

This document includes usage of the verbs *shall* and *should*; whichever is the more applicable to the function. For the purpose of this document:

Shall indicates the RP is considered a minimum requirement that has universal applicability to the specific activity.

Should indicates a RP: (1) for which alternative practices may be equally safe and/or effective; or, (2) which may not be practical under some circumstances or applications.

It is recommended indicates a preferred practice that has no known direct safety or regulatory implication.

Phrases that use “consider” such as “should be considered,” “consideration should be given,” etc, indicate the user should pay particular attention to the referenced topic, in the context of the sentence where used as well as other related topics in this document and then make an application decision based on the relevant facts and sound engineering judgment.

This RP shall become effective on the date printed on the cover but may be used voluntarily from the date of distribution.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in this publication be construed as insuring anyone against liability for infringement of letters patent.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, D.C. 20005, standards@api.org.

Currently in preview, click buy full version

Contents

	Page
1 General	1
1.1 Scope	1
1.2 Applicability of <i>National Electrical Code</i>	1
2 References	1
2.1 Industry Codes, Guides, and Standards	1
2.2 Government Codes, Rules, and Regulations	9
2.3 Classification Society Rules and Regulations	10
3 Acronyms and Abbreviated Definitions	11
3.1 Acronyms	11
3.2 Definitions, Abbreviated	12
3.3 Definitions Specific to Floating Facilities	26
4 Electrical Equipment for Hazardous (Classified) Locations	27
4.1 General	27
4.2 High-temperature Devices	28
4.3 Protection Techniques Related To Equipment Installed in Locations Classified as Division 1 or Division 2	28
4.4 Protection Techniques Related to Equipment Approved for Zone 0, Zone 1, or Zone 2 Locations	31
4.5 General Purpose Equipment	31
4.6 Listing, Marking and Documentation	31
5 Electric Power Generating Stations	32
5.1 General	32
5.2 Prime Movers	32
5.3 Generators	36
5.4 Generator Packaging Considerations	42
5.5 Switchboards	42
5.6 Special Requirements for Floating Facilities	44
6 Electrical Distribution Systems	47
6.1 Scope	47
6.2 Voltage Level Selection	47
6.3 Conductor Selection	48
6.4 Wiring Methods for Classified Locations	55
6.5 Wiring Methods for Unclassified Locations	60
6.6 Wiring Methods for Drilling and Workover Rigs	60
6.7 General Wiring Considerations	60
6.8 Conduit and Cable Seals and Sealing Methods	64
6.9 Circuit Protection	74
6.10 Grounding	74
6.11 Electrical Enclosures	77
6.12 Working Space About Electrical Equipment and Means of Access	82
6.13 Additional Requirements for Floating Facilities	84
7 Electric Motors	84
7.1 General	84
7.2 Selection	84
7.3 Motor Space Heaters	86
7.4 Motor Control	86

8	Transformers	88
8.1	General	88
8.2	Selection	88
8.3	Installation	90
8.4	Connections	90
8.5	Protection	91
9	Lighting	92
9.1	General	92
9.2	Lighting Levels	92
9.3	Fixture Selection and Installation	93
9.4	Standby Lighting	95
9.5	Lighting for Helicopter Operations	96
10	Battery-powered DC Supply Systems	97
10.1	General	97
10.2	Specific Applications	98
10.3	Batteries	98
10.4	Battery Chargers	102
10.5	Uninterruptible Power Supply (UPS) Systems	103
11	Special Systems	105
11.1	Electrical Platform Safety Control Systems	105
11.2	Gas Detection Systems	107
11.3	Fire Detection Systems	108
11.4	Aids-to-Navigation Equipment	109
11.5	Communications Equipment	110
11.6	Heat Trace Systems	111
11.7	Fire Pumps	111
11.8	Adjustable Frequency Controllers (Variable Frequency Drives)	111
11.9	Submarine Cables	118
11.10	Electric Oil-immersion Heaters	118
11.11	Electric Power-operated Boat Winches for Survival Craft	119
11.12	Electric Power-operated Water-tight Doors	119
11.13	Hull Mechanical Systems Controls	119
11.14	Cargo Tanks on Floating Facilities	119
11.15	Cargo Handling Rooms on Floating Facilities	120
11.16	General Alarm System	120
11.17	Cathodic Protection	123
12	Special Considerations	124
12.1	Construction Practices	124
12.2	Electronic Instrumentation	126
12.3	Electrical Tools	126
12.4	Electrical Appliances	126
12.5	Extension Cords	127
12.6	Electrical Equipment Buildings	127
12.7	Signs	127
12.8	Lockout and Tagout Procedures	127
12.9	Portable Electronic Devices	127
13	System Checkout	127
13.1	General	127
13.2	Generators and Motors	128

13.3	Instrumentation and Control Circuits	128
14	Maintenance	128
15	Safety	128
	Annex A (informative) Inspection Intervals	129
	Annex B (informative) ABS Rules For Building and Classing Steel Vessels—1998, PART 4	130
	Annex C (informative) USCG Requirements, 46 CFR, Subchapter J, 111.95	141
	Annex D (informative) USCG Requirements, 46 CFR, Subchapter J, 111.97	144
	Annex E (informative) USCG Requirements, 46 CFR, Subchapter J, Subpart 111.105	146
Figures		
1	Typical Class 1, Division 1 Electrical Installation Conduit System	65
2	Typical Class 1, Division 1 Electrical Installation Cable System	66
3	Typical Class 1, Division 2 Electrical Installation Conduit or Cable System	67
4	Typical Class 1, Division 1 or Division 2 Electrical Installation Conduit and Cable Connections to Process-connected Nonarcing Devices with Single-seal Diaphragm or Tube	68
5	Typical Class 1, Division 1 or Division 2 Electrical Installation Conduit and Cable Connections to Process-connected Nonarcing Devices with Multiple Seal Diaphragms or Tubes	69
6	Typical Class 1, Division 1 or Division 2 Electrical Installation Conduit or Cable Connections to Process-connected Arcing Devices	70
7	Typical Class 1, Division 1 or Division 2 Electrical Installation Placement of Drain Seals	71
8	Typical Speed Torque Curve for Variable Torque Load	114
9	Typical Speed Torque Curve for Constant Torque Load	114
10	Typical Speed Torque Curve for Constant Horsepower Load	115
11	Typical Speed Torque Characteristics for Impact-type Loads	116
4/5 C.1	Limiting Curves for Loading 4-stroke Diesel Engines Step by Step from No-load to Rated Power as Function of the Brake Mean Effective Pressure	137
Tables		
1	Ampacities for Marine Shipboard Distribution, Control, and Signal Cables, 2000 Volts or Less, AC or DC, Copper Conductors, Single-banked (Single-layered), Maximum Current-carrying Capacity Based on 45 °C Ambient	49
2	Ampacities for Marine Shipboard Single-conductor Distribution Cables, 2000 Volts or Less DC Only, Copper Conductors, Single-banked (Single-layered), Maximum Current-carrying Capacity Based on 45 °C Ambient	50
3	Ampacities for Three-conductor Medium Voltage Power Cable, 2001 Volts to 35 kV, Copper Conductor Single-banked (Single-layered), Maximum Current-carrying Capacity Based on 45 °C Ambient	51
4	Ampacities for Medium Voltage Power Cable, 2001 Volts to 35 kV, Copper Conductor Single-conductor in Triplexed or Triangular Configuration, Maximum Current-carrying Capacity Based on 45 °C Ambient	52
5	Ampacities for Single-conductor Medium Voltage Power Cable, 2001 Volts to 35 kV, Copper Conductor Single-banked (Single-layered), Maximum Current-carrying Capacity Based on 45 °C Ambient, Shields Grounded on One End (Open-circuited Shields)	53
6	Wiring Methods for Classified Locations (See 6.4, 6.6, 6.7, and 6.8 for Explanations and Qualifications)	56
7	Common Power and Control Cables Sizes and Configurations	63
8	Common Instrumentation Cable Sizes and Configurations	64
9	Circuit Protection Devices—Advantages and Disadvantages	75
10	NEMA Enclosures	78
11	Degree of Protection of Enclosures in Accordance with IEC 60529	81

12	Selection of IP Rated enclosures to meet NEMA requirements	81
12-1	Selection of NEMA enclosures to Meet IP Designations	82
13	Working Clearances	83
14	NEMA Motor Starter Sizing	87
15	Minimum Recommended Levels of Illumination for Efficient Visual Tasks	95
16	Minimum Recommended Levels of Illumination for Safety	95
17	Comparison of Batteries by Cell Type	100

Currently in preview, click buy full version

Design, Installation, and Maintenance of Electrical Systems for Fixed and Floating Offshore Petroleum Facilities for Unclassified and Class 1, Division 1 and Division 2 Locations

1 General

1.1 Scope

1.1.1 This document recommends minimum requirements and guidelines for the design, installation, and maintenance of electrical systems on fixed and floating petroleum facilities located offshore. For facilities classified as Zone 0, Zone 1 or Zone 2, reference API 14FZ, *Recommended Practice for Design and Installation of Electrical Systems for Fixed and Floating Offshore Petroleum Facilities for Unclassified and Class 1, Zone 0, Zone 1 or Zone 2*. These facilities include drilling, producing and pipeline transportation facilities associated with oil and gas exploration and production. This recommended practice (RP) is not applicable to Mobile Offshore Drilling Units (MODUs) without production facilities. This document is intended to bring together in one place a brief description of basic desirable electrical practices for offshore electrical systems. The recommended practices contained herein recognize that special electrical considerations exist for offshore petroleum facilities. These include:

- a) the inherent electrical shock possibility presented by the marine environment and steel decks;
- b) space limitations that require that equipment be installed in or near classified locations;
- c) the corrosive marine environment;
- d) motion and buoyancy concerns associated with floating facilities.

1.1.2 This RP applies to both permanent and temporary electrical installations. The guidelines presented herein should provide a high level of electrical safety when used in conjunction with well-defined area classifications. This RP emphasizes safe practices for classified locations on offshore petroleum facilities but does not include guidelines for classification of areas; for guidance on the classification of areas refer to API 500 and API 505, as applicable.

1.2 Applicability of *National Electrical Code*

1.2.1 Electrical systems for offshore petroleum facilities shall be designed and installed in accordance with the *National Electrical Code*, 2008 edition, except where specific departures are noted.

2 References

2.1 Industry Codes, Guides, and Standards

Various organizations have developed numerous codes, guides and standards that have substantial acceptance by industry and governmental bodies. Codes, guides, and standards useful in the design and installation of electrical systems are listed below as references only. These are not considered to be a part of this RP except for those specific sections of documents referenced elsewhere in this RP.

API RP 2, *Planning, Designing, and Constructing Heliports for Fixed Offshore Platforms*

API RP 14C, *Analysis, Design, Installation and Testing of Basic Surface Safety Systems on Offshore Production Platforms*

API RP 14FZ, *Design and Installation of Electrical Systems for Fixed and Floating Offshore Petroleum Facilities for Unclassified and Class 1, Zone 0, Zone 1 and Zone 2 Locations*

API RP 14G, *Fire Prevention and Control on Open Type Offshore Production Platforms*