

# Fireproofing Practices in Petroleum and Petrochemical Processing Plants

API RECOMMENDED PRACTICE 2218  
THIRD EDITION, JULY 2013

REAFFIRMED, MARCH 2020



AMERICAN PETROLEUM INSTITUTE

## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Classified areas may vary depending on the location, conditions, equipment, and substances involved in any given situation. Users of this recommended practice should consult with the appropriate authorities having jurisdiction.

Users of this recommended practice should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Where applicable, authorities having jurisdiction should be consulted.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the recommended practice. At all times users should employ sound business, scientific, engineering, and judgment safety when using this recommended practice.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

## Foreword

This recommended practice is intended to provide guidelines for developing effective methods of fireproofing in petroleum and petrochemical processing plants. It is not a design manual. This is a guideline—a starting place and not a prescriptive set of limits; each facility should review their needs and act accordingly. Thus the title is fireproofing “practices”. It seeks to share good practice which has evolved over the years. Participants in developing this third edition included representation from both producers and users of fireproofing.

By its nature fireproofing is passive property protection. Effective protection of equipment in petroleum and petrochemical plants may reasonably be expected to have a benefit in reducing risks. Where fireproofing helps control structural damage and potential incident escalation it may also benefit life safety concerns.

API 2218 is a “pool fire” standard. It uses facility configuration and equipment knowledge as a means of identifying probable liquid fuel release locations and the extent of resulting pool fires. This leads to development of “fire-scenario envelopes”. This is the first step in determining fireproofing needs. The process is shown in simple form in Figure 1.

Planning for (and prevention) of all types of fire is of concern. Although infrequent, jet fires are dramatic and can cause significant damage. Consequently, Annex C provides an overview of “Jet Fire Considerations” including the extensive body of research knowledge.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation for that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

## Contents

	Page
<b>1 Scope</b> .....	<b>1</b>
1.1 Purpose .....	1
1.2 Scope .....	1
1.3 Introduction .....	1
1.4 Units of Measurement .....	1
<b>2 Normative References</b> .....	<b>2</b>
<b>3 Terms and Definitions</b> .....	<b>2</b>
<b>4 General</b> .....	<b>5</b>
4.1 The Function of Fireproofing .....	5
4.2 Determining Fireproofing Needs .....	5
<b>5 Fire Scenario Envelope Fireproofing Considerations</b> .....	<b>16</b>
5.1 Fireproofing Inside Processing Areas .....	16
5.2 Fireproofing Outside Processing Units .....	21
<b>6 Fireproofing Materials</b> .....	<b>26</b>
6.1 General .....	26
6.2 Characteristics of Fireproofing Materials .....	27
6.3 Types of Fireproofing Materials .....	30
<b>7 Testing and Rating Fireproofing Materials</b> .....	<b>35</b>
<b>8 Installation and Quality Assurance</b> .....	<b>35</b>
8.1 General .....	35
8.2 Ease of Application .....	35
8.3 Fireproofing Installation Considerations .....	36
8.4 Quality Control in Application .....	37
<b>9 Inspection and Maintenance</b> .....	<b>37</b>
9.1 Effects of Long-term Exposure .....	37
9.2 Inspection .....	38
9.3 Maintenance .....	38
<b>Annex A (informative) Definition of Terms Used in this Standard which are in General Use in the Petroleum Industry</b> .....	<b>40</b>
<b>Annex B (informative) Testing and Rating Fireproofing Materials</b> .....	<b>42</b>
<b>Annex C (informative) Jet Fire Considerations</b> .....	<b>45</b>
<b>Annex D (informative) Fireproofing Questions and Answers</b> .....	<b>50</b>
<b>Bibliography</b> .....	<b>57</b>

## Figures

1A	Selecting Fireproofing Systems .....	7
1B	Fireproofing Process with MOC .....	8
2A	Example of Effect of Temperature on Strength of Structural Steel .....	16
2B	Heating of Unwetted Steel Plates Exposed to Gasoline Fire on One Side .....	16
3A	Structure Supporting Fire Potential Equipment in a Fire Scenario Area .....	23
3B	Structure Supporting Fire Potential and Non-fire Potential Equipment in a Fire Scenario Area .....	23
3C	Structure Supporting Non-fire Potential Equipment in a Fire Scenario Area .....	23
4A	Pipe Rack without Pumps in a Fire Scenario Area .....	24
4B	Pipe Rack with Large Fire-potential Pumps Installed Below .....	24
4C	Pipe Rack Supporting Fin-Fan Air Coolers in a Fire Scenario Area .....	25
4D	Transfer Line with Hanger Support in a Fire Scenario Area .....	25
4E	Transfer Line Support in a Fire Scenario Area .....	26

## Tables

1	Initial Planning Dimensions for Fire Scenario Envelope .....	13
2	Level of Fireproofing Protection in Pool Fire Scenario Envelope .....	13

# Fireproofing Practices in Petroleum and Petrochemical Processing Plants

## 1 Scope

### 1.1 Purpose

This recommended practice (RP) is intended to provide guidance for selecting, applying, and maintaining fireproofing systems designed to limit the extent of fire-related property loss from pool fires in the petroleum and petrochemical industries. Where comparable hazards exist, and to the extent appropriate, it may be applied to other facilities that could experience similar severe fire exposure and potential losses.

### 1.2 Scope

This RP identifies fireproofing needs for petroleum and petrochemical plants specifically focusing on property loss protection for pool fires scenarios in on-shore processing plants.

Only passive fireproofing systems are within the scope of this recommended practice. The following are outside the scope of this RP; however this RP contains information which may be useful in these applications:

- fireproofing for LPG storage vessels (see API 2510 and API 2510A);
- fireproofing for personnel protection;
- fireproofing for buildings.

### 1.3 Introduction

Properly implemented fireproofing (passive fire protection) can protect against intense and prolonged heat exposure which otherwise could cause collapse of unprotected equipment, leading to the spread of burning liquids and substantial loss of property. Fireproofing may also mitigate concerns for life safety and environmental impact by reducing escalation. Fireproofing and other fire protection measures may be appropriate for fire protection where hazardous chemicals could be released with the potential for exposure of employees or persons outside the facility.

The term “fireproofing” is widely used although strictly speaking the term is misleading since almost nothing can be made totally safe from the effects of fire exposure for an unlimited time. In effect, fireproofing “buys time” for implementation of other protective systems or response plans such as isolation and use of emergency isolation valve/remotely-operated shutoff valve (EIV/ROSOV), unit shutdown, deployment of fire brigades or evacuation.

This RP addresses fireproofing of structural supports in process units and supports for related equipment (such as tanks, utilities and relevant off-site facilities). Fireproofing can also be used to protect instruments, emergency shutoff valves and electrical equipment that may be used to mitigate fire.

### 1.4 Units of Measurement

Values for measurements used in this document are generally provided in both English and SI (metric) units. To avoid implying a greater level of precision than intended, the second cited value may be rounded off to a more appropriate number. Where specific test criteria are involved an exact mathematical conversion is used.