

Classification of Locations for Electrical Installations at Petroleum Facilities Classified as Class I, Division 1, and Division 2

API RECOMMENDED PRACTICE 500
FOURTH EDITION, JUNE 2023



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them. However, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

	Page
1	Scope..... 1
1.1	Purpose..... 1
1.2	Application 1
2	Normative References..... 2
2.1	General..... 2
3	Terms, Definitions, and Acronyms 3
3.1	Terms and Definitions 3
3.2	Acronyms 10
4	Basic Conditions for a Fire or Explosion..... 11
5	Flammable and Combustible Liquids, Gases and Vapors 11
5.1	General 11
5.2	Flammable and Combustible Liquids..... 11
5.3	Flammable Highly Volatile Liquids 12
5.4	Flammable Lighter-than-air Gases 13
5.5	National Electrical Code Grouping of Atmospheric Mixtures 13
6	Classification Criteria..... 14
6.1	General 14
6.2	Classification Criteria and Considerations 15
6.3	Ventilation 18
6.4	Adjacent Areas 22
6.5	Use of Combustible Gas Detection Equipment 23
7	Extent of a Classified Location 24
7.1	General..... 24
7.2	Outdoor Locations 24
7.3	Enclosed Locations Containing Sources of Release..... 25
8	Recommendations for Determining Degree and Extent of Classified Locations—Common Applications 25
8.1	General 25
8.2	Recommendations for Areas Surrounding Specific Equipment 25
9	Recommendations for Determining Degree and Extent of Classified Locations in Petroleum Refineries 43
9.1	Introduction 43
9.2	Recommendations..... 44
10	Recommendations for Determining Degree and Extent of Classified Locations at Drilling Rig and Production Facilities on Land and on Marine Platforms..... 51
10.1	General 51
10.2	Drilling Areas 53
10.3	Production Facilities 53
10.4	Drilling Wells..... 54
10.5	Producing Oil and Gas Wells 63
10.6	Oil and Gas Processing and Storage Equipment 70

Contents

	Page
10.7 Automatic Custody Transfer (ACT) Units.....	73
10.8 Produced, Processed, or Injection Water Handling Equipment.....	73
10.9 Compressor or Pump Handling Flammable Liquids, Gases, or Vapors	76
10.10 Drip Pans	77
10.11 Instruments	78
10.12 Sumps.....	80
10.13 Drains.....	82
10.14 Reserved For Future Use.....	86
10.15 Screwed Connections, Flanges, Valves, and Valve Operators.....	86
10.16 Control Panels Containing Instrumentation Utilizing or Measuring Flammable Liquids or Gases.....	87
10.17 Gas Meters.....	89
11 Recommendations for Determining Degree and Extent of Classified Locations on Mobile Offshore Drilling Units (MODUs).....	90
11.1 General.....	90
11.2 Definitions Specific to MODUs.....	91
11.3 Reserved for Future Use.....	92
11.4 Classified Locations on Mobile Offshore Drilling Units (MODUs).....	92
11.5 Basis for Area Classification.....	94
11.6 Classification of Hazardous (Classified) Locations	95
11.7 Drill Floor and Derrick Areas.....	97
11.8 Substructure or Moonpool Areas	97
11.9 Mud System Processing Equipment Overview	99
11.10 Mud Tanks (After Discharge of Final Degasser)	99
11.11 Mud Ditches or Troughs	103
11.12 Mud Pumps.....	106
11.13 Mud Processing Equipment (Between the Bell Nipple and Mud Discharge of Final Degasser)	106
11.14 Desander or Desilter (Between Mud Discharge of Final Degasser and the Mud Pit).....	106
11.15 Choke Manifold	109
11.16 Cement Unit.....	110
11.17 Degasser.....	110
11.18 Vents	111
11.19 Diverter Line Outlet.....	111
11.20 Blowout Preventer (BOP).....	112
11.21 Well Test Equipment Areas.....	112
11.22 Rooms Used to Store Paint (Paint Lockers)	113
11.23 Battery Rooms.....	113
11.24 Helicopter Fuel Storage Areas	113
11.25 Classification of Adjacent Spaces	113
12 Recommendations for Determining Degree and Extent of Classified Locations at Drilling Rigs and Production Facilities on Floating Production Units.....	114
12.1 General	114
12.2 Floating Production Storage and Offloading Units (FPSOs)	115
12.3 Tension Leg Platforms (TLPs).....	115
12.4 Spars, Caissons, and Similar Units	115
12.5 Classification of Adjacent Spaces	115
13 Recommendations for Determining Degree and Extent of Classified Locations at Petroleum and Gas Pipeline Transportation Facilities.....	120

Contents

	Page
13.1 General	120
13.2 Use of Figures	120
13.3 Figures	120
14 Recommendations for Determining Degree and Extent of Classified Locations at LNG Facilities.....	136
14.1 General.....	136
14.2 Pretreatment Facilities	138
14.3 Refrigeration and Liquefaction	138
14.4 LNG Storage Equipment and Containment.....	142
14.5 Loading/unloading Facilities	144
Annex A (informative) Sample Calculation to Achieve Adequate Ventilation of an Enclosed Area by Natural Means Using Equation (1) and Equation (2)	146
Annex B (informative) Calculation of Minimum Air Introduction Rate to Achieve Adequate Ventilation Using Fugitive Emissions.....	148
Annex C (informative) Development of Ventilation Criteria	151
Annex D (informative) An Alternate Method for Area Classification	153
Annex E (informative) Procedure for Classifying Locations.....	163
Annex F (informative) Preferred Symbols for Denoting Class 1, Division 1, and Division 2 Hazardous (Classified) Locations	166
Annex G (normative) Use of Combustible Gas Detection Equipment.....	167
Bibliography	169
Figures	
1 Increase in Flow Caused by Excess of One Opening Over Another.....	21
2 Non-enclosed or Adequately Ventilated Enclosed Area Adjacent to a Classified Area	23
3 Enclosed Area Adjacent to a Classified Area	23
4 Inadequately Ventilated, Enclosed Area Adjacent to a Classified Area	23
5 Inadequately Ventilated, Enclosed Area Adjacent to a Classified Area	23
6 Fixed-roof Flammable Liquid Storage Tank in a Non-enclosed, Adequately Ventilated Area.....	27
7 Open-top Floating Roof Flammable Liquid Storage Tank in a Non-enclosed, Adequately Ventilated Area.....	28
8 Combustible Liquid Storage Tank in a Non-enclosed, Adequately Ventilated Area	29
9 Tank Car or Tank Truck Loading and Unloading Via Closed System Product Transfer Through Dome Only	30
10 Tank Car or Tank Truck Loading and Unloading via Closed System Product Transfer Through Dome Only	31
11 Tank Car or Tank Truck Loading and Unloading via Closed System Product Transfer Through Bottom Only	31
12 Tank Car or Tank Truck Loading and Unloading via Closed System Product Transfer Through Top or Bottom	32
13 Tank Car or Tank Truck Loading and Unloading via Closed System Product Transfer Through Bottom Only	33
14 Process Equipment Vent in a Non-enclosed, Adequately Ventilated Area	34
15 Instrument or Control Device Vent in a Non-enclosed, Adequately Ventilated Area	34

Contents

	Page
16 Atmospheric Vent from a Division 1 Area	35
17 Atmospheric Vent from a Division 2 Area	35
18 Relief Valve in a Non-enclosed, Adequately Ventilated Area	35
19 Marine Terminal Handling Flammable Liquids	37
20 Adequately Ventilated Process Location With Heavier-than-air Gas or Vapor Source Located Near Grade	44
21 Adequately Ventilated Process Location With Heavier-than-air Gas or Vapor Source Located Above Grade	45
22 Inadequately Ventilated Process Location With Heavier-than-air Gas or Vapor Source	46
23 Adequately Ventilated Compressor Shelter With Lighter-than-air Gas or Vapor Source	47
24 Adequately Ventilated Process Location With Lighter-than-air Gas or Vapor Source	47
25 Inadequately Ventilated Compressor Shelter With Lighter-than-air Gas or Vapor Source	48
26 Inadequately Ventilated Process Location With Lighter-than-air Gas or Vapor Source	49
27 Separators, Dissolved Air Flotation (DAF) Units, and Biological Oxidation (BIOX) Units	50
28 Mechanical Draft Cooling Tower Handling Process Cooling Water	51
29 Drilling Rig, Adequate Ventilation in Substructure, and Derrick is Not Enclosed, But is Equipped With a Windbreak, Open Top, and Open V-Door	55
30 Drilling Rig, Adequate Ventilation in Enclosed Derrick (Open Top) and Inadequately Ventilated Substructure	56
31 Platform Drilling Rig, Adequately Ventilated in Substructure and Inside Derrick, Several Producing Wells Beneath in an Adequately Ventilated Area	58
32 Platform Drilling Rig, Adequate Ventilation in Substructure and Inside Derrick, Several Producing Wells Beneath in an Inadequately Ventilated Location	59
33 Mud Tank in a Non-enclosed, Adequately Ventilated Area	60
34 Mud Tank in an Inadequately Ventilated Area	60
35 Shale Shaker in a Non-enclosed, Adequately Ventilated Area	61
36 Desander or Desilter in a Non-enclosed, Adequately Ventilated Area	61
37 Desander or Desilter in an Adequately Ventilated Enclosed Area	61
38 Degasser Vent in Non-enclosed, Adequately Ventilated Area	62
39 Flowing Well in a Non-enclosed, Adequately Ventilated Area and Without a Cellar or Below-grade Sump	64
40 Flowing Well in a Non-enclosed, Adequately Ventilated Area With an Inadequately Ventilated Cellar or Below-grade Sump	64
41 Flowing Well in an Inadequately Ventilated, Enclosed Area	65
42 Non-enclosed Beam Pumping Well in an Adequately Ventilated Area Without a Cellar	65
43 Non-enclosed Beam Pumping Well in an Adequately Ventilated Area With an Inadequately Ventilated Cellar	66
44 Electric Submersible Pumping Well in a Non-enclosed, Adequately Ventilated Area Without a Cellar	67
45 Electric Submersible Pumping Well in a Non-enclosed, Adequately Ventilated Area With an Inadequately Ventilated Cellar	67
46 Junction Box in a Non-enclosed, Adequately Ventilated Area Connected to an Electric Submersible Pump	68
47 Non-enclosed, Adequately Ventilated Well on Which Wireline Work is Being Performed ...	70
48 Non-carbon Pressure Vessel or Protected Fired Vessel in a Non-enclosed Adequately Ventilated Area	71
49 Ball or Pig Launching or Receiving Installation in a Non-enclosed Adequately Ventilated Area	73
50 Flammable Gas-blanketed and Produced/Processed/Injected Water-handling Equipment [Tank (in lower figure) and Flotation Cell (in upper figure)] in a Non-enclosed, Adequately Ventilated Area	75

Contents

	Page
51 Compressor or Pump in an Adequately Ventilated, Non-enclosed Area	76
52 Compressor or Pump in an Adequately Ventilated, Non-enclosed Area	76
53 Compressor or Pump in an Adequately Ventilated Enclosed Area	77
54a Compressor or Pump in an Inadequately Ventilated, Enclosed Area	78
54b Turbine-driven Compressor or Pump in an Adequately Ventilated, Non-enclosed Area	79
55 Flammable Gas-operated Instruments in an Adequately Ventilated, Enclosed Area with all Devices Vented to the Outside	80
56 Flammable Gas-operated Instruments in an Inadequately Ventilated, Enclosed Area	81
57 Open Sump in Non-enclosed, Adequately Ventilated Area	82
58 Type 1 Open Drain System	83
59 Type 2 Open Drain System	83
60 Type 3 Open Drain System in Non-enclosed Area	84
61 Type 3 Drain System In Enclosed Area	85
62 Type 4 Open Drain System in Non-enclosed Area	85
63 Type 4 Open Drain System in Enclosed Area	86
64 Control Panel With Flammable Gas Vented to the Inside of the Enclosure	88
65 Inadequately Ventilated Control Panel with Instruments Inside	89
66 Adequately Ventilated Control Panel with Instruments Inside	90
67 Drilling Rig Open Derrick	97
68 Drilling Rig Semi-enclosed Derrick	98
69 Drilling Rig Derrick Fully Enclosed (Open Top)	99
70 Drilling Rig Open Substructure and Semi-Enclosed Derrick	100
71 Drilling Rig with Total Containment Substructure and Semi-enclosed Derrick	101
72 Drilling Rig Semi-enclosed Substructure and Semi-enclosed Derrick	102
73 Drilling Rig Enclosed Moonpool and Semi-enclosed Derrick	103
74 Mud System Processing Equipment in Adequately Ventilated, Enclosed Spaces	104
75 Mud System Processing Equipment in Open Spaces	105
76 Mud Tanks in Open Areas	106
77 Open-top Mud Tanks in Enclosed or Semi-Enclosed Locations With Adequate Ventilation	106
78 Closed-top Mud Tanks In Enclosed or Semi-enclosed Locations With Adequate Ventilation	107
79 Open Mud Trough in Open Space Before Degasser	107
80 Open Mud Trough in Enclosed Space With Adequate Ventilation Before Degasser	108
81 Open Mud Trough In Enclosed Space With Adequate Ventilation Downstream of Degasser	108
82 Open Mud Trough in Open Space Downstream of Degasser	108
83 Shale Shaker in Enclosed or Semi-enclosed Space with Adequate Ventilation	109
84 Shale Shaker in Open Area With Adequate Ventilation	109
85 Desander or Desilter in Enclosed or Semi-enclosed Space With Adequate Ventilation	110
86 Desander or Desilter in Open Area	110
87 Discharges or Ventilation Vents and Equipment Vents Originating In Division 1 Areas	111
88 Ventilation Vents Originating in Division 2 Areas	111
89 Diverter Line Outlet	112
90 Typical Floating Production Storage and Offloading Unit (FPSO and FSO)	117
91 Typical Tension Leg Platform (TLP)	118
92 Typical Spar, Caisson, or Similar Unit	119
93 Outdoors—Pump Handling Flammable Liquids or Highly Volatile Liquids	122
94 Adequately Ventilated Building—Pump Handling Flammable Liquids or Highly Volatile Liquids	123
95 Inadequately Ventilated Building—Pump Handling Flammable Liquids or Highly Volatile Liquids	124

Contents

	Page
96	Outdoors—Valves, Screwed Fittings, Flanges, or Similar Devices Handling Flammable Liquids or Highly Volatile Liquids. Also Covers Sampling Systems, Instrumentation, and Instrument-sized Pumps 125
97	Adequately Ventilated Building—Valves, Screwed Fittings, Flanges, or Similar Devices Handling Flammable Liquids or Highly Volatile Liquids. Also Covers Sampling Systems, Instrumentation, and Instrument-sized Pumps 126
98	Inadequately Ventilated Building—Valves, Screwed Fittings, Flanges, or Similar Devices Handling Flammable Liquids or Highly Volatile Liquids. Also Covers Sampling Systems, Instrumentation, and Instrument-sized Pumps 127
99	Elevated Storage Tank or Pressure Vessel 128
100	Below-grade Sump Tank and Oil-water Separator 129
101	Below-grade Vault—Valves, Screwed Fittings, Flanges, or Similar Accessories Handling Flammable Liquids or Highly Volatile Liquids. Also Covers Sampling Systems, Instrumentation, and Instrument-sized Pumps 130
102	Above-grade Source With Closure Handling Flammable Liquid or Highly Volatile Liquids 131
103	Storage Cavern Handling Flammable Liquids and Highly Volatile Liquids 132
104	Outdoors—Compressors, Valves, Screwed Fittings, Flanges, or Similar Devices Handling Lighter-than-air Flammable Gas 132
105	Adequately Ventilated Building—Compressors, Valves, Screwed Fittings, Flanges, or Similar Devices Handling Lighter-than-air Flammable Gas 133
106	Inadequately Ventilated Building—Compressors, Valves, Screwed Fittings, Flanges, or Similar Devices Handling Lighter-than-air Flammable Gas 134
107	Outdoors—Ball or Pig Launching or Receiving Installation Handling Lighter-than-air Flammable Gas 135
108	Outdoors—Storage Cavern Handling Lighter-than-air Flammable Gas 136
109	LNG Facility Process Flow Diagram (typical) 137
110	Refrigerant Storage Tank in a Non-enclosed, Adequately Ventilated Area 139
111	Adequately Ventilated Cryogenic Heat Exchanger 141
112	Pumps Handling LNG in Non-enclosed, Adequately Ventilated Areas 142
113	Above-ground, Single Containment LNG Storage Tank with Secondary Containment Provided by Earthen Dike or Concrete Wall (where $H < x$) 143
114	Above-ground, Single Containment LNG Storage Tank with Secondary Containment Provided by Earthen Dike or Concrete Wall (where $H > x$) 143
115	Above-ground, Full Containment LNG Storage Tank 143
116	Marine Terminal Handling LNG 145
D.1	Vapor Pressure-Temperature Volatility Chart 156
D.2	Volatility Release Probability Matrix for Determining Hazard Radius 158
D.3	Adequately Ventilated Process Area With Heavier-than-air Gas or Vapor Source Located Near or Above Grade 161
F.1	Preferred Symbols for Denoting Class I, Hazardous (Classified) Locations 165

Tables

1	Pressure Adjustment Factor 52
D.1(a)	Pumps Handling Liquids with Heavier-than-air Gases or Vapors Located in Non-enclosed, Adequately Ventilated Process Areas 159
D.1(b)	Pumps Handling Liquids with Heavier-than-air Gases or Vapors Located in Non-enclosed, Adequately Ventilated Process Areas (Metric) 160
D.2	Determining Hazard Radius for Sources With Restrictions for Heavier-than-air Gases or Vapors 160
D.3	Atmospheric Vents and Drains Handling Heavier-than-air Gases or Vapors 160
D.4	Flanges Containing Heavier-than-air Gases or Vapors with a Higher Probability of Leakage 161

Introduction

This recommended practice (RP) is under the jurisdiction of the Committee on Refinery Equipment (CRE). It is based upon a level of knowledge gained through experience and through the successful application of this practice in the refining, drilling and producing, and pipeline segments of the petroleum industry. The first edition of this recommended practice was issued June 1, 1991, under the joint jurisdiction of the API Production, Refining, and Transportation departments. The second edition was issued in November 1997 and reaffirmed in November 2002. The third edition was issued in December 2012.

The first edition of Recommended Practice 500A was published in February 1955 as API 500 *Recommended Practice for Classification of Areas for Electrical Installations in Petroleum Refineries*. The second edition was published in January 1957. The third edition was published as API 500A in April 1966. The third edition was reaffirmed in 1973. The fourth edition was published in January 1982 as API 500A, with a new title, *Classification of Locations for Electrical Installations in Petroleum Refineries*. The fourth edition was reaffirmed in December 1987.

API 500B was originally issued in January 1961 as API 11J, *Recommended Practice for Placement of Electrical Equipment on Production Leases*. The first edition of API 500B was issued in January 1966 with the title *Recommended Practice for Classification in Areas for Electrical Installations at Production Facilities*. The title was changed in the second edition, July 1973, to *Recommended Practice for Classification of Areas for Electrical Installations at Drilling Rigs and Production Facilities on Land and on Marine Fixed and Mobile Platforms*. The third edition of API 500B, *Recommended Practice for Classification of Locations for Electrical Installations at Drilling Rigs and Production Facilities on Land and on Marine Fixed and Mobile Platforms*, was issued October 1, 1987.

The first edition of API 500C was published in September 1976, under the title *Recommended Practice for Classification of Areas for Electrical Installations at Petroleum and Gas Pipeline Transportation Facilities*. The first edition was reaffirmed in 1974. The title was changed in the second edition (July 1984) to *Classification of Locations for Electrical Installations at Pipeline Transportation Facilities*. The second edition was reaffirmed in March 1990.

Classification of Locations for Electrical Installations at Petroleum Facilities Classified as Class I, Division 1 and Division 2

1 Scope

1.1 Purpose

1.1.1 The purpose of this recommended practice is to provide guidelines for classifying locations Class I, Division 1 and Class I, Division 2 at petroleum facilities for the selection and installation of electrical equipment. Basic definitions given in the 2023 edition of NFPA 70, *National Electrical Code (NEC)*, have been followed in developing this recommended practice. This publication is only a guide and requires the application of sound engineering judgment.

NOTE Recommendations for determining the degree and extent of locations classified Class I, Zone 0, Zone 1, and Zone 2 are addressed in API 505, *Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities Classified as Class I, Zone 0, Zone 1, and Zone 2*.

1.1.2 Electrical installations in areas where flammable liquids, flammable gases or vapors, or combustible liquids are produced, processed, stored, or otherwise handled can be suitably designed if the locations of potential sources of release and accumulation are clearly defined. Once a location has been classified, requirements for electrical equipment and associated wiring should be determined from applicable publications. Applicable publications may include NFPA 70 (NEC), CSA C22.1 (Canadian Electrical Code), or API 14F.

NOTE Recommendations for electrical installations for locations classified Class I, Zone 0, Zone 1, and Zone 2 are addressed in API 14FZ, *Recommended Practice for Design, Installation, and Maintenance of Electrical Systems for Fixed and Floating Offshore Petroleum Facilities for Unclassified and Class I, Zone 0, Zone 1, and Zone 2 Locations*.

1.2 Application

1.2.1 This RP applies to the classification of locations for both temporarily and permanently installed electrical equipment. It is intended to be applied where there may be a risk of ignition due to the presence of flammable gases, flammable liquid-produced vapors, or combustible liquid-produced vapors, mixed with air, under normal atmospheric conditions. Normal atmospheric conditions are defined as conditions that vary above and below reference levels of 101.3 kPa (14.7 psia) and 20 °C (68 °F), provided that the variations have a negligible effect on the explosion properties of the flammable materials.

The following items are beyond the scope of this RP:

- a) piping systems used for odorized natural gas used as fuel for cooking, heating, air conditioning, laundry, and similar appliances;
- b) catastrophes such as well blowouts or process vessel ruptures (such extreme events are not predictable and require emergency measures at the time of occurrence);
- c) suitability of locations for the placement of non-electrical incendiary equipment;
- d) classification of locations containing combustible dust, ignitable fibers, or flyings;
- e) installations underground in mines;