

# Sizing, Selection, and Installation of Pressure-Relieving Devices in Refineries

## Part I—Sizing and Selection

API RECOMMENDED PRACTICE 520  
SEVENTH EDITION, JANUARY 2000



American  
Petroleum  
Institute

**Helping You  
Get The Job  
Done Right.<sup>SM</sup>**



## **API ENVIRONMENTAL, HEALTH AND SAFETY MISSION AND GUIDING PRINCIPLES**

The members of the American Petroleum Institute are dedicated to continuous efforts to improve the compatibility of our operations with the environment while economically developing energy resources and supplying high quality products and services to consumers. We recognize our responsibility to work with the public, the government, and others to develop and to use natural resources in an environmentally sound manner while protecting the health and safety of our employees and the public. To meet these responsibilities, API members pledge to manage our businesses according to the following principles using sound science to prioritize risks and to implement cost-effective management practices:

- To recognize and to respond to community concerns about our raw materials, products and operations.
- To operate our plants and facilities, and to handle our raw materials and products in a manner that protects the environment, and the safety and health of our employees and the public.
- To make safety, health and environmental considerations a priority in our planning, and our development of new products and processes.
- To advise promptly, appropriate officials, employees, customers and the public of information on significant industry-related safety, health and environmental hazards, and to recommend protective measures.
- To counsel customers, transporters and others in the safe use, transportation and disposal of our raw materials, products and waste materials.
- To economically develop and produce natural resources and to conserve those resources by using energy efficiently.
- To extend knowledge by conducting or supporting research on the safety, health and environmental effects of our raw materials, products, processes and waste materials.
- To commit to reduce overall emissions and waste generation.
- To work with others to resolve problems created by handling and disposal of hazardous substances from our operations.
- To participate with government and others in creating responsible laws, regulations and standards to safeguard the community, workplace and environment.
- To promote these principles and practices by sharing experiences and offering assistance to others who produce, handle, use, transport or dispose of similar raw materials, petroleum products and wastes.

# Sizing, Selection, and Installation of Pressure-Relieving Devices in Refineries

## Part I—Sizing and Selection

Downstream Segment

API RECOMMENDED PRACTICE 520  
SEVENTH EDITION, JANUARY 2000



American  
Petroleum  
Institute

**Helping You  
Get The Job  
Done Right.<sup>SM</sup>**

## SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication, unless as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Downstream Segment Telephone (202) 682-8000]. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the general manager of the Downstream Segment, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the general manager.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

*All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.*

## FOREWORD

API Recommended Practice 520, *Sizing, Selection, and Installation of Pressure-Relieving Devices in Refineries*, is the result of several years' work by engineers in the petroleum industry.

The information in this recommended practice is intended to supplement the information contained in Section VIII, "Pressure Vessels," of the ASME *Boiler and Pressure Vessel Code*. The recommendations presented in this publication are not intended to supersede applicable laws and regulations.

Users of this recommended practice are reminded that no publication of this type can be complete, nor can any written document be substituted for qualified engineering analysis.

The current edition of this recommended practice, published in two parts, has been updated with respect to the practices generally used in the installation of all devices covered in the previous editions; the current edition also contains additional information based on revisions suggested by many individuals and several organizations.

The first edition of this recommended practice was issued in 1955. The second edition was published in two parts: Part I, "Design," in 1960 and Part II, "Installation," in 1963. The third edition of Part I was issued in November 1967 and reaffirmed in 1973. The fourth edition was issued in December 1976, the fifth edition was issued in July 1990, and the sixth edition was issued in March 1993.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to the general manager of the Downstream Segment, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005.

Currently in preview, click buy full version

## CONTENTS

	Page
1 INTRODUCTION . . . . .	1
1.1 Scope . . . . .	1
1.2 Definition of Terms . . . . .	1
1.3 Referenced Publications . . . . .	4
2 PRESSURE RELIEF DEVICES . . . . .	5
2.1 General . . . . .	5
2.2 Pressure Relief Valves . . . . .	5
2.3 Rupture Disk Devices . . . . .	16
2.4 Pin-Actuated Devices . . . . .	8
2.5 Other Types of Devices . . . . .	30
3 PROCEDURES FOR SIZING . . . . .	30
3.1 Determination of Relief Requirements . . . . .	30
3.2 API Effective Area and Effective Coefficient of Discharge . . . . .	32
3.3 Back Pressure . . . . .	34
3.4 Cold Differential Test Pressure (CDTP) . . . . .	38
3.5 Relieving Pressure . . . . .	39
3.6 Sizing for Gas or Vapor Relief . . . . .	41
3.7 Sizing for Steam Relief . . . . .	50
3.8 Sizing for Liquid Relief: Pressure Relief Valves Requiring Capacity Certification . . . . .	52
3.9 Sizing for Liquid Relief: Pressure Relief Valves Not Requiring Capacity Certification . . . . .	53
3.10 Sizing for Two-Phase Liquid/Vapor Relief . . . . .	55
3.11 Sizing for Rupture Disk Devices . . . . .	55
4 REFERENCES . . . . .	56
APPENDIX A RUPTURE DISK DEVICE SPECIFICATION SHEET . . . . .	57
APPENDIX B REVIEW OF FLOW EQUATIONS USED IN SIZING PRESSURE RELIEF VALVES FOR GAS OR VAPOR . . . . .	61
APPENDIX C PRESSURE RELIEF VALVE SPECIFICATION SHEETS . . . . .	63
APPENDIX D SIZING FOR TWO-PHASE LIQUID/VAPOR RELIEF . . . . .	69
APPENDIX E CAPACITY EVALUATION OF RUPTURE DISK AND PIPING SYSTEM 100% VAPOR FLOW AND CONSTANT PIPE DIAMETER . . . . .	83

### Figures

1 Pressure-Level Relationships for Pressure Relief Valves . . . . .	3
2 Conventional Pressure Relief Valve with a Single Adjusting Ring for Blowdown Control . . . . .	6
3 Balanced-Bellows Pressure Relief Valve . . . . .	7
4 Balanced-Bellows Pressure Relief Valve with an Auxiliary Balanced Piston . . . . .	9
5 Conventional Pressure Relief Valve with Threaded Connections . . . . .	10
6 Pop-Action Pilot-Operated Valve (Flowing-Type) . . . . .	11
7 Pop-Action Pilot-Operated Valve (Nonflowing-Type) . . . . .	12

8	Modulating Pilot-Operated Valve (Flowing-Type) . . . . .	13
9	Pilot-Operated Relief Valve with a Nonflowing Modulating Pilot Valve . . . . .	14
10	Low-Pressure Pilot-Operated Valve (Diaphragm-Type) . . . . .	15
11	Forward-Acting Solid Metal Rupture Disk . . . . .	17
12	Forward-Acting Scored Rupture Disk . . . . .	19
13	Forward-Acting Composite Rupture Disk . . . . .	20
14	Reverse-Acting Rupture Disk with Knife Blades . . . . .	22
15	Reverse-Acting Scored Rupture Disk . . . . .	23
16	Graphite Rupture Disk . . . . .	24
17	Rupture Disk Device in Combination with a Pressure Relief Valve . . . . .	25
18	Buckling Pin Valve . . . . .	26
19	Pressure Relief Valve Operation—Vapor/Gas Service . . . . .	27
20	Typical Relationship Between Lift of Disk in a Pressure Relief Valve and Vessel Pressure . . . . .	28
21	Pressure Relief Valve Operation—Liquid Service . . . . .	28
22	Typical Effects of Superimposed Back Pressure on the Opening Pressure of Conventional Pressure Relief Valves . . . . .	29
23	Typical Effects of Back Pressure on the Set Pressure of Balanced Pressure Relief Valves . . . . .	29
24	Typical Relationship Between Lift of Disk or Piston and Vessel Pressure in a Pop-Action Pilot-Operated Pressure Relief Valve . . . . .	30
25	Typical Relationship Between Lift of Disk or Piston and Vessel Pressure in a Modulating-Action Pilot-Operated Pressure Relief Valve . . . . .	30
26	Pressure-Level Relationships for Rupture Disk Devices . . . . .	31
27	Common Types of Manufacturing Ranges and Corresponding Burst Pressure Marking . . . . .	32
28	Rupture Disk Application Parameters . . . . .	33
29	Rupture Disk Application Parameters . . . . .	35
30	Back Pressure Correction Factor, $K_b$ , for Balanced-Bellows Pressure Relief Valve (Vapors and Gases) . . . . .	37
31	Capacity Correction Factor, $K_w$ , Due to Back Pressure on Balanced-Bellows Pressure Relief Valves in Liquid Service . . . . .	38
32	Curve for Evaluating Coefficient $C$ in the Flow Equation from the Specific Heat Ratio, assuming Ideal Gas Behavior . . . . .	44
33	Sample of Completed Pressure Relief Valve Specification Sheet . . . . .	46
34	Values of $F_2$ for Subcritical Flow . . . . .	48
35	Constant Back Pressure Correction Factor, $K_b$ , for Conventional Pressure Relief Valves (Vapors and Gases Only) . . . . .	49
36	Capacity Correction Factor, $K_v$ , Due to Viscosity . . . . .	54
37	Capacity Correction Factors Due to Overpressure for Noncertified Pressure Relief Valves in Liquid Service . . . . .	55
A-1	Rupture Disk Device Specification Sheet . . . . .	60
C-1	Spring-Loaded Pressure Relief Valve Specification Sheet . . . . .	65
C-2	Pilot-Operated Pressure Relief Valve Specification Sheet . . . . .	68
D-1	Correlation for Nozzle Critical Flow of Flashing and Nonflashing Systems . . . . .	78
D-2	Back Pressure Correction Factor, $K_b$ , for Balanced-Bellows Pressure Relief Valves (Vapors and Gases) . . . . .	79
D-3	Correlation for Nozzle Critical Flow of Inlet Subcooled Liquids . . . . .	80
D-4	Back Pressure Correction Factor, $K_b$ , for Balanced-Bellows Pressure Relief Valves (Liquids) . . . . .	81
E-1	Pressure Relief System for Example Problem . . . . .	84
E-2	Curve Fit for $C_p/C_v = 1.4$ (Crane Figure A-22) . . . . .	85

## Tables

1	Set Pressure and Accumulation Limits for Pressure Relief Valves . . . . .	39
2	Example Determination of Relieving Pressure for a Single-Valve Installation (Operating Contingencies) . . . . .	40
3	Example Determination of Relieving Pressure for a Multiple-Valve Installation (Operating Contingencies) . . . . .	40
4	Example Determination of Relieving Pressure for a Single-Valve Installation (Fire Contingencies) . . . . .	41
5	Example Determination of Relieving Pressure for a Multiple-Valve Installation (Fire Contingencies) . . . . .	41
6	Example Determination of Relieving Pressure for a Supplemental-Valve Installation (Fire Contingencies) . . . . .	41
7	Properties of Gases . . . . .	43
8	Values of Coefficient $C$ . . . . .	50
9	Superheat Correction Factors, $K_{SH}$ . . . . .	51
D-1	Two-Phase Liquid/Vapor Relief Scenarios for Pressure Relief Valves . . . . .	69

Currently in preview, click buy full version

# Sizing, Selection, and Installation of Pressure-Relieving Devices in Refineries

## Part I—Sizing and Selection

### 1 Introduction

#### 1.1 SCOPE

This recommended practice applies to the sizing and selection of pressure relief devices used in refineries and related industries for equipment that has a maximum allowable working pressure of 15 psig [103 kPag] or greater. The pressure relief devices covered in this recommended practice are intended to protect unfired pressure vessels and related equipment against overpressure from operating and fire contingencies.

This recommended practice includes basic definitions and information about the operational characteristics and applications of various pressure relief devices. It also includes sizing procedures and methods based on steady state flow of Newtonian fluids.

Pressure relief devices protect a vessel against overpressure only; they do not protect against structural failure when the vessel is exposed to extremely high temperatures such as during a fire. See API Recommended Practice 521 for information about appropriate ways of reducing pressure and restricting heat input.

Atmospheric and low pressure storage tanks covered in API Standard 2000 and pressure vessels used for the transportation of products in bulk or shipping containers are not within the scope of this recommended practice.

The rules for overpressure protection of fired vessels are provided in Section I of the ASME *Boiler and Pressure Vessel Code* and ASME B31.1, and are not within the scope of this recommended practice.

#### 1.2 DEFINITION OF TERMS

Terms used in this recommended practice relating to pressure relief devices and their dimensional and operational characteristics are defined in 1.2.1 through 1.2.3. The terms are covered more specifically in the applicable sections of text and accompanying illustrations.

##### 1.2.1 Pressure Relief Devices

**1.2.1.1 pressure relief device:** Actuated by inlet static pressure and designed to open during emergency or abnormal conditions to prevent a rise of internal fluid pressure in excess of a specified design value. The device also may be designed to prevent excessive internal vacuum. The device may be a pressure relief valve, a non-reclosing pressure relief device, or a vacuum relief valve.

**1.2.1.2 pressure relief valve:** A pressure relief device designed to open and relieve excess pressure and to reclose and prevent the further flow of fluid after normal conditions have been restored.

a. A *relief valve* is a spring loaded pressure relief valve actuated by the static pressure upstream of the valve. The valve opens normally in proportion to the pressure increase over the opening pressure. A relief valve is used primarily with incompressible fluids.

b. A *safety valve* is a spring loaded pressure relief valve actuated by the static pressure upstream of the valve and characterized by rapid opening or pop action. A safety valve is normally used with compressible fluids.

c. A *safety relief valve* is a spring loaded pressure relief valve that may be used as either a safety or relief valve depending on the application.

d. A *conventional pressure relief valve* is a spring loaded pressure relief valve whose operational characteristics are directly affected by changes in the back pressure.

e. A *balanced pressure relief valve* is a spring loaded pressure relief valve that incorporates a bellows or other means for minimizing the effect of back pressure on the operational characteristics of the valve

f. A *pilot operated pressure relief valve* is a pressure relief valve in which the major relieving device or main valve is combined with and controlled by a self actuated auxiliary pressure relief valve (pilot).

**1.2.1.3 non-reclosing pressure relief device:** A pressure relief device which remains open after operation. A manual resetting means may be provided.

**1.2.1.4 rupture disk device:** A non-reclosing pressure relief device actuated by static differential pressure between the inlet and outlet of the device and designed to function by the bursting of a rupture disk. A rupture disk device includes a rupture disk and a rupture disk holder.

a. A *rupture disk* is a pressure containing, pressure and temperature sensitive element of a rupture disk device.

b. A *rupture disk holder* is the structure which encloses and clamps the rupture disk in position. (Some disks are designed to be installed between standard flanges without holders.)

c. A *nonfragmenting rupture disk* is a rupture disk designed and manufactured to be installed upstream of other piping components, such as pressure relief valves, and will not impair the function of those components when the disk ruptures.