

# Process Control Systems— Functions and Functional Specification Development

API RECOMMENDED PRACTICE 554, PART 1  
THIRD EDITION, MAY 2021



American  
Petroleum  
Institute

## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Users of this recommended practice should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

## Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, [standards@api.org](mailto:standards@api.org).

## Contents

	Page
<b>1</b> Scope.....	1
<b>1.1</b> General.....	1
<b>1.2</b> Document Organization.....	2
<b>2</b> Normative References.....	4
<b>3</b> Terms and Definitions.....	4
<b>4</b> Process Control System Planning and Conceptual Design Basis.....	9
<b>4.1</b> General.....	9
<b>4.2</b> Business Drivers.....	9
<b>4.3</b> Process Control System Conceptual Design Basis.....	9
<b>4.4</b> Input Requirements.....	10
<b>4.5</b> Conceptual Design Assessment.....	17
<b>5</b> Process Control Functional Specification.....	17
<b>5.1</b> General.....	17
<b>5.2</b> Scope Definition Input.....	17
<b>5.3</b> Process Control System Functional Requirements.....	18
<b>5.4</b> Process Control System Physical Requirements.....	18
<b>5.5</b> Technology Selection.....	19
<b>5.6</b> Execution Plan.....	20
<b>5.7</b> Ownership and Operation Plan.....	20
<b>6</b> General Functions of Process Control Systems.....	21
<b>6.1</b> Introduction.....	21
<b>6.2</b> Sensing and Actuation.....	22
<b>6.3</b> Signal Transmission.....	22
<b>6.4</b> Basic Control Functions.....	24
<b>6.5</b> Advanced Control Functions.....	27
<b>6.6</b> Safety, Protective, and Process Interlock Systems.....	27
<b>6.7</b> Control Systems Digital Communication Functions.....	28
<b>6.8</b> Human Machine Interface.....	29
<b>6.9</b> Alarming.....	31
<b>6.10</b> History.....	32
<b>6.11</b> Reporting and Logging.....	34
<b>6.12</b> System Management Tools.....	34
<b>6.13</b> Database Management.....	35
<b>6.14</b> Security.....	37
Bibliography.....	42
<b>Figure</b>	
<b>1</b> Refinery Control and Automation Functions.....	1
<b>2</b> Process Control Systems Functions.....	21
<b>3</b> Process Control System Data.....	35

## Contents

	Page
<b>Tables</b>	
1 Process Control Systems Life Cycle Overview.....	3
2 Device Diagnostic Functions .....	23
3 Continuous Control Functions .....	24
4 Auxiliary Control Functions.....	25
5 Logic Functions.....	26
6 Human Machine Interface (HMI) Displays .....	29

## Introduction

Advances in computing and digital communications technologies since the preparation of the first edition of API 554 have had major impacts on the way instrumentation and control systems function as compared with historical designs. The advances have also radically changed the way that the design and specification of such systems must be approached and have created major issues relative to system design and system security. These issues are as follows.

- The repurposing and relocation of central control room.
- Advances in computing power, software standards, and communications standards have resulted in many of the functions historically implemented in stand-alone process control and historization computers being integrated within the process control systems (PCSs). This has greatly expanded the scope of PCS design and blurred the division between real time control and historization functions and higher-level information systems that provide input to business and maintenance systems. The control systems engineer is challenged to maintain a design that allows communications between the control and the business networks but that also maintains safe and reliable operations.
- Advances in field instrumentation design leading to the general use of smart digital field instrumentation. Further advances in field bus and related technologies allow these smart instruments to communicate directly with the PCSs or with each other. These instruments not only transfer information about the basic process measurement but also communicate diagnostic information about the health of the device or other secondary information derived from the primary measurements. The smart devices enable very real, albeit basic, “distributed control” across the various real-time devices within the control domain. The degree of such distributed control shall be considered, if it’s within the corporate policy.
- Further developments in standardization of operating systems and software practices have enabled use of standard computer components and peripherals operating on standard operating systems. This has resulted in a developing trend away from control systems applications being implemented on proprietary hardware and software systems, and instead being implemented on standard personal computer, workstation, and network communication products running widely available operating systems.
- This standardization has reduced the cost and increased the flexibility of the systems. It has also resulted in greater exposure of the PCS to external interference and requires additional support to keep the operating systems current and secure. Security and virus protection are major concerns of newer PCSs and must be addressed at both the design and operational phases.
- The integration of the human machine interface and communication networks for the PCS and the safety instrumented system (SIS).
- The addition of “wireless process networks” is bringing new challenges and it is transforming the way the information generated in the field sensors is transmitted and the way the facilities are designed.

The result of all these technical advances is that PCSs are no longer entirely based upon proprietary closed hardware and software systems offered by a single vendor. While these implementations are still available and form the preponderance of the existing installed base, there is a very strong trend away from closed systems provided by one vendor, to more open systems based upon industry standard hardware and software which have both proprietary and open system components.

These trends result in a far greater flexibility in selection of the control functions and the control hardware.

These trends place greater responsibility upon the design engineer and user to understand the interaction between PCSs and the business functions of an organization: to select and specify the functions that are necessary for a given application; and to implement those functions in a safe, reliable, cost effective, and maintainable manner.

API 554 consists of three documents to better define the processes required to properly scope, specify, select, install, commission, operate, and maintain PCSs. This recommended practice is not intended to be used as a purchase specification, but recommendations are made for minimum requirements that can be used as a specification basis.

Currently in preview, click buy full version

# Process Control Systems— Functions and Functional Specification Development

## 1 Scope

### 1.1 General


This recommended practice (RP) addresses the processes required to successfully implement process control systems (PCSs) for oil and gas production, refinery, and petrochemical services. The major topics addressed are listed below.

- *Part 1.* The basic functions that a PCS may need to perform, and recommended methodologies for determining the functional and integration requirements for a particular application.
- *Part 2.* The practices to select and design the installation for hardware and software required to meet the functional and integration requirements.
- *Part 3.* The project organization, skills, and management required to execute a process control project and then to own and operate a PCS.

Figure 1 shows the general overall scope of oil and gas production, refinery process control, and the associated automation functions, as well as the portions of which this recommended practice addresses.

The general scope of the material covers general industrial process control topics that are applicable to oil and gas production, refineries, and petrochemical facilities.

The user is cautioned to fully consider the requirements of the particular applications and circumstances that may exist and carefully apply the concepts described in this RP as appropriate. This document is not intended to present a tutorial on the subjects discussed, but rather to aid the reader in identifying and understanding the basic concepts of PCSs. The references provided within the document direct the reader to publications that describe one or more subjects in greater detail than is necessary or desirable for the purposes of this document.



**Figure 1—Refinery Control and Automation Functions**