

Inspection Practices for Atmospheric and Low-pressure Storage Tanks

API RECOMMENDED PRACTICE 575
FOURTH EDITION, JULY 2020



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

	Page
1 Scope	1
2 Normative References	1
2.1 Codes, Standards, and Related Publications	1
2.2 Other References	1
3 Terms and Definitions	4
4 Types of Storage Tanks	9
4.1 General	9
4.2 Atmospheric Storage Tanks	10
4.3 Low-pressure Storage Tanks	23
5 Reasons for Inspection and Causes of Deterioration	28
5.1 Reasons for Inspection	28
5.2 Deterioration of Tanks	29
5.3 Deterioration of Other than Flat Bottom and Non-steel Tanks	31
5.4 Leaks, Cracks, and Mechanical Deterioration	32
5.5 Deterioration and Failure of Auxiliary Equipment	35
6 Inspection Plans	36
6.1 General	36
6.2 Inspections Planning and Reports	37
6.3 RBI Plans	39
7 Interval/Frequency and Extent of Inspection	40
7.1 Interval of Inspection	40
7.2 Condition-based Inspection Scheduling	41
7.3 Inspection Scheduling Based on Minimum Acceptable Thickness	41
7.4 Similar Service Methodology for Estimating Tank Corrosion Rates	43
7.5 Fitness-For-Service Evaluation	45
8 Inspections	45
8.1 Preparation for Inspections	45
8.2 External Inspection of an In-service Tank	48
8.3 External Inspection of Out-of-service Tanks	62
8.4 Internal Inspection	66
8.5 Hydrostatic and Pneumatic Testing of Tanks	79
8.6 Inspection Checklists	80
9 Leak Testing and Hydraulic Integrity of the Bottom	80
9.1 General	80
9.2 Leak Integrity Methods Available During Out-of-service Periods	82
9.3 Leak Detection Methods Available During In-service Periods	86
10 Integrity of Repairs and Alterations	90
10.1 General	90
10.2 Repairs	90
10.3 Special Repair Methods	93
11 Records	95
11.1 General	95
11.2 Records and Reports	95
11.3 Form and Organization	97

Contents

	Page
Annex A (informative) Selected NDE Methods	98
Annex B (informative) Similar Service Evaluation Tables	13
Bibliography	106
Figures	
1 Cone Roof Tank	11
2 Umbrella Roof Tank	12
3 Self-supporting Aluminum (Geodesic) Dome Roof Tank	12
4 Self-supporting Dome Roof Tank	13
5 Externally Stiffened Pan-type Floating-roof Tank	13
6 Annular-pontoon Floating-roof Tank	14
7 Double-deck Floating-roof Tank	14
8 Cross-section Sketches of Floating-roof Tanks Showing the Most Important Features	15
9 Floating-roof Shoe Seal	16
10 Floating-roof Log Seal	16
11 Floating Roof Using Counterweights to Maintain Seal	17
12 Floating Roof Using Resilient Tube-type Seal	17
13 Typical Arrangement for Metallic Float Internal Floating-roof Seals	18
14 Typical Internal Floating-roof Components	19
15 Cable-supported Internal Floating-roof Tank	19
16 Plain Breather Roof Tanks	21
17 Tank with Vapor Dome Roof	22
18 Balloon Roof Tank	22
19 Cutaway View of Vapor Dome Roof	23
20 Plain Hemispheroids	24
21 Noded Hemispheroid	25
22 Drawing of Hemispheroid	25
23 Plain Spheroid	26
24 Plain Hemispheroid with Knuckle Radius	26
25 Noded Spheroid	27
26 Drawing of Noded Spheroid	27
27 Foundation Seal	30
28 Cracks in Tank Shell Plate	33
29 Extensive Destruction from Instantaneous Failure	34
30 Cracks in Bottom Plate Welds Near the Shell-to-bottom Joint	34
31 Cracks in Tank at Riveted Lap Joint to Tank Shell	35
32 Failure of Concrete Ringwall	49
33 Anchor Bolt	50
34 Corrosion of Anchor Bolts	50
35 Corrosion Under Insulation	51
36 Close-up of Corrosion Under Insulation	52
37 Corrosion (External) at Grade	53
38 Caustic Stress Corrosion Cracks	55
39 Small Hydrogen Blisters on Shell Interior	56
40 Large Hydrogen Blisters on Shell Interior	56
41 Tank Failure Caused by Inadequate/Obstructed Vacuum Venting	58
42 Roof Overpressure	59
43 Example of Severe Corrosion of Tank Roof	64

Contents

Page

44	Collapse of Pan-type Roof from Excessive Weight of Water While the Roof Was Resting on Its Supports	65
45	Pontoon Floating-roof Failure	67
46a	Rolling Scaffold Used for Inspection and Repairs Inside of Tank	67
46b	Tank Buggy Used for Inspection and Repairs on Exterior of Tank	67
47	Remote Control Automated Crawler	68
48	Example of Vapor-Liquid Line Corrosion	70
49	Corrosion Behind Floating-roof Seal	70
50	Localized Corrosion-erosion at Riveted Seam in a Tank Bottom.	73
51	Example of Extensive Corrosion of a Tank Bottom.	73
52	Shell-to-bottom Weld Corrosion	74
53	External View of Erosion-corrosion Completely Penetrating a Tank Shell	75
54	Internal Corrosion on Rafters and Roof Plates	77
55	Failure of Roof Supports	77
56	Fin-tube Type of Heaters Commonly Used in Storage Tanks.	78
57	Example of Corrosion of Steam Heating Coil.	78
58	Hydraulic Integrity Test Procedures	81
59	Vacuum Box Used to Test for Leaks.	83
60	Vacuum Box Arrangement for Detection of Leaks in Vacuum Seals.	84
61	Helium Tester	85
62	Method of Repairing Tank Bottoms.	92
63	Temporary “Soft Patch” Over Leak in Tank Roof	94
64	Mastic Roof Coating	94
65	Tank Jacked Up for Repairing Pad	95
A.1	Automatic Ultrasonic Testing	100
A.2	MFL Scanner	100
A.3	Ultrasonic Examination	101
A.4	Guided Wave Ultrasonic Testing	101
A.5	Robotic Inspection Tool	102
Tables		
1	Tools for Tank Inspection	46
2	Useful Supplemental Tools	47
B.1	Selected Considerations for Performing Similar Service Assessments	103
B.2	Similar Service Examples for Product-side Corrosion	105

Inspection Practices for Atmospheric and Low-pressure Storage Tanks

1 Scope

This document provides useful information and recommended practices for the maintenance and inspection of atmospheric and low-pressure storage tanks. While these maintenance and inspection guidelines may apply to other types of tanks, these practices are intended primarily for existing tanks that were constructed to one of the following four standards: API Std 12A, API Spec 12C, API Std 620, or API Std 650. This document addresses the following:

- a) descriptions and illustrations of the various types of storage tanks;
- b) new tank construction standards;
- c) maintenance practices;
- d) reasons for inspection;
- e) causes of deterioration;
- f) frequency of inspection;
- g) methods of inspection;
- h) inspection of repairs;
- i) preparation of records and reports;
- j) safe and efficient operation;
- k) leak prevention methods.

This recommended practice is intended to supplement API Std 653, which provides minimum requirements for maintaining the integrity of storage tanks after they have been placed in service.

2 Normative References

2.1 Codes, Standards and Related Publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Standard 653, *Tank Inspection, Repair, Alteration, and Reconstruction*

2.2 Other References

The following codes and standards are cited in the text of this recommended practice or included in the knowledge base to develop this document. Familiarity with these documents is suggested as they provide additional information pertaining to the inspection and repair of aboveground storage tanks.

API Standard 12A, *Specification for Oil Storage Tanks with Riveted Shells* (withdrawn)

API Specification 12B, *Specification for Bolted Tanks for Storage of Production Liquids*