

# Inspection Practices for Atmospheric and Low-pressure Storage Tanks

API RECOMMENDED PRACTICE 575  
FIFTH EDITION, SEPTEMBER 2024



American  
Petroleum  
Institute

## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

Users of this Recommended Practice should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

*Copyright © 2024 American Petroleum Institute*

## Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, [standards@api.org](mailto:standards@api.org).

## Contents

1	Scope.....	1
2	Normative References .....	1
2.1	Codes, Standards, and Related Publications.....	1
2.2	Other References .....	1
3	Terms, Definitions, Acronyms, and Abbreviations .....	4
3.1	Terms and Definitions .....	4
3.2	Acronyms and Abbreviations .....	4
4	Types of Storage Tanks.....	9
4.1	General.....	9
4.2	Atmospheric Storage Tanks .....	10
4.3	Low-pressure Storage Tanks.....	21
5	Reasons for Inspection and Causes of Deterioration .....	23
5.1	Reasons for Inspection .....	23
5.2	Deterioration of Tanks .....	24
5.3	Leaks, Cracks, and Mechanical Deterioration .....	26
5.4	Deterioration and Failure of Auxiliary Equipment .....	29
6	Inspection Plans.....	30
6.1	General.....	30
6.2	Inspection Planning and Reports.....	31
6.3	Risk-based Inspection Plans .....	32
7	Interval/Frequency and Extent of Inspection .....	33
7.1	Interval of Inspection.....	33
7.2	Condition-based Inspection Scheduling .....	34
7.3	Inspection Scheduling Based on Minimum Acceptable Thickness .....	35
7.4	Similar Service Methodology for Establishing Tank Corrosion Rates.....	37
7.5	Fitness-For-Service Evaluation .....	39
8	Inspections .....	39
8.1	Inspection Procedure .....	39
8.2	Preparation for Inspections.....	39
8.3	External Inspection of an In-service Tank.....	43
8.4	External Inspection of Out-of-service Tanks .....	58
8.5	Internal Inspection.....	62
8.6	Hydrostatic and Pneumatic Testing of Tanks.....	74
8.7	Inspection Checklists .....	75
9	Leak Testing and Integrity of the Bottom.....	75
9.1	General.....	75
9.2	Leak Detection Methods Available During In-service Periods.....	81
10	Integrity of Repairs and Alterations .....	84
10.1	General.....	84
10.2	Repairs .....	85
10.3	Special Repair Methods.....	88
11	Records.....	90
11.1	General.....	90
11.2	Records and Reports.....	90
11.3	Form and Organization.....	91
	<b>Annex A (informative) Selected Nondestructive Examination Methods.....</b>	<b>92</b>
	<b>Annex B (informative) Similar Service Evaluation Tables.....</b>	<b>97</b>

<b>Annex C (informative, normative if used) Less Common Tank and Roof Designs</b> .....	<b>100</b>
---	------------

<b>Bibliography</b> .....	<b>108</b>
---------------------------	------------

## Figures

<b>1</b>	<b>Fixed Cone Roof Tank</b> .....	<b>11</b>
<b>2</b>	<b>Self-supporting Dome Roof Tank</b> .....	<b>12</b>
<b>3</b>	<b>Umbrella Roof Tank</b> .....	<b>12</b>
<b>4</b>	<b>Self-supporting Aluminum (Geodesic) Dome Roof Tank</b> .....	<b>13</b>
<b>5</b>	<b>Externally Stiffened Pan-type Floating-roof Tank</b> .....	<b>13</b>
<b>6</b>	<b>Annular-pontoon Floating-roof Tank</b> .....	<b>14</b>
<b>7</b>	<b>Double-deck Floating-roof Tank</b> .....	<b>14</b>
<b>8</b>	<b>Cross-section Sketches of External Floating-roof Tanks Showing the Most Important Features</b> .....	<b>16</b>
<b>9</b>	<b>Floating-roof Shoe Seal</b> .....	<b>17</b>
<b>10</b>	<b>Floating-roof Log Seal</b> .....	<b>17</b>
<b>11</b>	<b>Floating Roof Using Counterweights to Maintain Seal</b> .....	<b>18</b>
<b>12</b>	<b>Floating Roof Using Resilient Tube-type Seal</b> .....	<b>18</b>
<b>13</b>	<b>Typical Arrangement for Metallic Float Internal Floating-roof Seals</b> .....	<b>19</b>
<b>14</b>	<b>Typical Internal Floating-roof Components</b> .....	<b>20</b>
<b>15</b>	<b>Cable-supported Internal Floating-roof Tank</b> .....	<b>20</b>
<b>16</b>	<b>Cracks in Tank Shell Plate</b> .....	<b>27</b>
<b>17</b>	<b>Extensive Destruction from Instantaneous Failure</b> .....	<b>27</b>
<b>18</b>	<b>Cracks in Bottom Plate Welds Near the Shell-to-bottom Joint</b> .....	<b>28</b>
<b>19</b>	<b>Cracks in Tank at Riveted Lap Joint to Tank Shell</b> .....	<b>28</b>
<b>20</b>	<b>Failure of Concrete Ringwall</b> .....	<b>45</b>
<b>21</b>	<b>Anchor Bolt with Suspected Corrosion</b> .....	<b>45</b>
<b>22</b>	<b>Corrosion of Anchor Bolts</b> .....	<b>46</b>
<b>23</b>	<b>Corrosion Under Insulation</b> .....	<b>47</b>
<b>24</b>	<b>Close-up of Corrosion Under Insulation</b> .....	<b>48</b>
<b>25</b>	<b>Corrosion (External) at Grade</b> .....	<b>49</b>
<b>26</b>	<b>Caustic Stress Corrosion Cracks</b> .....	<b>51</b>
<b>27</b>	<b>Small Hydrogen Blisters on Shell Interior</b> .....	<b>52</b>
<b>28</b>	<b>Large Hydrogen Blisters on Shell Interior</b> .....	<b>52</b>
<b>29</b>	<b>Tank Failure Caused by Inadequately Obstructed Vacuum Venting</b> .....	<b>54</b>
<b>30</b>	<b>Roof Overpressure</b> .....	<b>54</b>
<b>31</b>	<b>Example of Severe Corrosion of Tank Roof</b> .....	<b>59</b>
<b>32</b>	<b>Collapse of Pan-type Roof from Excessive Weight of Water While the Roof Was Resting on Its Supports</b> .....	<b>61</b>
<b>33</b>	<b>Pontoon Floating-roof Failure</b> .....	<b>61</b>
<b>34</b>	<b>Rolling Scaffold Used for Inspection and Repairs Inside of Tank</b> .....	<b>63</b>
<b>35</b>	<b>Single-point Suspended Scaffold Used for Inspection and Repairs on Exterior of Tank</b> .....	<b>63</b>
<b>36</b>	<b>Remotely Controlled Automated Crawler</b> .....	<b>64</b>
<b>37</b>	<b>Example of Vapor-liquid Line Corrosion</b> .....	<b>66</b>
<b>38</b>	<b>Corrosion Behind Floating-roof Seal</b> .....	<b>66</b>
<b>39</b>	<b>Example of Extensive Corrosion of a Tank Bottom</b> .....	<b>69</b>
<b>40</b>	<b>Shell-to-bottom Weld Corrosion</b> .....	<b>70</b>
<b>41</b>	<b>External View of Erosion-corrosion Completely Penetrating a Tank Shell</b> .....	<b>70</b>
<b>42</b>	<b>Internal Corrosion on Rafters and Roof Plates</b> .....	<b>72</b>
<b>43</b>	<b>Fin-tube Type of Heaters Commonly Used in Storage Tanks</b> .....	<b>73</b>
<b>44</b>	<b>Example of Corrosion of Steam Heating Coil</b> .....	<b>73</b>
<b>45</b>	<b>Hydraulic Integrity Test Procedures</b> .....	<b>76</b>
<b>46</b>	<b>Vacuum Box Used to Test for Leaks</b> .....	<b>78</b>
<b>47</b>	<b>Vacuum Box Arrangement for Detection of Leaks in Vacuum Seals</b> .....	<b>78</b>
<b>48</b>	<b>Helium Tester</b> .....	<b>80</b>
<b>49</b>	<b>Method of Repairing Tank Bottoms</b> .....	<b>86</b>

50	Temporary “Soft Patch” Over Leak in Tank Roof.....	89
51	Tank Jacked Up for Repairing Pad.....	89
A.1	Automatic Ultrasonic Testing .....	94
A.2	Magnetic Flux Leakage Scanner .....	94
A.3	Ultrasonic Examination .....	95
A.4	Guided Wave Ultrasonic Testing.....	95
A.5	Robotic Inspection Tool .....	96
C.1	Plain Hemispheroids.....	100
C.2	Noted Hemispheroid .....	100
C.3	Drawing of Hemispheroid.....	101
C.4	Plain Spheroid .....	101
C.5	Plain Hemispheroid with Knuckle Radius .....	102
C.6	Noted Spheroid .....	102
C.7	Drawing of Noted Spheroid.....	103
C.8	Plain Breather Roof Tanks .....	104
C.9	Tank with Vapor Dome Roof .....	105
C.10	Balloon Roof Tank .....	105
C.11	Cutaway View of Vapor Dome Roof .....	106

**Tables**

1	Suggested Basic Tools for Tank Inspection .....	42
2	Useful Supplemental Tools.....	42
B.1	Selected Considerations for Performing Similar Service Assessments.....	97
B.2	Similar Service Example for Product-side Corrosion .....	99

# Inspection Practices for Atmospheric and Low-pressure Storage Tanks

## 1 Scope

This document provides useful information and recommended practices for the maintenance and inspection of atmospheric and low-pressure storage tanks. Although these maintenance and inspection guidelines may apply to other types of tanks, these practices are intended primarily for existing tanks that were designed and constructed to API aboveground storage tank standards or specifications, as referenced in 2.2.

This document addresses the following:

- a) descriptions and illustrations of the various types of storage tanks;
- b) new tank construction standards;
- c) maintenance practices;
- d) reasons for inspection;
- e) causes of deterioration;
- f) frequency of inspection;
- g) methods of inspection;
- h) inspection of repairs;
- i) preparation of records and reports;
- j) safe and efficient operation;
- k) leak prevention methods.

This recommended practice is intended to supplement API 653 (applicable for all tanks) and API 12R1 (as applicable for the API 12 series tanks storing production liquids) that provide minimum requirements for maintaining the integrity of storage tanks after they have been placed in service.

## 2 Normative References

### 2.1 Codes, Standards, and Related Publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Standard 653, *Tank Inspection, Repair, Alteration, and Reconstruction*

### 2.2 Other References

The following codes and standards are cited in the text of this recommended practice or included in the knowledge base to develop this document. Familiarity with these documents is suggested as they provide additional information pertaining to the inspection and repair of aboveground storage tanks.