

Heat Recovery Systems

API RECOMMENDED PRACTICE 669
FIRST EDITION, JUNE 2022



American
Petroleum
Institute

Currently in preview, click buy full version

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees makes any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Users of this recommended practice should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required to conform to the standard.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standard_@api.org.

Currently in preview, click buy full version

Contents

	Page
1 Scope.....	1
2 Normative References.....	1
3 Terms, Definitions, Acronyms, and Abbreviations.....	1
3.1 Definitions.....	1
3.2 Acronyms and Abbreviations.....	3
4 General Information.....	3
4.1 Utility Systems.....	3
4.2 Mechanical Descriptions.....	3
4.3 Specific Heat Recovery Applications.....	4
Annex A (informative) Steam Systems.....	5
Annex B (informative) Hot Oil and Other Heat Transfer Fluids.....	12
Annex C (informative) Hot Water/Glycol Systems.....	17
Annex D (informative) Watertube WHRU Configurations.....	20
Annex E (informative) Firetube WHRU Configurations.....	23
Annex F (informative) FCCU/RCCU Process Units Heat Recovery Systems.....	48
Annex G (informative) Process Heater Convection Sections.....	50
Annex H (informative) Gas Turbine Exhaust Heat Recovery Systems.....	51
Annex I (informative) Thermal Oxidizers Heat Recovery Systems.....	52
Annex J (informative) Process/Flue Gas Heat Recovery Systems.....	56
Annex K (informative) Process Liquid Heat Recovery Systems.....	60
Annex L (informative) Sulfur Recovery Unit Heat Recovery Systems.....	61
Annex M (informative) Heat Flux and Circulation Ratio.....	68
Bibliography.....	73
Figures	
A.1 Typical Steam System Components as Part of a Watertube Steam Generator.....	7
B.1 Typical Molten Salt System.....	13
B.2 Typical Heat Transfer Fluid System with Waste Heat Recovery Unit.....	14
D.1 Typical Natural Circulation Watertube.....	21
D.2 Typical Forced Circulation System.....	22

Contents

	Page
E.1	Typical Horizontal Firetube with External Drum HRSG 26
E.2	Typical Vertical Firetube with External Drum HRSG 26
E.3	Typical Firetube Kettle Type HRSG 27
E.4	Typical Insulated Metal Ferrule 28
E.5	Typical Straight Ceramic Ferrule 29
E.6	Typical Headed Ceramic Ferrule 30
E.7	Tube Arrangements with Straight, Hex-head, and Square-head Ferrules 31
E.8	Typical Damage when Ferrule Fit is Too Tight 32
E.9	Conventional Strength Welds 33
E.10	Full Depth Strength Weld 33
E.11	Back Face (Shell Side) Weld 34
E.12	Typical Channel to Tubesheet-shell Interconnections 36
E.13	Typical Knuckles for Full Diameter Kettles 37
E.14	Typical Dual-compartment Firetube HRSG 39
E.15	Typical Two-pass, Separate Shells, Firetube HRSG 40
E.16	Typical Two Tube Pass Firetube HRSG 42
E.17	Typical Internal Bypass System with Valve and Damper 43
M.1	Example of Circulation Ratio Variability with Steam Rate 71

Tables

C.1	Freezing Points of Ethylene Glycol Based Water Solutions 19
C.2	Freezing Points of Propylene Glycol Based Water Solutions 19
M.1	HRSG Firetube and Watertube Local Heat Flux 69

Introduction

Users of this recommended practice (RP) need to be aware that further or differing requirements can be needed for individual applications. This RP is not intended to inhibit a vendor from offering, or the purchaser from accepting, alternative equipment or engineering solutions for the individual application. This can be particularly applicable where there is innovative or developing technology. Where an alternative is offered, the vendor should identify any variations from this RP and provide details.

This RP requires the purchaser to specify certain details and features.

In this RP, System International (SI) units are used and where practical, U.S. customary (USC) units are included in parentheses for information.

Currently in preview, click buy full version

Currently in preview, click buy full version

Heat Recovery Systems

1 Scope

1.1 This recommended practice (RP) provides guidelines for heat transfer equipment used in waste heat recovery systems in the petroleum, petrochemical, and natural gas industries. Details of related equipment designs are included only where these are necessary to ensure proper design and operation and safe interaction with the heat recovery system. It indicates areas that need attention and offers information and descriptions of various types of heat transfer equipment available to aid in the selection of the appropriate heat recovery system.

1.2 This RP does not include detailed requirements for:

- process to process heat recovery systems,
- gas turbine exhaust heat recovery,
- CO boilers, or
- convection sections used within fired heaters.

1.3 The waste heat recovery systems included in this RP are typical of those currently in use and should not limit the use of alternate systems.

1.4 Instrumentation and controls for waste heat recovery systems are sometimes mentioned but is not meant to completely define all requirements. Other standards and documents, such as API Recommended Practice 556, *Instrumentation, Control, and Protective Systems for Fired Heaters*, should be used to fully define the needed instruments and controls.

2 Normative References

There are no normative references in this document.

3 Terms, Definitions, Acronyms and Abbreviations

3.1 Definitions

For the purposes of this document, the following terms and definitions apply.

3.1.1

approach temperature

The difference between the saturation temperature of the steam at the selected pressure and the temperature of the water leaving the economizer.

3.1.2

desuperheater attenuer

A device located internal or external to the HRSG that controls the exit temperature of the steam from the superheater. The device typically injects water with very low solids content into the steam to control the steam temperature by reducing it. Also called an attenuator.

3.1.3

downcomer

A heated or unheated pipe carrying water from the steam drum to an evaporator/generator section of an HRSG.