

Materials and Fabrication of 2¼Cr-1Mo, 2¼Cr-1Mo-¼V, 3Cr-1Mo, and 3Cr-1Mo-¼V Steel Heavy-wall Pressure Vessels for High-temperature, High-pressure Hydrogen Service

API RECOMMENDED PRACTICE 934-A
FOURTH EDITION, JANUARY 2025



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Currently in preview, click buy full version

Contents

	Page
1 Scope.....	1
2 Normative References.....	2
3 Terms, Definitions, and Abbreviations.....	3
3.1 Terms and Definitions.....	3
3.2 Abbreviations.....	6
4 Design.....	7
5 Base Metal Requirements.....	7
5.1 Material Specifications.....	7
5.2 Steel-making Practice.....	8
5.3 Chemical Composition Limits.....	8
5.4 Heat Treatment.....	8
5.5 Mechanical Properties.....	9
6 Welding Consumable Requirements.....	11
6.1 Material Requirements.....	11
6.2 Mechanical Properties.....	12
7 Welding, Heat Treatment, and Production Testing.....	13
7.1 General Forming and Welding Requirements.....	13
7.2 Welding Procedure Qualification.....	14
7.3 Preheat and Heat Treatments during Base Metal Forming and Welding.....	15
7.4 Production Testing of Base Metal Welds.....	17
7.5 Weld Overlay.....	18
7.6 Final Postweld Heat Treatment.....	20
8 Nondestructive Examinations.....	21
8.1 General.....	21
8.2 NDE prior to Fabrication.....	21
8.3 NDE during Fabrication.....	22
8.4 NDE after Fabrication and prior to Final PWHT.....	22
8.5 NDE after Final PWHT.....	22
8.6 Positive Material Identification.....	23
9 Hydrostatic Testing.....	23
10 Preparation for Shipping.....	23
11 Documentation.....	23
12 Summary Material Examination and NDE Requirements.....	25
Annex A (informative) Guidance for Inspection for Transverse Reheat Cracking.....	28
Annex B (informative) Weld Metal/Flux Screening Test for Reheat Cracking Susceptibility.....	37
Annex C (informative) Minimum Pressurization Temperature (MPT) Determination.....	50

Contents

	Page
Bibliography.....	51

Figures

1	Location of Vickers Hardness Indentations.....	15
A.1	Schematic Showing Reheat Cracking Locations.....	30
A.2	B-scan for Detecting Transverse Defects with TOFD.....	30
A.3	Alternate Probe Setup with Offset for Detecting Transverse Defects.....	32
A.4	TOFD Sensitivity Demonstration Block.....	34
A.5	Characterization of Reheat Cracks Using Pulse-echo UT.....	36
B.1	Example of a Gripping Device Devoted to Threaded-end Specimens.....	38
B.2	Geometry of the Weld Joint To Be Used for the Screening Test Coupon.....	41
B.3	Welding Sequence To Be Used for the Screening Test.....	41
B.4	Example of Strongbacks Used to Minimize Coupon Distortion.....	41
B.5	Position of Pre-forms inside the Welded Zone (Macrographic View).....	42
B.6	Position of Pre-forms inside the Welded Zone (Schematic View).....	43
B.7	Detailed Geometry of RHC Standard Specimen.....	43
B.8	Location of the Thermocouples on the RHC Standard Specimen.....	44
B.9	Illustration of Heating Requirements on Test Specimens.....	45
B.10	Sample Test Certificate.....	48

Tables

1	Base Metal Specifications.....	8
2	Heat Treatment of Test Specimens.....	10
3	Proposed Testing Conditions at 842 °F (450 °C) to Simulate Hydrogen Charging from Maximum Operating Conditions.....	19
4	Test Conditions Domains.....	19
5	PWHT Holding Temperature and Time.....	21
6	Summary of API RP 934-A Material Examination and NDE Requirements.....	26
A.1	TOFD Guideline for Identifying Transverse Reheat Cracks.....	33
A.2	Example Probe Setup for 0.8 in. (250 mm) Thick Wall.....	34
A.3	Manual Pulse-echo Shear Wave Guideline for Identifying Transverse Reheat Cracks.....	35
B.1	Welding Parameters to be Used for Welding of Screening Test Coupons.....	40

Introduction

This recommended practice (RP) applies to new heavy-wall pressure vessels in petroleum refining, petrochemical, and chemical facilities in which hydrogen or hydrogen-containing fluids are processed at elevated temperature and pressure. It is based on decades of industry operating experience and the results of experimentation and testing conducted by independent manufacturers and purchasers of heavy-wall pressure vessels for this service.

Licensors and owners of process units in which these heavy-wall pressure vessels are to be used may modify or supplement this RP with additional proprietary requirements.

Currently in preview, click buy full version

Currently in preview, click buy full version

Materials and Fabrication of 2¼Cr-1Mo, 2¼Cr-1Mo-¼V, 3Cr-1Mo, and 3Cr-1Mo-¼V Steel Heavy-wall Pressure Vessels for High-temperature, High-pressure Hydrogen Service

1 Scope

This RP covers materials and fabrication requirements for new 2¼Cr and 3Cr steel heavy-wall pressure vessels for high-temperature, high-pressure hydrogen service. For this RP, “heavy-wall” is defined as a shell thickness of 4 in. (100 mm) or greater, and “high-temperature” is considered to be operating temperatures of 650 °F (345 °C), and up to a maximum design temperature where ASME Section II-D:2023 Table 5A defines the threshold temperature-dependent properties for the given material classification and in compliance with API 941. This RP applies to pressure vessels that are designed, fabricated, certified, and documented in accordance with ASME Section VIII, Division 2, Class 2, including Paragraph 3.4, Supplemental Requirements for Cr-Mo Steels, and ASME Code Case 2151, as applicable.

Although outside of its scope, this RP can be used as a resource for pressure vessels with wall thicknesses below 4 in. (100 mm) or operating at temperatures of less than 650 °F (345 °C), or with maximum design temperature limits above the thresholds given in the paragraph above with changes defined by the purchaser. This document may also be used as a resource when planning to modify an existing heavy-wall pressure vessel.

ASME Section VIII, Division 3 is typically used for much higher-pressure applications (beyond the hydroprocessing range), and a specific ASME Code Case developed for these alloys is also available under Division 3. Division 3 has much stricter design rules (e.g., fatigue and fracture mechanics analyses are required) and material testing requirements, and application of these rules is outside the scope of this document.

Materials covered by this RP are conventional Cr-Mo steels including standard 2¼Cr-1Mo and 3Cr-1Mo steels as well as advanced Cr-Mo steels, which include 2¼Cr-1Mo-¼V, 3Cr-1Mo-¼V-Ti-B, and 3Cr-1Mo-¼V-Nb-Ca steels. This document may be used as a reference document for the fabrication of pressure vessels made of enhanced steels (i.e., steels with mechanical properties increased by special heat treatments such as ASME SA-542, Grade B, Class 4) at the purchaser’s discretion. However, no attempt has been made to cover specific requirements for the enhanced steels, and they may be different than the requirements for vanadium grade steels.

The interior surfaces of these heavy-wall pressure vessels may have an austenitic stainless steel weld overlay lining to provide additional corrosion resistance. A lining of stainless steel cladding using a roll-bonded or explosion-bonded layer on Cr-Mo base metal may be acceptable, but this is outside the scope of this document except as mentioned in [7.5.2.2](#). Roll-bonded cladding is generally not available with the base metal thicknesses covered by this document. However, if users extend the recommendation of this document to thinner material, roll-bonded cladding may be used. Multilayer vessels are also outside the scope of this document.

Heat exchanger shells and channels that meet the conditions listed above are within the scope of this RP. They are included in the term “pressure vessel” for the purposes of this RP.

This is the fourth edition of RP 934-A. The legacy first edition was API RP 934, *Materials and Fabrication Requirements for 2¼Cr-1Mo & 3Cr-1Mo Steel Heavy Wall Pressure Vessels for High Temperature, High Pressure Hydrogen Service*, published December 2000. The second edition was issued in May 2008, and it was the first version referred to as “934-A.” RP 934-A, Second Edition, later incorporated [Annex A](#) and then [Annex B](#), which were issued in February 2010 and March 2012 as Addendum 1 and Addendum 2, respectively. The third edition was issued in January 2019 with an Errata in September 2021.