

Installation, Operation, Maintenance, Inspection, and Repair of Tanks in Production Service

API STANDARD 12R1
SEVENTH EDITION, JULY 2025

ERRATA 1, JULY 2025



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Classified areas may vary depending on the location, conditions, equipment, and substances involved in any given situation. Users of this specification should consult with the appropriate authorities having jurisdiction. Users of this specification should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or the violation of any authorities having jurisdiction with which this publication is in conflict.

API publications are published to facilitate the broad availability of proven sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or material in conformance with the marking requirements of an API standard is solely responsible for complying with all of the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the safety data sheet.

Where applicable, authorities having jurisdiction should be consulted.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the standard. At all times users should employ sound business, scientific, engineering, and judgment safety when using this standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Currently in preview, click buy full version

Contents

	Page
1 Scope.....	1
2 Normative References	1
3 Terms, Definitions, Acronyms, and Abbreviations	2
3.1 Terms and Definitions	2
3.2 Acronyms and Abbreviations	7
4 Installation.....	7
4.1 General	7
4.2 Setting of New or Relocating Tanks	7
4.3 Spill Containment.....	8
4.4 Foundations for Steel and Nonmetallic Tanks.....	8
4.5 Safety and Security.....	9
4.6 Electrical	10
4.7 Venting	10
4.8 Tank Access	11
4.9 Corrosion Protection	12
5 Operation	12
5.1 General	12
5.2 Measurement.....	14
6 Maintenance	15
6.1 General	15
7 Inspection	15
7.1 General	15
7.2 Inspection Protocols	17
7.3 External Inspections	18
7.4 Internal Inspections.....	19
7.5 Evaluation	20
8 Repairs	20
8.1 General	20
8.2 Temporary Repairs	21
8.3 Replacement Shell Plate	21
8.4 Weld Joints	21
8.5 Weld Repair	21
8.6 Shell Penetration Repair.....	21
8.7 Hot Taps.....	22
8.8 Leak Detection with Bottom Replacement.....	22
8.9 Reconstruction of a Dismantled Tank	22
8.10 Leak Testing.....	22
9 Nameplates.....	22
Annex A (informative) Recommended Qualifications for Qualified Inspectors	24
Annex B (informative) External Condition Examination Checklist	25

Contents

	Page
Annex C (informative) Internal Condition Examination Checklist	29
Annex D (normative) Minimum Thickness for Tank Elements	32
Annex E (normative) Walkways and Stairways	36
Annex F (informative) Figures and Diagrams	44
Annex G (informative) Unmanned Upstream Facility Design and Safety Considerations	48
Annex H (informative) Existing Tank Re-rating for Higher Pressure	54
Annex I (informative) Inquiries and Suggestions for Change	59
Bibliography	63

Figures

D.1	Corrosion Calculation Nomenclature	34
E.1	Walkway Dimensional Requirements	38
E.2	Stairway Dimensional Requirements	41
F.1	Example of Straight-line Tank Battery Installation and Piping Configurations	45
F.2a	Example Tank Battery Installation Elevation Showing Dike and Example Piping Configuration	46
F.2b	Example Tank Battery Installation Top View Showing Dike and Example Piping Configuration	47
G.1	Full-size Gate	51
G.2	Half-size Gate	51
G.3	Examples of Signage	53
H.1	API 12F Detailed Junction Drawings	58

Tables

1a	External Tank Examination/Inspection Scheduled	19
1b	External Tank Examination/Inspection Unscheduled	19
2	Internal Tank Examination/Inspection Schedule	20
B.1a	External Condition Examination Information and Guidance	25
B.1b	External Condition Examination Checklist	26
C.1a	Internal Condition Examination Information and Guidance	29
C.1b	Internal Condition Examination Checklist	30
D.1	Summary of Minimum Thickness for Tank Elements	35

Introduction

This standard is based on the accumulated knowledge and experience of owner/operators and manufacturers of storage tanks of various sizes and capacities. This standard provides guidelines to install (set, connect), operate, maintain, inspect, and repair a tank in the upstream segment of the petroleum industry. This standard is not to be interpreted as approving, recommending, or endorsing any specific design or as limiting the method of design or construction.

It is not the intent to modify operating facilities; however, it is intended that any new work, operation, maintenance, inspection, and repair meet these requirements. The user may modify, delete, or amplify sections of this standard, but reference to this standard shall not be made on the nameplates of, or certification for, tanks that do not fulfill the minimum requirements of this standard. More stringent requirements specified by the purchaser or furnished by the contractor are acceptable as mutually agreed upon by the purchaser and the contractor.

This standard is not intended to cover storage tanks that are to be erected in areas subject to regulations more stringent than the specifications in this standard or for midstream or downstream segments of the petroleum industry. When this standard is specified for such tanks, it should be followed insofar as it does not conflict with local requirements. The purchaser is responsible for specific state and federal jurisdictional requirements applicable to the design and construction of the tank. After revisions to this standard have been issued, they may be applied to tanks that are to be completed after the date of issue. The tank nameplate shall state the date of the edition of the standard and any revision and edition to which the tank has been designed and constructed. Each edition, revision, or addendum to this standard may be used beginning the date of issue on the cover page for that edition, revision, or addenda. Each edition, revision, or addenda to this standard becomes effective six months after the date of issuance for equipment that is certified as being constructed, tested, inspected, maintained, or repaired in accordance with this standard. During the six-month period between the date of issuance of the edition, revision or addenda and effective date, the purchaser and the manufacturer shall specify to which edition, revision, or addenda the equipment is to be constructed and inspected.

Currently in preview, click buy full version

Installation, Operation, Maintenance, Inspection, and Repair of Tanks in Production Service

1 Scope

1.1 This standard provides the minimum requirements to install, operate, maintain, inspect, repair, and reconstruct both new and existing tanks used in petroleum production service in a manner that includes best practices for tank facility safety, security, and environmental protection.

1.2 Tanks in refineries, petrochemical plants, marketing bulk plants, and pipeline storage facilities operated by carriers are not within the scope of this standard.

1.3 This standard is intended primarily for application to tanks fabricated to API Specifications 12B, 12D, 12F, and 12P which are deployed in onshore production services; however, it may be applied to other tanks and services at the discretion of the owner/operator.

1.4 [Annex G](#) of this standard contains specific safety information applicable to tanks. For additional safety information, see other publications referenced within this standard.

1.5 The schematic drawings included in this standard are examples of some features described in the standard.

1.6 Lease automatic custody transfer (LACT) operations are covered in the *API Manual of Petroleum Measurement Standards*.

NOTE A bullet [•] at the beginning of a paragraph indicates that there is an expressed decision or action recommended or required to be addressed by or on behalf of the owner/operator. The purchaser's responsibility is not limited to these decisions or actions alone. When such decisions and actions are taken, they are to be specified in documents such as requisitions, change orders, data sheets, and drawings.

2 Normative References

The following referenced documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any addenda) applies.

API Specification 12B, *Bolted Tanks for Storage of Production Liquids*

API Specification 12D, *Field Welded Tanks for Storage of Production Liquids*

API Specification 12F, *Shop Welded Tanks for Storage of Production Liquids*

API Specification 12P, *Fiberglass Reinforced Plastic Tanks*

API Standard 620, *Welded Steel Tanks for Oil Storage*

API Standard 653, *Tank Inspection, Repair, Alteration and Reconstruction*

API Standard 2000, *Venting Atmospheric and Low-Pressure Storage Tanks*

API Recommended Practice 2003, *Protection against Ignitions Arising Out of Static, Lightning and Stray Currents*

API Standard 2015, *Requirements for Safe Entry and Cleaning of Petroleum Storage Tanks*

API Manual of Petroleum Measurement Standards, Chapter 2—Tank Calibration