

Design, Construction, Operation, Maintenance, and Inspection of Terminal and Tank Facilities

API STANDARD 2610
THIRD EDITION, SEPTEMBER 2018



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Classified areas may vary depending on the location, conditions, equipment, and substances involved in any given situation. Users of this specification should consult with the appropriate authorities having jurisdiction. Users of this specification should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the safety data sheet.

Where applicable, authorities having jurisdiction should be consulted.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the standard. At all times users should employ sound business, scientific, engineering, and judgment safety when using this standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Contents

	Page
1 Scope and Purpose	1
1.1 Overview	1
1.2 Petroleum Terminals	1
1.3 Pipeline Tankage Facilities	1
1.4 Refinery Facilities	1
1.5 Bulk Plants	2
1.6 Lubricant Blending and Packaging Facilities	2
1.7 Asphalt Plants	2
1.8 Aviation Service Facilities	2
1.9 Nonapplicability and Retroactivity	2
1.10 Governmental Requirements and Reviews	3
2 Normative References	3
3 Terms and Definitions	12
4 Site Selection and Spacing Requirements	14
4.1 Overview	14
4.2 Site Selection	14
4.3 Spacing Requirements	15
5 Pollution Prevention and Waste Management	16
5.1 Applicability	16
5.2 Waste Management Hierarchy	17
5.3 Pollution Prevention	18
5.4 Waste Management Practices	21
6 Safe Operations of Terminals and Tanks	22
6.1 General	22
6.2 Hazard Identification	22
6.3 Operating Procedures	23
6.4 Safe Work Practices	23
6.5 Emergency Response and Control Procedures	23
6.6 Management of Change	24
6.7 Training	24
6.8 Pre-start-up Safety and Operational Inspection	24
6.9 Incident Investigation	25
6.10 Contractor Safety	25
7 Fire Prevention and Protection	25
7.1 General	25
7.2 Fire Prevention	25
7.3 Fire Fighting Equipment	27
7.4 Fire Extinguishment and Control	28
7.5 Fire Protection Water Supplies	29
7.6 Fire Emergency Plan	30
7.7 Exposure Protection	30
7.8 Special Product Considerations	31
8 Tanks	32
8.1 Aboveground Petroleum Storage Tanks	32
8.2 Operations, Inspections, Maintenance, and Repair for Aboveground Tanks	37

Contents

	Page
8.3 Fiberglass Reinforced Plastic (FRP) ASTs	39
8.4 Underground Storage Tanks (USTs) and Piping	39
8.5 UST Vapor Emissions	39
9 Dikes and Berms	40
9.1 Overview	40
9.2 Dikes	40
9.3 Berms	42
10 Pipe, Valves, Pumps, and Piping Systems	43
10.1 General	43
10.2 Material Compatibility	43
10.3 Piping Systems	43
10.4 Piping Components	45
10.5 Pumps	47
10.6 Pipeline Integrity Assurance of Existing Piping Systems	48
10.7 Testing Following Construction	49
11 Loading, Unloading, and Product Transfer Facilities	49
11.1 Scope	49
11.2 General Design	49
11.3 Truck Loading/Unloading	50
11.4 Rail Tank Car Loading and Unloading	53
11.5 Marine Loading/Unloading	55
11.6 Aviation Loading/Unloading	56
11.7 Vapor Control	57
11.8 Oxygenate Blending	59
11.9 Emergency Shutdown Systems and Procedures	59
11.10 Product Testing	60
11.11 Communication	60
11.12 Measurements	60
11.13 Valves, Lines, Loading Arms, and Close Product Identification	60
11.14 Release Prevention System in Loading/Unloading Areas	60
11.15 Maintenance/Testing	60
11.16 Auxiliary Systems	61
12 Corrosion Control	61
12.1 Scope	61
12.2 Protective Coatings	61
12.3 Internal Tank Lining	66
12.4 Cathodic Protection (CP)	68
12.5 Volatile Corrosion Inhibitors (VCIs)	70
13 Structures, Utilities, and Yard	71
13.1 Structures	71
13.2 Utilities	72
13.3 Yard	80
14 Removals and Decommissioning of Facility	85
14.1 General	85
14.2 Site Control and Protection	86
14.3 Preparations	86

Contents

	Page
14.4 Execution	86
14.5 Site Assessment and Remediation	87
14.6 Closeout and Cleanup	87
14.7 Facility Lockout	87
14.8 Signage and De-identification	88
Bibliography	89

Figures

1	Typical Electric Service and Distribution System Terminals and Bulk Plants	74
2	Segregated Waste Stream in a Typical Terminal	78
3	Tank Truck Loading Yard Layout Without Garage	82
4	Tank Truck Loading Yard Layout with Garage	83
5	Yard Dimensions for Trucks	84

Introduction

This standard was developed to guide the management of terminals and tanks in a manner that protects the environment and the safety of workers and the public. This standard is intended for petroleum terminal and tank facilities associated with marketing, refining, pipeline, and other similar facilities. This standard may be used as a resource and management guide by those responsible for such facilities and by those working on their behalf. This standard is a compilation of industry knowledge, information, and management practices for all relevant aspects of terminal and tank operations aggregated into an overview document comprising best practices. In instances where greater detail or additional information may be helpful or needed, this standard references other API publications, or similar industry guides and standards. It is intended to be consistent with, but is not a substitute for, any applicable federal, state, and local regulations.

The requirements of this standard represent minimum requirements applicable to all facilities within the scope of this document. Some provisions in this standard, as indicated by the use of the word shall, are mandatory and have to be followed to meet the intent of this standard. Some provisions are recommended, as denoted by the word should, but are not mandatory. These provisions will need to be considered based on site-specific factors. Still other provisions are optional, as denoted by the word may. Typically, these will be given where a range of good options exists.

To foster greater awareness and assist the industry in addressing environmental, health, and safety concerns, API has undertaken the development of this single document aggregating the various standards, specifications, and recommended practices on the design, construction, operation, inspection, and maintenance of petroleum terminals and tanks. API also has significant research underway to assist members in addressing issues of groundwater protection and remediation of soil contamination. This research includes the evaluation of improved leak detection technology and the evaluation of better methods to detect and remediate groundwater and soil contamination.

Design, Construction, Operation, Maintenance, and Inspection of Terminal and Tank Facilities

1 Scope and Purpose

1.1 Overview

This standard covers the design, construction, operation, inspection, and maintenance of petroleum terminal and tank facilities associated with marketing, refining, pipeline, and other similar activities as stipulated in 1.2 through 1.8. This standard covers site selection and spacing, pollution prevention and waste management, safe operation, fire prevention and protection, tanks, dikes and berms, mechanical systems, product transfer, corrosion protection, structures, utilities and yard, and removals and decommissioning.

The purpose of this standard is to consolidate a wide base of current industry experience, knowledge, information, and management practices into a cohesive standard comprising a range of best practices.

The values stated for this standard are in U.S. Customary units with the International System of Units (SI) provided in parentheses.

The petroleum industry is engaged in the manufacture, storage, transportation, blending, and distribution of crude oil and refined products. Individual terminal facilities and plants may perform one or more of these functions. These facilities represent diverse operations ranging from small distribution facilities (e.g. bulk plants and warehouses), to large storage and distribution facilities (e.g. pipeline and marine terminals and wholesale plants), to large integrated facilities (e.g. petroleum refineries and gas production, oil blending, and packaging plants). The specific application of this standard within those various types of operations is itemized in 1.2 through 1.8.

1.2 Petroleum Terminals

Petroleum terminals may include tank farms, loading and unloading areas, pipeline manifolds, storage areas, warehouses, docks, garages, product quality test rooms, and office buildings. Products may be received and distributed by pipeline, marine transport, rail, or truck. Bulk quantities of refined products are stored in aboveground tanks for distribution in smaller quantities to industrial customers, to commercial consumers, and to retail and wholesale marketing facilities. Petroleum terminals may also store petroleum products in consumer packaging, bulk containers, totes, and drums. See USCG 33 *CFR* Parts 154 and 156.

1.3 Pipeline Tankage Facilities

Pipeline tankage facilities consist of breakout tanks and tank farms used to receive and transport petroleum (crude oil and refined products) from pipelines and to provide surge relief from pipeline operations (see Office of Pipeline Safety regulation PHMSA 49 *CFR* Part 195).

1.4 Refinery Facilities

Provisions for loading and unloading areas, docks, blending and packaging facilities, warehouses, and some refinery tankage facilities are included in this standard. Refinery tankage covered by this standard does not include those aboveground tanks or groups of tanks as defined in 1.2 c) (e.g. process tanks).

Examples of covered refinery tankage include tanks that are used to accomplish the following.

- a) Receive incoming crude oil.
- b) Store intermediate products or components outside of the refinery process units.