

Pressure-relieving and Depressuring Systems

API STANDARD 521
SEVENTH EDITION, JUNE 2020



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which the publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the publisher, API Publishing Services, 200 Massachusetts Avenue, Suite 1100, Washington, DC.

Copyright © 2020 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

	Page
1	Scope 1
2	Normative References 1
3	Terms, Definitions, Acronyms, and Abbreviations 1
3.1	Terms and Definitions 1
3.2	Acronyms and Abbreviations 10
4	Causes of Overpressure and Their Relieving Rates 11
4.1	General 11
4.2	Overpressure Protection Philosophy 12
4.3	Determination of Individual Relieving Rates 14
4.4	Individual Overpressure Causes and Their Relieving Rates 16
4.5	Guidance on Vacuum Relief 64
4.6	Vapor Depressuring 66
4.7	Relief System Design Documentation 74
4.8	Flare Header Design Documentation 78
4.9	Special Considerations for Individual PRDs 78
5	Disposal Systems 80
5.1	General 80
5.2	Fluid Properties That Influence Selection and Design of Disposal Systems 80
5.3	System Design Load 82
5.4	System Arrangement 85
5.5	Piping 88
5.6	Disposal to a Lower-pressure System 104
5.7	Disposal to Flare 104
5.8	Disposal to Atmosphere 125
5.9	Design Details for Seal and Knockout Drums 142
	Annex A (informative) An Analytical Methodology for Fire Evaluations 144
	Annex B (informative) Special System Design Considerations 162
	Annex C (informative) Sample Calculations 165
	Annex D (informative) Typical Details and Sketches 204
	Annex E (informative) High-Integrity Protection Systems 207
	Annex F (informative) Flare Background Information 213
	Annex G (informative) Vapor Breakthrough into Liquid-containing Systems 219
	Annex H (informative) Flow-induced Vibration 222
	Bibliography 223
	Figures
1	Average Rate of Heating Steel Plates Exposed to Open Gasoline Fire on One Side 40
2	Effect of Overheating Carbon Steel (ASTM A515, Grade 70) 41
3	Isothermal Flow Chart 91
4	Adiabatic Flow of $k = 1.00$ (i.e. Isothermal Flow) Compressible Fluids Through Pipes at High Pressure Drops 93
5	Determination of Drag Coefficient 117

Contents

	Page	
6	Typical Flare Gas Recovery System	122
7	Flare Gas Recovery Inlet Pressure	127
8	Maximum Downwind Vertical Distance from Jet Exit to Lean-flammability Concentration Limit for Petroleum Gases	128
9	Maximum Downwind Horizontal Distance from Jet Exit to Lean-flammability Concentration Limit for Petroleum Gases	129
10	Axial Distance to Lean- and Rich-flammability Concentration Limits for Petroleum Gases	130
11	Sound Pressure Level at 30 m (100 ft) from the Stack Tip	141
A.1	Effect of Fuel Air Stoichiometry on Pool and Jet Fire Heat Fluxes	144
A.2	Typical Effect of Wall Temperature on Absorbed Heat Flux for Pool Fires	147
A.3	Illustration of Actual Stress Compared with the UTS for a Fire Exposed Pipe That Is Depressurized	154
A.4	Fire Depressurization Work Flow Diagram	155
A.5	Minimum Depressuring Rates to Avoid Failure of a Gas-filled Vessel Fabricated from SA-516 Carbon Steel and Exposed to a Pool Fire	159
A.6	Vapor Pressure and Heat of Vaporization of Pure, Single-component Paraffin Hydrocarbon Liquids	161
B.1	Typical Flow Scheme of a System Involving a Single PRD Service Components in a Process System with Typical Pressure Profiles	163
C.1	Equilibrium Phase Diagram for a Given Liquid	166
C.2	Dimensional References for Sizing a Flare Stack	171
C.3	Flame Center for Flares and Ignited Vents—Horizontal Distance, x_c (SI Units)	176
C.4	Flame Center for Flares and Ignited Vents—Horizontal Distance, x_c (USC Units)	177
C.5	Flame Center for Flares and Ignited Vents—Vertical Distance, y_c (SI Units)	178
C.6	Flame Center for Flares and Ignited Vents—Vertical Distance, y_c (USC Units)	179
C.7	Flare Knockout Drum	182
C.8	Use of the Analytical Method to Reproduce API Fire Test Data (See Plate 2 of Figure 1)	190
C.9	Use of the Analytical Method to Reproduce API Figure 1, Plates 1, 3, and 4	191
C.10	BRL Test Data Illustrating Fire Temperature vs Time at the Top of the Front and Rear Walls of a Rail Tank Car Containing LPG and Exposed to a JP-4 Pool Fire	192
C.11	BRL Test Data Illustrating Wall Temperature vs Time at the Top of the Front and Rear Walls of a Rail Tank Car Containing LPG and Exposed to a JP-4 Pool Fire	192
C.12	Use of the Analytical Method to Reproduce BRL Fire Test Data (Constant Fire Temperature)	193
C.13	BAM Test Data Illustrating Fire Temperature vs Time at Various Locations Around a Rail Tank Car Containing LPG and Exposed to a Fuel Oil Pool Fire	194
C.14	BAM Test Data Illustrating Wall Temperature vs Time at Various Locations Around a Rail Tank Car Containing LPG and Exposed to a Fuel Oil Pool Fire	195
C.15	Use of the Analytical Method to Reproduce BAM Fire Test Data (Variable Fire Temperature)	196
C.16	Use of the Analytical Method to Reproduce BAM Fire Test Data (Constant Fire Temperature)	197
C.17	Liquid Temperature vs Time Profile from the BAM Fire Test	199
C.18	Comparison of the API Empirical Method and the Analytical Method with BRL Fire Test Data	201
C.19	Calculated Wetted Area Exponent of the API Empirical Method Equation (8) Based on BRL Fire Test Data	201
D.1	Typical Horizontal Flare Seal Drum	204
D.2	Quench Drum	205
D.3	Typical Flare Installation	206
F.1	Flame Length vs Heat Release—Industrial Sizes and Releases (SI Units)	216
F.2	Flame Length vs Heat Release—Industrial Sizes and Releases (USC Units)	217
F.3	Approximate Flame Distortion Due to Lateral Wind on Jet Velocity from Flare Stack	218

Contents

Page

Tables

1	Guidance for Required Relieving Rates Under Selected Conditions	17
2	Typical Values of Cubic Expansion Coefficient for Hydrocarbon Liquids and Water	27
3	Values of Linear Expansion Coefficient, α_l , and Modulus of Elasticity, E	36
4	Effects of Fire on the Wetted Surfaces of a Vessel	39
5	Environmental Factor	42
6	Thermal Conductivity Values for Typical Thermal Insulations	50
7	Possible Utility Failures and Equipment Affected	62
8	Design Basis for PRD Laterals and Disposal System Headers	85
9	Typical K -factors for Pipe Fittings	94
10	Typical K -factors for Reducers (Contraction or Enlargement)	95
11	Exposure Times Necessary to Reach the Pain Threshold	106
12	Recommended Design Thermal Radiation for Personnel	106
A.1	Comparison of Heat Absorption Rates in Fire Tests	146
A.2	Typical Range in Equation (A.1) Parameters for an Open Pool Fire	149
A.3	Recommended Values for Equation (A.1) Parameters for an Open Pool Fire Where Other Data or Information is Unavailable	150
A.4	Typical Range in Equation (A.1) Parameters for a Jet Fire	151
A.5	Recommended Values for Equation (A.1) Parameters for a Jet Fire Where Other Data or Information Is Unavailable	152
A.6	Typical Starting Points for Step 1 in Figure A.4 When Designing Depressurization System for Unwetted Walls Exposed to Jet Fires	156
A.7	High-temperature Tensile Strength of Carbon Steel and 18-8 Stainless Steel	159
C.1	Optimizing the Size of a Horizontal Knockout Drum (SI Units)	185
C.2	Optimizing the Size of a Horizontal Knockout Drum (USC Units)	186
C.3	Equation (A.1) Parameters Used to Reproduce Curves in Figure 1	190
C.4	Equation (A.1) Parameters Used to Reproduce BRL Fire Test Data for the Rail Tank Car Top Front and Rear Wall Temperatures vs Time	193
C.5	Equation (A.1) Parameters Used to Reproduce BAM Fire Test Data for the Rear Locations of the Rail Tank Car Temperatures vs Time	195
C.6	Comparison of Absorbed Heat Duties Calculated with the API Empirical and Analytical Method Applying the BAM Fire Test Data	198
E.1	Safety Integrity Level vs. Availability	210
F.1	Radiation from Gaseous Diffusion Flames	215

Introduction

The portions of this standard dealing with flares and flare systems are an adjunct to API Standard 537, which addresses design, operation, and maintenance of flare equipment. It is important for all parties involved in the design and use of a flare system to have an effective means of communicating and preserving design information about the flare system. To this end, API has developed a set of flare datasheets, which can be found in API Standard 537, Annex E. The use of these datasheets is both recommended and encouraged as a concise, uniform means of recording and communicating design information.

The Bibliography lists the documents that are referenced informatively in this standard, as well as other documents not cited in this standard but which contain additional useful information. Some of the content of the documents listed might not be suitable for all applications and therefore needs to be assessed for each application before use.

In this standard, quantities are expressed in the International System (SI) of units and the US customary (USC) units.

Pressure-relieving and Depressuring Systems

1 Scope

This standard is applicable to pressure-relieving and vapor depressuring systems. Although intended for use primarily in oil refineries, it is also applicable to petrochemical facilities, gas plants, liquefied natural gas (LNG) facilities, and oil and gas production facilities. The information provided is designed to aid in the selection of the system that is most appropriate for the risks and circumstances involved in various installations.

This standard specifies requirements and gives guidelines for the following:

- examining the principal causes of overpressure;
- determining individual relieving rates;
- selecting and designing disposal systems, including such component parts as piping, vessels, flares, and vent stacks.

This standard does not apply to direct-fired steam boilers.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Standard 520, *Sizing, Selection, and Installation of Pressure-relieving Devices, Part 1—Sizing and Selection*, Ninth Edition, 2014

API Standard 520, *Sizing, Selection, and Installation of Pressure-relieving Devices, Part 2—Installation*, Sixth Edition, 2015

API Standard 537, *Flare Details for Petroleum, Petrochemical, and Natural Gas Industries*, Third Edition, Addendum 1, 2020

3 Terms, Definitions, Acronyms, and Abbreviations

3.1 Terms and Definitions

For the purposes of this document, the following definitions apply.

3.1.1

accumulation

Pressure increase over the maximum allowable working pressure (MAWP) of the vessel during discharge through the pressure relief device.

NOTE Accumulation is expressed in units of pressure or as a percentage of MAWP or design pressure. Maximum allowable accumulations are established by pressure design codes for emergency operating and fire contingencies.

3.1.2

administrative controls

Procedures intended to ensure that personnel actions do not compromise the overpressure protection of the equipment.