

Post-combustion NO_x Control for Fired Equipment in General Refinery and Petrochemical Services

API STANDARD 536
THIRD EDITION, SEPTEMBER 2017



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Copyright © 2017 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patents.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, NW, Washington, D.C. 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, D.C. 20005, standards@api.org.

Currently in preview, click buy full version

Contents

	Page
1 Scope	1
2 Normative References	1
3 Terms, Definitions, and Abbreviations	3
3.1 Definitions	3
3.2 Abbreviations	6
4 Proposals and Documentation	7
4.1 Purchaser's Responsibilities	7
4.2 Vendor's Responsibilities	8
4.3 Documentation	9
4.4 Performance Tests and Guarantees	11
4.5 Final Records	12
5 Design Requirements	13
5.1 Process Design	13
5.2 System Design	13
5.3 Mechanical Definition	15
5.4 Post-combustion NO _x Treatment System	15
5.5 Ammonia Flow Control Unit (AFCU)	16
5.6 Direct Reactant Injection System (DRIS)	17
5.7 Reactant Injection System (RIS)	17
5.8 Reactant Control System	17
5.9 Piping and Skids	17
5.10 Urea Handling and Preparation	17
5.11 Ammonia Vaporizer/Mixer	18
5.12 Reactant Storage	18
5.13 SCR Catalyst and Reactor Housing	19
5.14 Structures and Appurtenances	19
5.15 Refractories and Insulation	20
5.16 Instrumentation and Electrical Systems	21
5.17 Induced Draft Fan and Dilution Air Blowers	21
5.18 Flue Gas Connections	21
5.19 NO _x Analyzers	22
6 Fabrication and Shop Assembly	22
6.1 General	22
6.2 Structural-steel Fabrication	22
6.3 Control Skids	23
6.4 Refractory and Insulation	25
6.5 Dilution Air Blowers	25
7 Inspection and Testing	25
7.1 General	25
7.2 Catalyst	26
7.3 Mechanical Components	27
7.4 Electrical Components	27
7.5 Structural	28
7.6 Piping	28
7.7 Refractory	28
7.8 Acceptance Testing	28

Contents

	Page
8 Storage, Handling, Identification, and Shipping	29
9 Field Installation and Erection	30
9.1 General	30
9.2 Catalyst	30
Annex A (informative) Post-Combustion NO _x Control Process Selection and Application	31
Annex B (informative) Selective Non-catalytic Reduction (SNCR)	33
Annex C (informative) Selective Catalytic Reduction (SCR)	36
Annex D (informative) Reactant Storage, Distribution, Control, and Injection Systems	40
Annex E (informative) General Design Considerations	61
Annex F (informative) Post-combustion NO _x Control Datasheets	63
Annex G (informative) Operational Considerations	78
Annex H (informative) Calculation Method for Correcting NO _x Measurements	86
Annex I (informative) Flow Modeling Considerations	88
Annex J (informative) SCR Operations, Inspection, and Maintenance Considerations	92
Annex K (informative) Design Considerations Affected By Flue Gas Quality and Particulates	96
Annex L (informative) Units of Emission Measurement	99
Annex M (informative) Proposed Shop Assembly Conditions	100
Annex N (informative) Post-combustion NO _x Control Checklist	102
Bibliography	107
Figures	
B.1 Comparison of Typical SNCR and SCR Systems	34
B.2 SNCR Effect of Residence Time	34
C.1 Typical Operating Temperature Ranges for SCR Catalysts	37
D.1 SNCR Aqueous Ammonia System Schematic	54
D.2 SNCR Anhydrous Ammonia System Schematic	55
D.3 SNCR Urea System Schematic	56
D.4 SCR Aqueous Ammonia System Schematic	57
D.5 SCR Anhydrous Ammonia System Schematic	58
D.6 Aqueous Ammonia Storage System	59
D.7 Anhydrous Ammonia Storage System	60
G.1 Ammonium Sulfate and Ammonium Bisulfate Precipitation Temperature Downstream of SCR	79
G.2 Typical NO _x Reduction Efficiency and Ammonia Slip	83
Tables	
A.1 Comparison of Typical SNCR and SCR Systems	32
B.1 SNCR Design Considerations for New and Retrofit Units	35
C.1 SCR Design Considerations-New Units and Retrofit Units	39
G.1 Flue Gas Temperature Operation	82
K.1 Catalyst Degradation Sources and Mechanisms	97
N.1 Checklist for Post-combustion NO _x Control Equipment	103

Currently in preview, click buy full version

Introduction

Post-combustion NO_x control systems reduce levels of NO_x emissions by converting the NO_x formed during the combustion process to nitrogen (N₂) gas. The chemical reactions required to convert the NO_x to N₂ for the systems described in this standard are applied downstream of the combustion zone. These techniques introduce a reactant into the flue gas stream to react with the NO_x. The reaction may be completed with or without the use of catalyst.

It may be necessary to combine more than one method of post-combustion control to achieve the desired level of NO_x reduction.

The application of any NO_x reduction technique and control technology is most often in compliance with an environmental regulation requirement, which include both instantaneous and time averaged performance criteria. Reliable and effective performance of the NO_x control systems and related mechanical systems and components are critical in meeting regulatory requirements and environmentally responsible operation.

The fundamental elements that are required in order to provide the expected reliability and performance requirements for post-combustion NO_x control systems specified and supplied through the use of this standard include the following:

- process definition;
- process performance expectations;
- system design selection;
- mechanical definition of systems and components.

The selected post-combustion NO_x control systems and equipment should be capable of the specified performance for a design period for the run length specified in the data sheets without the need for an unplanned outage of the post-combustion NO_x treatment control systems and equipment or the associated combustion equipment.

For new designs, the type of post-combustion NO_x control system design selections and mechanical definition can be advanced using the requirements, guidance and recognized good industry practice that are identified in this document.

Users of this Standard should be aware that further or differing requirements may be needed for individual applications. This Standard is not intended to inhibit a vendor from offering, or the purchaser from accepting, alternative equipment or engineering solutions for the individual application. This may be particularly applicable where there is innovative or developing technology. Where an alternative is offered, the vendor should identify any variations from this standard and provide details.

In this Standard, the SI system of units is used. Where practical in this Standard, U.S. Customary units are included in brackets for information.

A bullet (●) at the beginning of a clause or sub-clause indicates that either a decision is required or further information is to be provided by the purchaser. This information should be indicated on data sheets (see examples in Annex N) or stated in the inquiry or purchase order.

Post-combustion NO_x Control for Fired Equipment in General Refinery and Petrochemical Services

1 Scope

This standard specifies requirements and provides guidance for the selection, design specification, mechanical description, operation, maintenance, and test procedures for post-combustion NO_x control equipment and related mechanical systems and components used for fired equipment in petrochemical and general refinery service.

This document covers the following methods of post-combustion NO_x reduction for both new and retrofit applications:

- Selective Non-catalytic Reduction (SNCR), and
- Selective Catalytic Reduction (SCR).

This standard is primarily intended for direct application to fired process heaters, reformers, and industrial and power boilers used in petrochemical and general refinery services. The same fundamental NO_x control technologies and systems may also be applied to Fluid Catalytic Cracking Units (FCCUs), incinerators, gas turbine exhaust, and other exhaust gas process systems; however, SCRs may require additional considerations beyond the scope of this standard to address unique aspects, such as high particulate content and corrosive chemicals, in the flue gas stream.

This document does not cover:

- reduced NO_x formation through combustion controls and design techniques such as low-NO_x burners, flue gas recirculation (FGR), and staged combustion; or
- non-selective catalytic reduction (NSCR) for the control of NO_x and other pollutant emissions.

For further guidance on post-combustion NO_x control process selection and the application of SNCR and SCR systems, refer to Annex A.

For further guidance on the process description of SNCR and SCR technologies and systems, refer to Annex B and Annex C, respectively.

For further guidance on reactant storage, distribution, control, and injection systems, and general design considerations, including purchaser decisions for SNCR and SCR systems, refer to Annex D and Annex E, respectively.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Standard 560, *Fired Heaters for General Refinery Service*

API Standard 620, *Design and Construction of Large, Welded, Low-pressure Storage Tanks*

AISC *Steel Construction Manual*¹

AMCA 801:2001², *Industrial Process/Power Generation Fans — Specifications and Guidelines*

ANSI/ISA-5.1³, *Instrumentation Symbols and Identification*

ANSI/ISA-77.82.01; *Selective Catalytic Reduction (SCR) Control Systems*

ASME *Boiler and Pressure Vessel Code (BPVC), Section VIII: Rules for Construction of Pressure Vessels, Division 1*⁴

ASME B31.3, *Process Piping*

ASTM A123⁵, *Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products*

ASTM A143, *Standard Practice for Safeguarding Against Embrittlement of Hot-Dip Galvanized Structural Steel Products and Procedure for Detecting Embrittlement*

ASTM A153, *Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*

ASTM A384, *Standard Practice for Safeguarding Against Warpage and Distortion During Hot-Dip Galvanizing of Steel Assemblies*

ASTM B633, *Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel*

AWS D1.1/D1.1M⁶, *Structural Welding Code — Steel*

AWS D14.6/D14.6M, *Specification for Welding of Rotating Elements of Equipment*

CGA G-2.1/ANSI K61.1⁷, *American National Standard Safety Requirements for the Storage and Handling of Anhydrous Ammonia*

EN 13480⁸ (all parts), *Metallic industrial piping*

International Building Code (IBC)⁹

¹ American Institute of Steel Construction, One East Wacker Drive, Suite 700, Chicago, Illinois 60601-1802, www.aisc.org.

² Air Movement and Control Association International, Inc., 30 W. University Drive, Arlington Heights, Illinois 60004, www.amca.org.

³ The International Society of Automation 67 T.W. Alexander Drive, P.O. Box 12277, Research Triangle Park, North Carolina 27709, www.isa.org.

⁴ ASME International, 2 Park Avenue, New York, New York 10016-5990, www.asme.org.

⁵ ASTM International, 100 Barr Harbor Drive, West Conshohocken, Pennsylvania 19428, www.astm.org.

⁶ American Welding Society, 8669 NW 36 Street, #130, Miami, Florida 33166-6672, www.aws.org.

⁷ Compressed Gas Association, 14501 George Carter Way #103, Chantilly, Virginia 20151, www.cganet.com.

⁸ European Committee for Standardization, Avenue Marnix 17, B-1000 Brussels, Belgium, www.cen.eu.

⁹ International Code Council, 500 New Jersey Avenue, NW, 6th Floor, Washington, D.C. 20001, www.iccsafe.org.

ISO 1461¹⁰ *Hot dip galvanized coatings on fabricated iron and steel articles — Specifications and test methods*

ISO 8501-1, *Preparation of steel substrates before application of paints and related products — Visual assessment of surface cleanliness — Part 1: Rust grades and preparation grades of uncoated steel substrates and of steel substrates after overall removal of previous coatings*

ISO 10684, *Fasteners — Hot dip galvanized coatings*

National Board Inspection Code Data Reports¹¹

NFPA 70¹², National Electrical Code

SSPC SP 6¹³/NACE No. 3, *Joint Surface Preparation Standard: Commercial Blast Cleaning*

40 CFR Part 60¹⁴; *United States Code of Federal Regulations – Standards of Performance for New Stationary Sources*

UL¹⁵, Underwriters Laboratories, Inc.

3 Terms, Definitions, and Abbreviations

3.1 Definitions

For the purposes of this document, the following terms and definitions apply.

3.1.1

ammonium bisulfate

ammonium sulfate

Compounds formed when ammonia from ammonia or urea injection into a flue gas stream combine with sulfur trioxide. These compounds may foul heat transfer surface, deactivate the catalyst, and increase particulate emissions.

3.1.2

ammonia breakthrough

The point at which increasing the NH₃/NO_x molar ratio does not significantly reduce the amount of NO_x.

3.1.3

ammonia flow control unit (AFCU)

A unit, typically skid mounted, that is used to vaporize ammonia, pump air, and mix the ammonia and air prior to being sent to the ammonia injection grid (AIG). The AFCU is also known as the reactant control and dilution system (RCDS).

3.1.4

Ammonia/NO_x ratio

The molar ratio of injected ammonia to the inlet NO_x in the flue gas stream.

¹⁰ International Organization for Standardization, 1, ch. de la Voie-Creuse, Case postale 56, CH-1211, Geneva 20, Switzerland, www.iso.org.

¹¹ The National Board of Boiler and Pressure Vessel Inspectors, 1055 Crupper Avenue, Columbus, OH 43229, www.nationalboard.org.

¹² National Fire Protection Association, 1 Batterymarch Park, Quincy, Massachusetts, 02169-7471, www.nfpa.org.

¹³ The Society for Protective Coatings, 40 24th Street, 6th Floor, Pittsburgh, Pennsylvania 15222, www.sspc.org.

¹⁴ U.S. National Archives and Records Administration, 700 Pennsylvania Avenue, NW, Washington, DC 20408, www.archives.gov.

¹⁵ UL LLC, 333 Pfingsten Road, Northbrook, Illinois 60062 USA. www.ul.com.