

Flare Details for Petroleum, Petrochemical, and Natural Gas Industries

API STANDARD 537
FOURTH EDITION, NOVEMBER 2024



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Copyright © 2024 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

1	Scope	1
2	Normative References	1
3	Terms, Definitions, Acronyms, and Abbreviations	2
3.1	Terms and Definitions (General)	2
3.2	Specific Terms and Definitions	3
3.3	Acronyms and Abbreviations	10
4	Design	10
4.1	General	10
4.2	System Design	11
4.3	Process Definition.....	14
4.4	Types of Flares	15
4.5	Flare Burners	15
4.6	Mechanical Design	16
4.7	Pilots.....	17
4.8	Pilot Ignition Systems.....	18
4.9	Pilot Flame Detection.....	19
4.10	Piping	19
4.11	Auxiliary Components	20
4.12	Control of Fluid Injection for Smoke Suppression	20
4.13	Sizing.....	21
5	Mechanical Details—Elevated Flares	23
5.1	Mechanical Design—Design Loads	23
5.2	Design Details	27
5.3	Flanges.....	28
5.4	Materials of Construction.....	29
5.5	Welding	30
5.6	Inspection	30
5.7	Surface Preparation and Protection.....	31
5.8	Attachments	31
5.9	Aircraft Warning Lighting.....	31
5.10	Platforms and Ladders	31
6	Mechanical Details—Enclosed-flame Flares	32
6.1	Combustion Chamber	32
6.2	Burners	33
6.3	Burner Piping	33
6.4	Pilots.....	34
6.5	Wind Fence	34
6.6	Radiation Shielding.....	34
Annex A (informative) Flare Equipment Overview		35
Annex B (informative) Components of Multi-burner (Point) Staged Flare Equipment		103
Annex C (informative) Enclosed-flame Flares		106
Annex D (informative) Offshore Flare Systems		120
Annex E (informative) Instructions for Flare Datasheets		129
Annex F (informative) Flare Datasheets		141
Annex G (informative) General Flame Information		188
Annex H (informative) Migration of Technical Content from API Standard 521, Seventh Edition....		191
Annex I (informative) Use of Unmanned Aerial Systems for Flare Inspections		224
Annex J (informative) Purchaser’s Checklist		227

Bibliography	229
--------------------	-----

Figures

A.1	Flare Type Selection	36
A.2	Self-supported Structure.....	38
A.3	Guyed-support Structure	39
A.4	Typical Fixed Derrick Support Structure.....	40
A.5	Demountable Derrick with Multiple-section Riser.....	41
A.6	Demountable Derrick with Single-section Riser.....	43
A.7	Horizontal Flares	44
A.8	Enclosed-flame Flare	44
A.9	Multi-point Staged Flare	45
A.10	Multi-point Flare Staging Curve.....	46
A.11	Air-assisted Flare	47
A.12	Flare Pilot Assembly.....	67
A.13	Flame Front Generator Panel Arrangement.....	72
A.14	Flare/Pilot/Flame Front Generator Panel Arrangement.....	73
A.15	Purge Reduction Device—Buoyancy Seal	87
A.16	Centrifugal Fan.....	91
A.17	Vaneaxial Fan	92
A.18	Simplified Control Diagram for a Three-stage Flare System.....	99
B.1	Multi-burner Staged Flares	103
C.1	Typical Enclosed Flare Staged to Elevated Flare	107
C.2	Enclosed-flame Flare	108
C.3	Wind Fence for an Enclosed-flame Flare.....	112
H.1	Dimensional References for Sizing a Flare Stack	201
H.2	Flame Center for Flares and Ignited Vents—Horizontal Distance, x_c (SI Units)	206
H.3	Flame Center for Flares and Ignited Vents—Horizontal Distance, x_c (USC Units)	207
H.4	Flame Center for Flares and Ignited Vents—Vertical Distance, y_c (SI Units)	208
H.5	Flame Center for Flares and Ignited Vents—Vertical Distance, y_c (USC Units)	209
H.6	Flame Length vs. Heat Release—Industrial Sizes and Releases (SI Units)	220
H.7	Flame Length vs Heat Release—Industrial Sizes and Releases (USC Units).....	221
H.8	Approximate Flare Distortion Due to Lateral Wind on Jet Velocity from Flare Stack	222

Tables

1	Number of Pilots for Single-point Flares	18
2	Allowable Forces and Moments for Flare Nozzles	26
3	Flange-bolting Dimensions for Flare Burners Larger than DN 600 (NPS 24)	29
A.1	Suggested Steam Injection Rates	53
A.2	Combustion Noise Spectrum.....	57
A.3	Typical Combustion Noise Spectrum	63
A.4	Troubleshooting of Pilots.....	70
A.5	Troubleshooting of Ignition Systems	79
A.6	Troubleshooting of Flame Detection Systems	84
A.7	Troubleshooting of Purge Gas Conservation Seals—Buoyancy Type	88
A.8	Troubleshooting of Blower Systems	93
A.9	Troubleshooting of Blower Staging and Control Systems.....	97
A.10	Troubleshooting of Pressure-staging Equipment.....	101
C.1	Troubleshooting of Enclosed-flame Flare Systems	119
H.1	API 537 to API 521 Cross-reference	191
H.2	Exposure Times Necessary to Reach the Pain Threshold	194
H.3	Recommended Design Thermal Radiation for Personnel	195
H.4	Radiation from Gaseous Diffusion Flames	219
J.1	Flare Details for Petroleum, Petrochemical, and Natural Gas Industries	227

Notice

Instructions for Submitting a Proposed Revision to This Standard Under Continuous Maintenance

The American Petroleum Institute maintains this standard under continuous maintenance procedures. These procedures establish a document program for regular publication of addenda or revisions, including timely and documented consensus action on requests for revisions to any part of the standard. Proposed revisions shall be submitted to the Director, Standards Department, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Introduction

A flare is a critical mechanical component of a complete system design intended for the safe, reliable, and efficient discharge and combustion of hydrocarbons from pressure-relieving and vapor-depressurizing systems.

The high-level safety and operating goals of a flare are summarized as follows:

- to provide safe, reliable, and efficient discharge and combustion of hydrocarbons with a high combustion efficiency;
- to ensure that the discharged hydrocarbons burn with stable combustion over the entire defined operating range;
- to ensure a continuity of the flare flame under severe weather conditions;
- to ensure that ground-level concentrations of specified compounds do not exceed environmental limits;
- to ensure that the back pressure does not exceed the maximum allowable;
- to ensure that velocity throughout the flare piping and the flare burner does not exceed the maximum specified;
- to ensure that the opacity limit at the smokeless flow rate range does not exceed that defined;
- to ensure that the flare radiation intensity does not exceed the maximum allowable;
- to ensure that noise levels do not exceed the maximum permissible.

For new designs, the development of a design can be advanced using the guidance and examples of good engineering practice that are identified in this standard.

A flare design basis is developed in consideration of the performance expectations, the functional requirements, and mechanical details required to fulfill the safety and operating goals established for each application. Section 4 provides the basis for design and functional requirements related to the primary components critical to fulfilling these safety and operating goals. Section 5 and Section 6 provide requirements more specific to the arrangement and mechanical details of design.

The functional requirements in this standard are supported by the technical guidance provided in Annex A, Annex B, Annex C, and Annex D. The technical guidance provided in the informative annexes addresses alternative designs or techniques and provides good practices on the basis of which, through sound engineering judgment, the practitioner can make appropriate design decisions and selections.

Datasheets are provided in Annex F in order to properly communicate and preserve the finalized basis of design and requirements. Annex E provides instructions for completing the flare datasheets in Annex F.

Users of this standard should be aware that further or differing requirements may be needed for individual applications. This standard is not intended to inhibit a vendor from offering, or the purchaser from accepting, alternative equipment or engineering solutions for the individual application. This may be particularly applicable where there is innovative or developing technology. Where an alternative is offered, the vendor should identify any variations from this standard and provide details.

The International System of Units (SI) is used in this standard. Where practical, United States customary (USC) units are included in brackets for information.

A bullet (●) at the beginning of a section or subsection indicates that either a decision is required or further information is to be provided by the purchaser. This information should be indicated on datasheets (see examples in Annex F) or stated in the inquiry or purchase order.

The Fourth Edition of API Standard 537 contains the completed migration and integration of technical content from API Standard 521, Sixth Edition, initiated with API Standard 537, Third Edition, Addendum 1. In the Fourth Edition of API Standard 537, the subject matter previously contained in Annex G (added in Addendum 1) is incorporated throughout the standard under the appropriate subject headings.

Annex G is completely revised relative to Addendum 1 and now contains new subject matter related to flame properties. Three additional annexes have been provided (Annex H, Annex I, and Annex J) together with revised datasheets that now include multi-point staged ground flares (Annex F) and instructions for their use (Annex E). Annex H continues the migration of technical content, however now from the Seventh Edition of API Standard 521. Annex I provides informative content on the use of unmanned aerial systems for flare inspections, and Annex J contains a new component to the standard; a purchaser's checklist which is complementary to the datasheets for the purchaser's specification of requirements.

Flare Details for Petroleum, Petrochemical, and Natural Gas Industries

1 Scope

This standard specifies requirements and provides guidance for the selection, design, specification, operation, and maintenance of flares and related combustion and mechanical components used in pressure-relieving and vapor-depressurizing systems for petroleum, petrochemical, and natural gas industries. Although this standard is primarily intended for onshore facilities, guidance related to offshore applications is included.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Recommended Practice 2A-WSD:2000, *Planning, Designing and Constructing Fixed Offshore Platforms—Working Stress Design*

API Standard 521, *Pressure-relieving and Depressuring Systems*

API Standard 560, *Fired Heaters for General Refinery Service*

ASME B16.5 ¹, *Pipe Flanges and Flanged Fittings NPS 1/2 Through NPS 24 Metric/Inch Standard*

ASME STS-1, *Steel Stacks*

ASTM A123/A123M ², *Standard Specification for Zinc (Hot Dip Galvanized) Coatings on Iron and Steel Products*

ASTM A143/A143M, *Standard Practice for Safeguarding Against Embrittlement of Hot-Dip Galvanized Structural Steel Products and Procedure for Detecting Embrittlement*

ASTM A153/A153M, *Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*

ASTM A384/A384M, *Standard Practice for Safeguarding Against Warpage and Distortion During Hot-Dip Galvanizing of Steel Assemblies*

ASTM A385/A385M, *Standard Practice for Providing High-Quality Zinc Coatings (Hot-Dip)*

ASTM A475-03, *Standard Specification for Zinc-Coated Steel Wire Strand*

ASTM A586-04a, *Standard Specification for Zinc-Coated Parallel and Helical Steel Wire Structural Strand*

ASTM B633, *Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel*

EN 1092-1:2007 ³, *Flanges and their joints—circular flanges for pipes, valves, fittings and accessories, PN designated—Part 1: Steel flanges*

¹ ASME International, Two Park Avenue, New York, New York 10016, www.asme.org.

² ASTM International, 100 Barr Harbor Drive, West Conshohocken, Pennsylvania 19428, www.astm.org.

³ CEN European Committee for Standardization, Rue de la Science 23, B-1040 Brussels, Belgium, www.cencenelec.eu.