

# Form-wound Squirrel Cage Induction Motors—375 kW (500 Horsepower) and Larger

API STANDARD 541  
FIFTH EDITION, DECEMBER 2014

REAFFIRMED, MAY 2021



American  
Petroleum  
Institute

## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Classified areas may vary depending on the location, conditions, equipment, and substances involved in any given situation. Users of this Standard should consult with the appropriate authorities having jurisdiction.

Users of this Standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Where applicable, authorities having jurisdiction should be consulted.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and practices in determining the appropriateness of applying the Standard. At all times users should employ sound business, scientific, engineering, and judgment safety when using this Standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

## Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001, [standards@api.org](mailto:standards@api.org).

## Contents

	Page
<b>1 General</b> .....	<b>1</b>
1.1 Scope .....	1
1.2 Alternative Designs .....	1
1.3 Dimensions and Standards .....	1
1.4 Conflicting Requirements .....	2
<b>2 Normative References</b> .....	<b>2</b>
<b>3 Terms and Definitions</b> .....	<b>6</b>
<b>4 Basic Design</b> .....	<b>8</b>
4.1 General .....	8
4.2 Electrical Design .....	10
4.3 Winding and Insulation Systems .....	14
4.4 Mechanical Design .....	16
<b>5 Accessories</b> .....	<b>40</b>
5.1 Terminal Boxes .....	40
5.2 Winding Temperature Detectors .....	42
5.3 Bearing Temperature Detectors .....	42
5.4 Space Heaters .....	42
5.5 Screens and Filters .....	43
5.6 Alarms and Control Devices for Motor Protection .....	43
5.7 Ground Connectors .....	44
5.8 Vibration Detectors .....	44
<b>6 Inspection, Testing, and Preparation for Shipment</b> .....	<b>45</b>
6.1 General .....	45
6.2 Inspection .....	46
6.3 Final Testing .....	47
6.4 Preparation for Shipment .....	61
<b>7 Guarantee and Warranty</b> .....	<b>62</b>
<b>8 Vendor's Data</b> .....	<b>63</b>
8.1 Proposals .....	63
8.3 Contract Data .....	65
8.5 Drawings .....	66
8.6 Final Data .....	68
8.7 Instruction Manuals .....	68
<b>Annex A Data sheets</b> .....	<b>70</b>
<b>Annex B Vendor Drawing and Data Requirements</b> .....	<b>97</b>
<b>Annex C Worksheet Guide</b> .....	<b>101</b>
<b>Annex D Procedure for Determination of Residual Unbalance</b> .....	<b>144</b>
<b>Annex E Procedure and Guidance for Determining the Allowable Resultant Vector Change During a Heat Run Test</b> .....	<b>152</b>
<b>Annex F Alternate Criteria for Defining a Well Damped Resonance</b> .....	<b>155</b>
<b>Annex G AC Stator Form Coil Data</b> .....	<b>157</b>
<b>Bibliography</b> .....	<b>160</b>

# Contents

Page

## Figures

1	Typical Rotor Mode Shapes .....	27
2	Shaft Vibration Limits (Metric Units, Relative to Bearing Housing Using Noncontact Vibration Probes) for All Hydrodynamic Sleeve Bearing Machines with the Machine Securely Fastened to a Massive Foundation. ....	49
3	Shaft Vibration Limits (U.S. Customary Units, Relative to Bearing Housing Using Noncontact Vibration Probes) for All Hydrodynamic Sleeve Bearing Machines with the Machine Securely Fastened to a Massive Foundation. ....	49
4	Bearing Housing Radial and Axial Vibration Limits (Metric Units) for Sleeve and Antifriction Bearing Machines with the Machine Securely Fastened to a Massive Foundation. ....	50
5	Bearing Housing Radial and Axial Vibration Limits (U.S. Customary Units) for Sleeve and Antifriction Bearing Machines with the Machine Securely Fastened to a Massive Foundation. ....	50
6	Adjacent Core .....	57
D.1	(Blank) Residual Unbalance Worksheet. ....	146
D.2	(Blank) Residual Unbalance Polar Plot Worksheet. ....	147
D.3	Sample Residual Unbalance Worksheet for Left Plane .....	148
D.4	Sample Residual Unbalance Polar Plot Worksheet for Left Plane .....	149
D.5	Sample Residual Unbalance Worksheet for Right Plane .....	150
D.6	Sample Residual Unbalance Polar Plot Worksheet for Right Plane .....	151
E.1	Example of a Polar Plot Complying with 6.3.3.13 .....	153
E.2	Example of a Polar Plot Not Complying with 6.3.3.13 .....	153
E.3	Example of a Polar Plot Not Complying with 6.3.3.1 .....	154
E.4	Possible Option if a Motor Fails Basic Specification Criteria .....	154
F.1	Evaluation of Amplification Factor (AF) from Speed Amplitude Plots .....	156

## Tables

1	Voltage Ratings for Three Phase 60 Hz Systems .....	11
2	Voltage Ratings for Three Phase 50 Hz Systems (British Standards) .....	11
3	Voltage Ratings for Three Phase 60 Hz Systems (General) .....	11
4	Starting Capabilities .....	13
5	Machine Enclosures and Corresponding NEMA or IEC Specifications .....	17
6	Maximum Severity of Defects in Castings .....	47
7	DC Test Voltages for Insulation Resistance and Determination of Polarization Index .....	52
8	DC High-Potential Test Voltage Levels .....	59

# Form-wound Squirrel Cage Induction Motors— 375 kW (500 Horsepower) and Larger

## 1 General

### 1.1 Scope

**1.1.1** This standard covers the minimum requirements for special purpose form-wound squirrel cage induction motors 375 kW (500 hp) and larger for use in petroleum, chemical, and other industry applications. This standard can also be used for induction generators by substituting “generator” for “motor” where applicable.

Notes following a paragraph in Sections 1 through 8 are informational only and are not enforceable as part of this standard.

**NOTE** A special purpose machine typically has one or more of the following characteristics:

- 1) is in an application for which the equipment is designed for uninterrupted, continuous operation in critical service, and for which there is usually no installed spare equipment;
- 2) is larger than 2250 kW (3000 hp) for speeds 1800 rpm and below;
- 3) is rated 600 kW (800 hp) or greater for two pole (3000 rpm or 3600 rpm) machines of totally enclosed construction, or rated 930 kW (1250 hp) or greater for two pole machines of open or guarded construction (including machines with WP-I or WP-II type enclosures);
- 4) drives a high-inertia load (in excess of the load  $Wk^2$  listed in IEC MG 1, Part 20);
- 5) uses an adjustable speed drive (ASD) as a source of power;
- 6) is an induction generator;
- 7) is a vertical machine rated 375 kW (500 hp) or greater; or
- 8) operates in abnormally hostile environments.

A round bullet (●) at the beginning of a paragraph indicates that either a decision is required or further information is to be provided by the purchaser. This information shall be indicated on the datasheets (see Annex A); otherwise, it shall be stated in the quotation request or in the order.

A diamond bullet (◆) at the start of a paragraph indicates additional requirements for motors applied with ASDs.

**1.1.2** This standard requires the purchaser to specify details and features. The purchaser shall complete the datasheets in Annex A.

**NOTE** Guidance for completion of the datasheets is provided in Annex C.

### 1.2 Alternative Designs

The vendor may offer alternative designs (see 8.1.9).

### 1.3 Dimensions and Standards

- **1.3.1** Both the metric (SI) and U.S. customary (USC) system of units and dimensions are used in this standard. Data, drawings, and hardware (including fasteners) related to equipment supplied to this standard shall use the