

General Purpose Form-wound Squirrel Cage Induction Motors—185 kW (250 hp) through 2240 kW (3000 hp)

API STANDARD 547
SECOND EDITION, MAY 2017

EFFECTIVE DATE: NOVEMBER 1, 2017



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Users of this Standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

Copyright reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Currently in preview, click buy full version

Contents

	Page
1 Scope	1
1.1 General	1
1.2 Usual Service Conditions	2
1.3 Unusual Service Conditions	2
1.4 Dimensions and Standards	2
2 Normative References	3
3 Terms and Definitions	4
4 Basic Design	6
4.1 General	6
4.2 Electrical Design	7
4.3 Winding and Insulation Systems	8
4.4 Mechanical Design	9
4.5 Vertical Motors	15
5 Accessories	16
5.1 Terminal Boxes	16
5.2 Winding Temperature Detectors	17
5.3 Bearing Temperature Detectors	17
5.4 Space Heaters	17
5.5 Ground Connectors	18
5.6 Auxiliary Device Installation	18
6 Inspection, Testing, and Preparation for Shipment	18
6.1 Final Testing	18
6.2 Preparation for Shipment	19
7 Guarantee and Warranty	20
8 Vendor Data	20
8.1 Proposals	20
8.2 Contract Data	21
Annex A (informative) Use of API Program by Licensees	24
Annex B (normative) Data Sheets	27
Annex C (informative) Data Sheet Guide	34
Bibliography	53
Tables	
C.1 Standard IEC and NEMA Power Ratings	36
C.2 List of Liquids with an Autoignition Temperature (AIT) of Less Than 200 °C, Requiring Space Heaters with Heater Element Surface Temperature Less Than 160 °C	41

Currently in preview, click buy full version

General Purpose Form-wound Squirrel Cage Induction Motors— 185 kW (250 hp) through 2240 kW (3000 hp)

1 Scope

1.1 General

1.1.1 This standard covers the requirements for form-wound induction motors for use in general purpose petroleum, chemical and other industrial severe duty applications and with the following characteristics:

- a) rated 185 kW [250 horsepower (hp)] through 2240 kW (3000 hp) for four-, six-, and eight-pole speeds;
- b) rated less than 600 kW (800 hp) for two-pole (3000 or 3600 RPM) motors of totally enclosed construction;
- c) rated less than 930 kW (1250 hp) for two-pole motors of WP-II type enclosures;
- d) rated less than 375 kW (500 hp) for vertical motors;
- e) drive centrifugal loads;
- f) drive loads having inertia values not exceeding those listed in NEMA MG-1 Part 20; and
- g) operated as motors, not induction generators.

NOTE Motors larger than that covered above and motors in other applications should be specified in accordance with API 541.

1.1.2 Application of the API Monogram—If the product is manufactured at a facility licensed by API and it is intended to be supplied bearing the API Monogram, the requirements of Annex A apply.

1.1.3 A datasheet is provided in Annex B. The purchaser is not required to complete and provide the datasheet for pre-configured or catalog based motors manufactured with standard features. However, the purchaser shall provide the completed datasheet to specify motor requirements for a specific application and/or with options and features beyond the above description. A datasheet guide, which provides detailed information to assist with completion of the datasheet, is provided in Annex C.

1.2 Usual Service Conditions

Unless otherwise specified, motors conforming to this standard shall be suitable for operation within their rating under the following service conditions:

- a) exposure to an ambient temperature in the range of $-18\text{ }^{\circ}\text{C}$ to $40\text{ }^{\circ}\text{C}$ ($0\text{ }^{\circ}\text{F}$ to $104\text{ }^{\circ}\text{F}$);
- b) exposure to a maximum altitude of 1000 m (3300 ft) above sea level;
- c) indoor or outdoor severe duty applications, such as humid, chemical (corrosive), or salty atmospheres;
- d) horizontal foot mounted;
- e) installation in a Class I, Zone 2 or Division 2 hazardous (classified) location;
- f) constant frequency sinusoidal input power;
- g) not subject to frequent transient overvoltages (e.g. switching surges, lightning surges); and
- h) direct coupled without a gear, fluid coupling, or other speed modification device.

1.3 Unusual Service Conditions

Unusual service conditions shall be brought to the attention of those responsible for the design, manufacture, application, and operation of the motor. Among such unusual conditions are:

- a) exposure to:
 - 1) combustible, explosive, abrasive, or conductive dust;
 - 2) dirty operating conditions where the accumulation of dirt will interfere with normal ventilation;
 - 3) nuclear radiation;
 - 4) abnormal shock, vibrations, or mechanical loading from external sources;
 - 5) abnormal axial or side thrust imposed on the motor shaft;
 - 6) altitude or ambient temperature outside the range covered in 1.2;
 - 7) reciprocating or positive displacement loads; and
 - 8) offshore applications;
- b) conditions under which the variation from rated voltage or frequency, or both, exceeds the limits given in NEMA MG 1 (or IEC 60034-1);
- c) conditions under which the AC supply voltage is unbalanced by more than the limits given in NEMA MG 1 (or IEC 60034-1);
- d) operation at speeds other than rated speed;
- e) operation on an adjustable speed drive;
- f) load inertia greater than and/or starting conditions more severe than given in NEMA MG 1;
- g) orientation of a foot-mounted motor in any position other than horizontal;
- h) vertical flange-mounted motor;
- i) coupled through a belt, gear, fluid coupling or other speed modification device; and
- j) requirements for enclosure purging or pre-start ventilation.

NOTE A bullet (•) at the beginning of a paragraph indicates that either a decision is required or further information is to be provided by the purchaser. This information should be indicated on the datasheets (see Annex B); otherwise it should be stated in the quotation request or in the order.

1.4 Dimensions and Standards

- 1.4.1 Both the SI and U.S. customary system of units and dimensions are used in this standard. Data, drawings, and hardware (including fasteners) related to equipment supplied to this standard shall use the system of units specified by the purchaser. An alternate system of units for hardware (including fasteners and flanges) may be substituted if mutually agreed upon by the purchaser and the vendor.