

Tank Inspection, Repair, Alteration, and Reconstruction

API STANDARD 653
FIFTH EDITION, NOVEMBER 2014

ADDENDUM 1, APRIL 2018
ADDENDUM 2, MAY 2020
ADDENDUM 3, NOVEMBER 2023



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Classified areas may vary depending on the location, conditions, equipment, and substances involved in any given situation. Users of this standard should consult with the appropriate authorities having jurisdiction.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Notice

Instructions for Submitting a Proposed Revision to This Standard Under Continuous Maintenance.

The American Petroleum Institute maintains this standard under continuous maintenance procedures. These procedures establish a documented program for regular publication of addenda or revisions, including timely and documented consensus action on requests for revisions to any part of the standard. See Annex I for additional information. Proposed revisions shall be submitted to the Director, Standards Department, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

Portions of this publication have been changed from the previous edition. The location of changes have been marked with a bar in the margin, as shown to the left of this paragraph. In some cases, the changes are significant, while in other cases the changes reflect minor editorial adjustments such as renumbering of a section/subsection or figure/table (the references *within the text* that have been subsequently updated are not marked). The bar notations in the margins are provided as an aid to users, but API makes no warranty as to the accuracy of such bar notations.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to the review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 332-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

The American Petroleum Institute maintains this standard under continuous maintenance procedures. These procedures establish a documented program for regular publication of addenda or revisions, including timely and documented consensus action on requests for revisions to any part of the standard. See Annex I for additional information.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Currently in preview, click buy full version

Contents

	Page
1 Scope	1-1
1.1 Introduction	1-1
1.2 Compliance with This Standard	1-1
1.3 Jurisdiction	1-2
1.4 Safe Working Practices	1-2
2 Normative References	2-1
3 Terms and Definitions	3-1
4 Suitability for Service	4-1
4.1 General	4-1
4.2 Tank Roof Evaluation	4-1
4.3 Tank Shell Evaluation	4-2
4.4 Tank Bottom Evaluation	4-15
4.5 Tank Foundation Evaluation	4-19
5 Brittle Fracture Considerations	5-1
5.1 General	5-1
5.2 Basic Considerations	5-1
5.3 Assessment Procedure	5-1
6 Inspection	6-1
6.1 General	6-1
6.2 Inspection Frequency Considerations	6-1
6.3 Inspections from the Outside of the Tank	6-1
6.4 Internal Inspection	6-2
6.5 Alternative to Internal Inspection to Determine Bottom Thickness	6-8
6.6 Preparatory Work for Internal Inspection	6-8
6.7 Inspection Checklists	6-8
6.8 Records	6-8
6.9 Reports	6-8
6.10 Nondestructive Examination (NDE)	6-10
7 Materials	7-1
7.1 General	7-1
7.2 New Materials	7-1
7.3 Original Materials for Reconstructed Tanks	7-1
7.4 Welding Consumables	7-1
8 Design Considerations for Reconstructed Tanks	8-1
8.1 General	8-1
8.2 New Weld Joints	8-1
8.3 Existing Weld Joints	8-1
8.4 Shell Design	8-1
8.5 Shell Penetrations	8-1
8.6 Windgirders and Shell Stability	8-2
8.7 Roofs	8-2
8.8 Seismic Design	8-2

Contents

	Page
9 Tank Repair and Alteration	9-1
9.1 General	9-1
9.2 Removal and Replacement of Shell Plate Material	9-4
9.3 Shell Repairs Using Lap-welded Patch Plates	9-4
9.4 Repairs Using Nonmetallic Materials	9-8
9.5 Repair of Defects in Shell Plate Material	9-8
9.6 Alteration of Tank Shells to Change Shell Height	9-9
9.7 Repair of Defective Welds	9-9
9.8 Repair of Shell Penetrations	9-9
9.9 Addition or Replacement of Shell Penetrations	9-9
9.10 Alteration of Existing Shell Penetrations	9-11
9.11 Repair of Tank Bottoms	9-13
9.12 Repair of Fixed Roofs	9-21
9.13 Repair of Floating Roofs	9-22
9.14 Repair or Replacement of Floating Roof Perimeter Seals	9-22
9.15 Hot Taps	9-23
10 Dismantling and Reconstruction	10-1
10.1 General	10-1
10.2 Cleaning and Gas Freeing	10-1
10.3 Dismantling Methods	10-1
10.4 Reconstruction	10-3
10.5 Dimensional Tolerances	10-5
11 Welding	11-1
11.1 Welding Qualifications	11-1
11.2 Identification and Records	11-1
11.3 Preheat or Controlled Deposition Welding Methods as Alternatives to Post-weld Heat Treatment (PWHT)	11-1
11.4 Welding Safety	11-3
11.5 Friction Stud Welding	11-3
12 Examination and Testing	12-1
12.1 NDE	12-1
12.2 Radiographs	12-4
12.3 Hydrostatic Testing	12-5
12.4 Leak Tests	12-8
12.5 Settlement Survey During Hydrostatic Testing	12-9
13 Marking and Recordkeeping	13-1
13.1 Nameplates	13-1
13.2 Recordkeeping	13-3
13.3 Certification	13-3
Annex A (informative) Background on Past Editions of API Welded Storage Tank Standards	A-1
Annex B (normative) Evaluation of Tank Bottom Settlement	B-1
Annex C (informative) Checklists for Tank Inspection	C-1

Contents

	Page
Annex D (normative) Authorized Inspector Certification	D-1
Annex E (Intentionally Left Blank)	E-1
Annex F (normative) NDE Requirements Summary	F-1
Annex G (informative) Qualification of Tank Bottom Examination Procedures and Personnel	G-1
Annex H (informative) Similar Service Assessment	H-1
Annex I (informative) Inquiries and Suggestions for Change	I-1
Annex J (normative, if specified by the purchaser) Shell Plate Repairs Using Nonmetallic Materials	J-1
Annex R (informative) Additional References for Tank Inspection Guidance	R-1
Annex S (normative) Austenitic Stainless Steel Storage Tanks	S-1
Annex SC (normative) Stainless and Carbon Steel Mixed Materials Storage Tanks	SC-1
Annex X (normative) Duplex Stainless Steel Storage Tanks	X-1
Annex Y (informative) Bibliography	Y-1

Figures

4.1 Inspection of Corrosion Areas	4-4
4.2 Pit Measurement	4-5
5.1 Brittle Fracture Considerations	5-2
5.2 Exemption Curve for Tanks Constructed from Carbon Steel of Unknown Material Specification	5-3
9.1 Acceptable Details for Replacement of Shell Plate Material	9-2
9.2 Details for Door Sheets in Riveted Seam Tank	9-4
9.3 Details for Door Sheets in Lap-welded Seam Tank	9-5
9.4 Details for Door Sheets in Butt-welded Shell Seam Tank—No Vertical Seam Offset	9-5
9.5 Details for Door Sheets in Butt-welded Shell Seam Tank—Vertical Seam Offset	9-6
9.6 Lapped Patch Repair Plate at the External Shell-to-bottom Joint	9-7
9.7 Typical Details for Addition of Reinforcing Plate to Existing Shell Penetration	9-10
9.8 Typical Details for Addition of “Tombstone” Shape Reinforcing Plate to Existing Shell Penetration	9-10
9.9 Method for Raising Shell Nozzles	9-12
9.10 Details for Installing a New Bottom Through an Existing Tapered Tombstone	9-13
9.11 Details for Installing a New Bottom Through an Existing Tombstone Reinforcing Plate with a Tapered Shell	9-14
9.12 Detail for Installing a New Bottom Through an Existing Tombstone Reinforcing Plate	9-15
9.13a Typical Welded-on Patch Plates on Tank Bottom Plates, in SI Units	9-16
9.13b Typical Welded-on Patch Plates on Tank Bottom Plates, in USC Units	9-17
9.14 Hot Tap for Tanks	9-25
10 Tank Shell and Bottom Cut Locations	10-2
10.1 Nameplate	13-1
13.2 Certification Forms	13-4
B.1 Measurements of Shell Settlement (External)	B-2
B.2 Measurements of Bottom Settlement (Internal) Tank Out-of-service	B-2

	Page	
B.3	Graphical Representation of Tank Shell Settlement per B.2.2.4.	B-3
B.4	Graphical Representation of Shell Settlement per B.2.2.5 (Tilt Plan Not Described by an Optimal Cosine Curve)	B-4
B.5	Graphical Representation of Shell Settlement per B.2.2.5 (Tilt Plane Described by an Optimal Cosine Curve)	B-6
B.6	Edge Settlement	B-7
B.7	Correction for Measured Edge Settlement	B-8
B.8	Bottom Settlement Near Shell.	B-9
B.9	Localized Bottom Depressions or Bulges Remote from Shell	B-10
B.10a	Localized Tank Bottom Settlement Limits for Single Pass Welds, in SI Units	B-13
B.10b	Localized Tank Bottom Settlement Limits for Single Pass Welds, in USC Units	B-14
B.11a	Maximum Allowable Edge Settlement for Areas with Bottom Lap Welds Approximately Parallel to the Shell, in SI Units	B-15
B.11b	Maximum Allowable Edge Settlement for Areas with Bottom Lap Welds Approximately Parallel to the Shell, in USC Units	B-16
B.12a	Maximum Allowable Edge Settlement for Areas with Bottom Lap Welds Approximately Perpendicular to the Shell, in SI Units.	B-17
B.12b	Maximum Allowable Edge Settlement for Areas with Bottom Lap Welds Approximately Perpendicular to the Shell, in USC Units.	B-18
B.13	Edge Settlement with a Lap Weld at an Arbitrary Angle to the Shell	B-18
H.1	Steps in Conducting Similar Service Assessment.	H-6
H.2	Example Corrosion Rate Curves for Bottom of Storage Tank	H-7
H.3	Example Corrosion Rate Curves for Top Course of Storage Tank.	H-8
	Similar Service Assessment—Data Sheet	H-9
Tables		
4.1a	Maximum Allowable Shell Stresses, in SI Units	4-7
4.1b	Maximum Allowable Shell Stresses, in USC Units	4-8
4.2a	Joint Efficiencies for Beveled Joints, in SI Units	4-10
4.2b	Joint Efficiencies for Beveled Joints, in USC Units	4-10
4.3	Joint Efficiencies for Riveted Joints	4-13
4.4a	Bottom Plate Minimum Thickness, in SI Units	4-18
4.4b	Bottom Plate Minimum Thickness, in USC Units	4-18
4.5a	Annular Bottom Plate Thicknesses (Product Specific Gravity < 1.0), in SI Units	4-20
4.5b	Annular Bottom Plate Thicknesses (Product Specific Gravity < 1.0), in USC Units	4-20
6.1	Tank Safeguard	6-4
9.1a	Hot Tap Connection Sizes and Shell Plate Thicknesses, in SI Units	9-23
9.1b	Hot Tap Connection Sizes and Shell Plate Thicknesses, in USC Units	9-23
10.1a	Maximum Thicknesses on New Welds, in SI Units	10-3
10.1b	Maximum Thicknesses on New Welds, in USC Units	10-3
10.2a	Radii Tolerances, in SI Units.	10-5
10.2b	Radii Tolerances, in USC Units	10-5

	Page
11.1 Welding Methods as Alternatives to Post-weld Heat Treatment (PWHT) Qualification	
Thicknesses for Test Plates and Repair Grooves	11-6
A.1 Editions of API Standard 650 and its Precursor, API Standard 12C	A-1
C.1 Tank In-service Inspection Checklist	C-2
C.2 Tank Out-of-service Inspection Checklist	C-8
F.1 NDE Requirements Summary	F-1
G.1a Underside Pits, in SI Units	G-4
G.1b Underside Pits, in USC Units	G-4
G.2a Product-side Pits, in SI Units	G-5
G.2b Product-side Pits, in USC Units	G-5
G.3a Flaws Required to Qualify a Procedure or Operator, in SI Units	G-6
G.3b Flaws Required to Qualify a Procedure or Operator, in USC Units	G-6
G.4a Flaw Depth to Qualify a Procedure or Examiner, in SI Units	G-6
G.4b Flaw Depth to Qualify a Procedure or Examiner, in USC Units	G-6
G.5a Suggested Essential Variables for Qualification Tests, in SI Units	G-7
G.5b Suggested Essential Variables for Qualification Tests, in USC Units	G-8
H.1 Similar Service Product Classification	H-5
J.1 API Requirements in Addition to ASME PCC-2	J-2

Tank Inspection, Repair, Alteration, and Reconstruction

SECTION 1—SCOPE

1.1 Introduction

1.1.1 This standard covers steel storage tanks built to API 650 and its predecessor API 12C. It provides minimum requirements for maintaining the integrity of such tanks after they have been placed in service and addresses inspection, repair, alteration, relocation, and reconstruction.

1.1.2 The scope is limited to the tank foundation, bottom, shell, structure, roof, attached appurtenances, and nozzles to the face of the first flange, first threaded joint, or first welding-end connection. Many of the design, welding, examination, and material requirements of API 650 can be applied in the maintenance inspection, rating, repair, and alteration of in-service tanks. In the case of apparent conflicts between the requirements of this standard and API 650 or its predecessor API 12C, this standard shall govern for tanks that have been placed in service.

1.1.3 This standard has requirements given in two alternate systems of units. Any repairs shall comply with the original construction units, i.e. either:

- a) all of the requirements given in this standard in metric (SI) units; or
- b) all of the requirements given in this standard in U.S. customary (USC) units.

1.1.4 This standard employs the principles of API 650; however, storage tank owner/operators, based on consideration of specific construction and operating details, may apply this standard to any steel tank constructed in accordance with a tank specification.

1.1.5 This standard is intended for use by organizations that maintain or have access to engineering and inspection personnel technically trained and experienced in tank design, fabrication, repair, construction, and inspection.

1.1.6 This standard does not contain rules or guidelines to cover all the varied conditions which may occur in an existing tank. When design and construction details are not given, and are not available in the as-built standard, details that will provide a level of integrity equal to the level provided by the current edition of API 650 must be used.

1.1.7 This standard recognizes fitness-for-service assessment concepts for evaluating in-service degradation of pressure containing components. API 579-1/ASME FFS-1, *Fitness-For-Service*, provides detailed assessment procedures or acceptance criteria for specific types of degradation referenced in this standard. When this standard does not provide specific evaluation procedures or acceptance criteria for a specific type of degradation or when this standard explicitly allows the use of fitness-for-service criteria, API 579-1/ASME FFS-1 may be used to evaluate the various types of degradation or test requirements addressed in this standard.

1.2 Compliance with This Standard

The owner/operator has ultimate responsibility for complying with the provisions of this standard. The application of this standard is restricted to organizations that employ or have access to an authorized inspection agency as defined in 3.3. Should a party other than the owner/operator be assigned certain tasks, such as relocating and reconstructing a tank, the limits of responsibility for each party shall be defined by the owner/operator prior to commencing work.