

# Spiral Plate Heat Exchangers

API STANDARD 664  
FIRST EDITION, MARCH 2014

ERRATA 1, FEBRUARY 2021

REAFFIRMED, JULY 2024



American  
Petroleum  
Institute

## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Where applicable, authorities having jurisdiction should be consulted.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the instructions. At all times users should employ sound business, scientific, engineering, and judgment safety when using this Standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

## Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001, [standards@api.org](mailto:standards@api.org).

Currently in preview, click buy full version

## Contents

	Page
1 Scope .....	1
2 Normative References .....	1
3 Terms and Definitions .....	1
4 General .....	3
5 Proposal Information Required .....	4
6 Drawings and Other Data Requirements .....	5
6.1 Outline Drawings and Other Supporting Data .....	5
6.2 Information Required After Outline Drawings Are Reviewed .....	6
6.3 Reports and Records .....	7
7 Design .....	7
7.1 General .....	7
7.2 Design Temperatures .....	8
7.3 Design Pressure .....	8
7.4 Fouling Margin .....	8
7.5 Corrosion Allowance .....	8
7.6 Components .....	8
7.7 Supports .....	14
7.8 Cover Gaskets .....	14
7.9 Handling Devices .....	16
8 Materials .....	16
8.1 General .....	16
8.2 Requirements for Carbon Steel in Sour Gas and Hydrogen Sulfide Service .....	16
8.3 Cover Gaskets .....	17
9 Fabrication .....	17
9.1 Welding .....	17
9.2 Heat Treatment .....	17
9.3 Gasket Contact Surfaces Other Than Nozzle Flange Facings .....	17
10 Inspection and Testing .....	18
10.1 Quality Assurance .....	18
10.2 Quality Control .....	18
10.3 Pressure Testing .....	19
10.4 Nameplates .....	20
11 Preparation for Shipment .....	20
11.1 Protection .....	20
11.2 Identification .....	21
Annex A (informative) Recommended Practice .....	22
Annex B (informative) Spiral Plate Heat Exchanger Checklist .....	28
Annex C (informative) Spiral Plate Heat Exchanger Datasheets .....	30
Bibliography .....	39

## Contents

Page

### Figures

1	Typical Cover Clamp Bolting	7
2	Typical Components of Spiral Plate Heat Exchangers	7
3	Typical Designs for Channel Closure	10
4	Typical Center Core Types	11
5	Directions of Forces and Moments on Connections	12
6	Connection Locations for Use with Nozzle Loading Tables	14
A.1	A Typical Column-mounted Overhead Condenser	24
A.2	Typical A-frame Mounted Spiral Heat Exchanger with Trunnions	26

### Tables

1	Maximum Allowable Nozzle Loading, Where the Connection is on a Distribution Manifold or a Centrally Bolted Cover	13
2	Maximum Allowable Nozzle Loading, Where the Connection is on a Cover	13
3	Maximum Allowable Nozzle Loading, on Shell or Dished End	15
4	Gasket Contact Surface Finishes	18
5	Hardness Limits	19
A.1	Indicative Levels of Fouling Margin for Various Process Conditions	25
B.1	Checklist for Spiral Plate Heat Exchangers	29

## Introduction

It is necessary that users of this standard be aware that further or differing requirements can be needed for individual applications. This standard is not intended to inhibit a vendor from offering, or the purchaser from accepting, alternative equipment or engineering solutions for the individual application. This can be particularly applicable where there is an innovative or developing technology. Where an alternative is offered, it is the responsibility of the vendor to identify any variations from this standard and provide details.

This standard requires the purchaser to specify certain details and features.

A bullet (●) at the beginning of a section or subsection indicates a requirement for the purchaser to make a decision or provide information (for information, a checklist is provided in Annex B).

In this standard, where practical, U.S. Customary (USC) or other units are included in parentheses for information.

# Spiral Plate Heat Exchangers

## 1 Scope

This standard specifies requirements and gives recommendations for the mechanical design, materials selection, fabrication, inspection, testing, and preparation for shipment of spiral plate heat exchangers for the petroleum, petrochemical, and natural gas industries. It is applicable to standalone spiral plate heat exchangers and those integral with a pressure vessel.

## 2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NACE MR0103<sup>1</sup>, *Materials Resistant to Sulfide Stress Cracking in Corrosive Petroleum Refining Environments*

NACE MR0175, *Petroleum and Natural Gas Industries—Materials for Use in H<sub>2</sub>S-containing Environments in Oil and Gas Production—Parts 1, 2, and 3*

NACE SP0472, *Methods and Controls to Prevent In-Service Environmental Cracking of Carbon Steel Weldments in Corrosive Petroleum Refining Environments*

## 3 Terms and Definitions

For the purposes of this document, the following terms and definitions apply.

### 3.1

#### **alternate channels welded**

Channel closures seal-welded at alternate ends such that each chamber is accessible by removing the corresponding hot or cold side end cover.

### 3.2

#### **center core**

Distribution chamber at the center of the spiral exchanger.

### 3.3

#### **channel**

Spiral passage formed by strips of metal rolled around a center core within an outer shell.

### 3.4

#### **channel closure**

Configuration to seal the edge of the internal spiral plate.

### 3.5

#### **channel spacing**

Distance or gap between adjacent spiral plates.

---

<sup>1</sup> NACE International (formerly the National Association of Corrosion Engineers), 1440 South Creek Drive, Houston, Texas 77084-4906, [www.nace.org](http://www.nace.org).