

Sealless Centrifugal Pumps for Petroleum, Petrochemical, and Gas Industry Process Service

API STANDARD 685
SECOND EDITION, FEBRUARY 2011



AMERICAN PETROLEUM INSTITUTE

Currently in preview, click buy full version

Sealless Centrifugal Pumps for Petroleum, Petrochemical, and Gas Industry Process Service

Downstream Segment

API STANDARD 685
SECOND EDITION, FEBRUARY 2011



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Copyright © 2011 American Petroleum Institute. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Currently in preview, click buy full version

Contents

Page

Introduction	vi
1 Scope	1
2 Normative References	1
3 Definition of Terms	4
4 General	12
4.1 Unit Responsibility	12
4.2 Nomenclature	12
5 Requirements	12
5.1 System of Measurements	12
5.2 Statutory Requirements	13
5.3 Requirements	13
6 Basic Design	13
6.1 General	13
6.2 Pressure Casings	19
6.3 Nozzles and Pressure Casing Connections	21
6.4 External Nozzles Forces And Moments	23
6.5 Rotors	27
6.6 Wear Rings and Running Clearances	27
6.7 Secondary Control/Containment	28
6.8 Dynamics	30
6.9 Process Cooled/Lubricated Bearings and Bearing Housings	34
6.10 Materials	35
6.11 Nameplates and Rotation Arrows	40
7 Accessories	41
7.1 Drivers	41
7.2 Couplings and Guards	42
7.3 Baseplates and Support Frames	42
7.4 Controls and Instrumentation	42
7.5 Piping and Appurtenances	43
7.6 Special Tools	43
8 Inspection, Testing, and Preparation for Shipment	44
8.1 General	44
8.2 Inspection	45
8.3 Testing	47
8.4 Preparation for Shipment	53
9 Specific Pump Sections	54
9.1 Magnetic Drive Pumps	54
9.2 Canned Motor Pumps	66
10 Vendor's Data	68
10.1 General	68
10.2 Proposals	69
10.3 Contract Data	71
Annex A (informative) Application Information	74

Contents

	Page
Annex B (informative) Hazard-Based Specification of Control/Containment Guidelines	80
Annex C (informative) Sealless Centrifugal Pump Nomenclature	84
Annex D (normative) Circulation and Cooling Water Piping Schematics	88
Annex E (informative) Instrumentation and Protective Systems	92
Annex F (normative) Criteria for Piping Design	95
Annex G (informative) Materials Class Selection Guidance	110
Annex H (normative) Materials and Material Specifications for Pump Parts	112
Annex I (informative) Magnet Materials for Magnetic Couplings	123
Annex J (normative) Determination of Residual Unbalance	125
Annex K (normative) Pressure Temperature Profiles in the Recirculation Circuit	131
Annex L (informative) Lateral Analysis	134
Annex M (normative) Standard Baseplates	140
Annex N (informative) Inspector's Checklist	142
Annex O (informative) Vendor Drawing and Data Requirements	144
Annex P (informative) Test Data Summary	153
Annex Q (informative) Specific Speed and Suction-Specific Speed	157
Annex R (informative) Typical Datasheets	158
Figures	
1 Typical Gusset Design	23
2 Machined Face Suitable for Gasket Containment if Using Cylindrical Threads	24
3 Coordinate System for the Forces and Moments in Table 4: Vertical Inline Pumps	26
4 Coordinate System for the Forces and Moments in Table 4: Horizontal Pumps	26
5 Relationship Between Flow and Vibration	31
6 Locations and Provisions for Taking Vibration Readings	32
7 Vibration Limits for Horizontal Pumps Running Above 3600 r/min or Absorbing More than 300 kW (400 hp) per Stage	33
8 Rotating Component Dimensions to Determine if Single-Plane Balancing is Allowable	34
9 Speed Torque Curve	57
B.1 Logic Diagram	81
C.1 Magnetic Drive Pump, Separately Coupled	85
C.2 Canned Motor Pump	86
C.3 Magnetic Drive Pump Terms Defined in Section 3	87
C.4 Canned Motor Pump Terms Defined in Section 3	87
D.1 Annex D Legend	88
D.2 Clean Circulating Fluid Arrangements	89
D.3 Dirty or Special Circulating Fluid Arrangements	90
D.4 Cooling Water Piping Arrangements	91
E.1 Magnetic Driven Pump	93
E.2 Canned Motor Pump	94
J.1 Residual Unbalance Worksheet	127

Contents

	Page
J.2 Residual Unbalance Worksheet — Polar Chart	128
J.3 Example of Completed Residual Unbalance Worksheet	129
J.4 Example of Completed Residual Unbalance Worksheet—Best-fit Circle for Residual Unbalance	130
K.1 Typical Pressure-Temperature Profile in Magnetic Drive Pump	132
K.2 Typical Pressure-Temperature Profile in Canned Motor Pump	133
L.1 Damping Factor versus Frequency Ratio	136
L.2 Typical Campbell Diagram	137
M.1 Standard Baseplate	141
O.1 Example Distribution Record	145
P.1 Test Data Summary Form	154
P.2 Example of Test Curve Format (SI units)	155
P.3 Example of Test Curve Format (USC units)	156

Tables

1 Water Cooling Systems—Conditions on the Water Side	17
2 Common Hazardous Area Electrical Codes	18
3 Casting Factors	19
4a Nozzle Loadings (SI Units)	24
4b Nozzle Loading (U.S. Customary Units)	25
5 Minimum Internal Running Clearances	29
6 Vibration Limits for Overhung Pumps	31
7 Welding Requirements	38
8 Power Ratings for Motor Drivers	41
9 Pressure Casing Material Inspection Requirements	46
10 Material Inspection Standards	47
11 Performance Acceptance Criteria	48
12 Magnetic Coupling Torque Service Factors	56
13 Stiffness Criteria	65
14 Recommended Spare Parts	70
B.1 H Statement Classification Table	82
B.2 R Phrase Classification Table	83
E.1 Instrumentation and Protective systems	92
F.1 Nozzle Sizes and Location Coordinates for Example 1A	99
F.2 Applied Nozzle Loading for Example 1A	99
F.3 Proposed Applied Nozzle Loadings for Example 2A	102
F.4 Nozzle Sizes and Location Coordinates for Example 1B	103
F.5 Nozzle Sizes and Location Coordinates for Example 1B	104
F.6 Proposed Applied Nozzle Loadings for Example 2B	107
G.1 Material Classes for Sealless Centrifugal Pump Services	110
H.1 Material Classes for Pump Parts	113
H.2 Material Specifications for Pump Parts	115
H.3 Non-metallic Wear Part Materials	122
I.1 Magnetic Materials Properties Overview and Temperature Limits	124
L.1 Rotor Lateral Analysis Logic Diagram	134
M.1 Dimensions of Standard Baseplates	140
N.1 Inspector's Checklist	142

Currently in preview, click buy full version

Introduction

Users of this National Standard should be aware that further or differing requirements may be needed for individual applications. This National Standard is not intended to inhibit a Vendor from offering, or the Purchaser from accepting, alternative equipment or engineering solutions for the individual application. This may be particularly appropriate where there is innovative or developing technology. Where an alternative is offered, the Vendor should identify any variations from this National Standard and provide details.

Annex A contains application specific information and cautions.

Annex B contains hazard-based criteria for secondary containment/control specification.

Annex C contains nomenclature for sealless pumps.

Annex D contains schematic drawings of cooling water and circulation systems.

Annex E defines options for instrumentation and protective systems.

Annex F specifies criteria for piping design.

Annex G gives guidance on material class selection.

Annex H specifies requirements and gives guidance on materials selection.

Annex I provides information on magnetic materials for magnetic couplings.

Annex J specifies requirements for determining residual unbalance.

Annex K provides information and examples for pressure temperature profiles in the recirculation flowpath.

Annex L specifies requirements for lateral analysis.

Annex M specifies requirements for standard baseplates.

Annex N contains an inspector's checklist.

Annex O contains forms which may be used to indicate Vendor drawing and data requirements.

Annex P contains forms which may be used to record test data.

Annex Q specifies calculations for specific speed and suction specific speed.

Annex R contains a data sheet format which Purchasers are encouraged to use.

This National Standard requires the Purchaser to specify certain details and features.

A bullet (•) at the beginning of a subclause or paragraph indicates that either a decision by, or further information from, the Purchaser is required. Further information should be shown on the data sheets or stated in the quotation request and purchase order.

In this National Standard, US Customary units are included in brackets for information.

Sealless Centrifugal Pumps for Petroleum, Petrochemical, and Gas Industry Process Service

1 Scope

1.1 This standard specifies the minimum requirements for sealless centrifugal pumps for use in petroleum, heavy duty petrochemical and gas industry services. Refer to Annex A for application information. Notes following a clause are informative.

1.2 This standard is applicable to single stage overhung pumps of two classifications, Magnetic Drive Pumps (MDP) and Canned Motor Pumps (CMP). Sections 2 through 8 and Section 10 cover requirements applicable to both classifications. Section 9 is divided into two subsections and covers requirements unique to each classification.

NOTE Extension of applicability to other designs such as multistage will need additional input and agreement between Purchaser and Supplier.

1.3 When application of sealless pumps is indicated, relevant industry operating experience suggests sealless pumps produced to this Standard may be used for many applications and should be applied when conditions exceed any of the following:

— Discharge pressure	1900 kPa	(275 psig)
— Suction pressure	500 kPa	(75 psig)
— Pumping temperature	150 °C	(300 °F)
— Rotative speed	3600 r/min	
— Rated total head	120 m	(400 ft)
— Impeller diameter	330 mm	(13 in.)

NOTE For sealed pumps, refer to ISO Standard 13709 (API 610).

2 Normative References

2.1 The following referenced documents are indispensable for the application of this document. The way in which these referenced documents are cited determines the extent (in whole or in part) to which they apply. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API 547, *General-purpose Form-wound Squirrel-cage Induction Motors—250 Horsepower and Larger*

API 611, *General-purpose Steam Turbines for Petroleum, Petrochemical, and Gas Industry Service*

API 670, *Machinery Protection Systems*

API 677, *General-purpose Gear Units for Petroleum, Chemical, and Gas Industry Services*

ABMA 7 ¹, *Shaft and Housing Fits for Metric Radial Ball and Roller Bearings (Except Tapered Roller Bearings) Conforming to Basic Boundary Plan*

¹) American Bearing Manufacturers Association, 2025 M Street, NW, Suite 800, Washington, DC 20036, USA.