

# Vapor Corrosion Inhibitors for Storage Tanks

API TECHNICAL REPORT 655  
FIRST EDITION, APRIL 2021



American  
Petroleum  
Institute

Currently in preview, click buy full version

## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Classified areas may vary depending on the location, conditions, equipment, and substances involved in any given situation. Users of this technical report should consult with the appropriate authorities having jurisdiction.

Users of this technical report should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of newer, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in accordance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

## Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, Suite 1100, Washington, DC 20001, [standards@api.org](mailto:standards@api.org).

## Contents

	Page
<b>1</b> Scope.....	1
<b>1.1</b> General.....	1
<b>1.2</b> Limitations.....	1
<b>2</b> Normative References.....	2
<b>3</b> Definitions.....	2
<b>4</b> VCI Application Method Options.....	4
<b>4.1</b> Foundation Design and Application Methods.....	4
<b>4.2</b> Single Bottom with Release Prevention Barrier.....	5
<b>4.3</b> Single Bottom Without a Release Prevention Barrier.....	5
<b>4.4</b> Double Bottom with Sand Pad.....	5
<b>4.5</b> Double Bottom with Concrete (Solid) Pad.....	6
<b>4.6</b> Double Bottom with Stretched Steel Interstice.....	7
<b>4.7</b> Single Bottom with Reinforced Concrete Slab and Sand Pad.....	7
<b>4.8</b> Sumps.....	8
<b>4.9</b> Other Foundation Designs.....	9
<b>5</b> Elements That Affect VCI Installation and Maintenance.....	9
<b>5.1</b> General.....	9
<b>5.2</b> Dike Liners.....	9
<b>5.3</b> Sand.....	9
<b>5.4</b> Concrete.....	9
<b>5.5</b> Asphalt or Oiled Sand (Bituminous Sand/Bitsand).....	10
<b>5.6</b> Gravel.....	10
<b>5.7</b> Contaminants.....	10
<b>5.8</b> Additives.....	10
<b>5.9</b> Oxygen Concentration Cells.....	11
<b>5.10</b> Microbially-Induced Corrosion (MIC).....	11
<b>5.11</b> Wet or Saturated Tank Pad.....	11
<b>5.12</b> Drain Pipes.....	11
<b>5.13</b> Weather and Temperature Effects.....	11
<b>5.14</b> Importance of Interstice Containment Integrity.....	12
<b>5.15</b> Installation of VCI on Tanks While in Service.....	12
<b>5.16</b> Installation of VCI on Tanks While Out of Service.....	12
<b>5.17</b> Dry VCI Applications.....	13
<b>5.18</b> Inhibitor Solution Applications.....	13
<b>5.19</b> Determining the Optimum Type and Concentration of VCI.....	13
<b>6</b> Monitoring and Replenishment.....	13
<b>6.1</b> Monitoring.....	13
<b>6.2</b> Components.....	13
<b>6.3</b> Electrical Resistance Probes.....	14
<b>6.4</b> Ultrasonic Testing Probes.....	14
<b>6.5</b> Out-of-service Inspection.....	14
<b>6.6</b> Replenishment.....	14
<b>7</b> VCI and Cathodic Protection.....	14
<b>7.1</b> General.....	14
<b>7.2</b> Synergistic Effects of VCI and CP.....	14

## Contents

	Page
7.3 Effect of VCI on Resistivity and CP.....	14
Annex A (informative) Recommended Tank Data for VCI Design .....	16
Bibliography.....	18

## Figures

1 VCI Application Points .....	4
2 Single Tank Bottom with Release Prevention Barrier .....	5
3 Double Bottom with Sand Pad .....	6
4 Double Bottom with Solid Concrete Pad.....	7
5 Double Bottom with Stretched Steel .....	7
6 Reinforced Concrete Slab with Sand Pad .....	8
7 Single Bottom on Reinforced Concrete Slab .....	8
8 Typical Sump .....	9

## Tables

1 Desired Chemical Properties of Sand Pad Material .....	10
--	----

## Introduction

This document provides details on using vapor corrosion inhibitors (VCIs) for protection of the soil-side of tank bottoms from corrosion.

VCIs are chemical compounds that are typically available as crystalline powders. They may be available as loose powder or in prepackaged tubes. The crystalline powders may be mixed into a liquid (commonly with potable water) to deliver the VCIs beneath the tank bottom. Whether delivered by either powder or liquid, the VCIs volatilize into a gas molecule and use their vapor pressure to permeate through air space until a steady-state concentration is reached. The VCI chemistry allows it to maintain a dynamic steady-state equilibrium, providing ongoing corrosion protection to the tank bottom plates.

Vapor pressures of different VCI compounds will vary. The vapor pressure will determine the carrying distance of the molecule within the enclosure and will also affect the concentration of the vapor molecules within that space. VCIs are compounds that vaporize or sublime and condense on the tank bottom surface, forming a molecular layer that mitigates the naturally occurring active corrosion mechanisms. The molecular size is such that the VCI propagates through the voids between the sand particles in a sand pad or airspaces between the steel plate and a foundation pad.

VCIs prevent corrosion by the following actions:

- Vapor transport: VCI molecules volatilize from a source and diffuse through the air space as a vapor molecule. This enables the VCI molecules to move to a metallic surface without direct surface contact of the source chemistry.
- Adsorption: Molecules adsorb onto the surface by a physical and chemical process. When a molecule adsorbs on a steel surface, it effectively blocks other molecules from interacting with the surface of the steel. Under a tank bottom, VCI molecules take precedence on the surface and block oxygen and water molecules, thus reducing the corrosion potential at the interface.
- pH balancing: Some VCI formulations are designed with components that can modify the pH of an environment, typically resulting in a more alkaline condition. Testing of the soil from beneath the steel bottom will provide information about the pH. A low pH may be an indication of bacteria or other causes of acidic conditions.
- Chemical passivation: Some VCIs act to shift the electrical potential of metal toward a more electro-positive state. The interaction can be direct, whereby VCI reacts with the metal surface and becomes part of the passive film, or it can be indirect, whereby VCI inhibits the adsorption of oxygen on the metal surface to passivate the metal surface.
- Contaminant neutralization: Acidic species are known to cause corrosion of ferrous metals. Some VCI molecules can neutralize the acidic species.

# Vapor Corrosion Inhibitors for Storage Tanks

## 1 Scope

### 1.1 General

**1.1.1** The purpose of this technical report (TR) is to provide information to owner/operators regarding the use of vapor corrosion inhibitors (VCI) and to provide guidance for their use in corrosion protection of aboveground storage tank (AST) bottoms, specifically from soil-side corrosion of carbon steel. The VCI chemistries discussed in this document are from the amine-carboxylate group.

**1.1.2** Certain practices recommended herein may also be applicable to metallic tanks in services other than hydrocarbon under special circumstances.

**1.1.3** VCI manufacturers should be able to assist in determining the suitability of VCI use for each situation, along with proper concentration and application method for their products. VCI professionals working for the manufacturers or working in conjunction with the owner/operators will need information about the tank to make valid recommendations. Annex A provides a list of relevant information that may be required to make an informed decision.

**1.1.4** The potential for corrosion can occur in void spaces where cathodic protection (CP) will not be effective because of oxygen concentration cells, from contaminants in the foundation bed, or contaminants that may ingress, such as water and oxygen. VCIs may be beneficial in these situations.

**1.1.5** VCI molecules disperse through the foundation materials from their source based on their vapor pressure. Because these molecules are lighter than air, they will adsorb to the surface of materials in the foundation. Also, they have a higher attraction to steel than to the sand, gravel, concrete, or asphalt and other surfaces. Uniform distribution of the VCI source material is not required since the vapor pressure of the VCI molecules will eventually complete the distribution under the tank bottom.

### 1.2 Limitations

**1.2.1** For VCIs to protect the tank bottom from soil-side corrosion, the tank foundation design shall provide a means to contain the VCI beneath the bottom.

**1.2.2** While most manufacturers' VCI chemistries for use in tank bottom applications have similarities, each has unique characteristics and chemistries. Owner/operators should review the characteristics of the chemistries to determine which product best suits their needs.

**1.2.3** In cases where API 651 identifies several foundation designs or details where CP may not be effective or may offer limited protection, VCIs may be an effective alternative or may work in conjunction with CP to improve protection.

**1.2.4** VCIs volatilize into vapors that may be inhaled. VCIs, in powder form, may create dust when handled. If engineering or administrative controls are not effective in reducing exposures, proper PPE should be worn when handling the VCI during installation. At very large concentrations, the dust may be combustible. Concentrations in air from working or applying VCI powder are considerably below the concentrations susceptible to combustion. Consult the Safety Data Sheet for additional information.

**1.2.5** Since VCIs may be discharged to the ground at any time during installation and service, it is imperative that all federal, state, and local discharge permit requirements be followed. This may preclude the use of VCIs, depending on the jurisdiction's discharge permit requirements.

**1.2.6** When using VCI powder near welding operations, VCI powder shall not be in the weld zone. The powder is not combustible, but may affect the quality of the weld, as would other contaminants.