

Australian Standard[®]

LOW VOLTAGE CONTACTORS

**Part 1—ELECTROMECHANICAL—
UP TO AND INCLUDING
1000 V a.c. AND
1200 V d.c.**

[Title allocated by the Defence Cataloguing Authority:
CONTACTOR, ELECTROMECHANICAL, (Up to 1000 V a.c.
or 1200 V d.c.)]

This Australian standard was prepared by Committee EL/6, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of the Standards Association of Australia on 19 October 1984, and published on 4 March 1985.

The following interests are represented on Committee EL/6:

Australian Electrical and Electronic Manufacturers Association
Australian-British Chamber of Commerce
Bureau of Steel Manufacturers of Australia
Confederation of Australian Industry
Department of Defence
Department of Defence Support
Electrical Contractors Associations of Australia
Electricity Supply Association of Australia
Institution of Engineers Australia
Metropolitan Water Sewerage and Drainage Board, Sydney
Railways of Australia Committee

Representatives of the following interests also participated in the drafting of this standard:

Department of Public Works, N.S.W.
State Rail Authority of New South Wales

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard[®]

LOW VOLTAGE CONTACTORS

**Part 1—ELECTROMECHANICAL—
UP TO AND INCLUDING
1000 V a.c. AND
200 V d.c.**

First published (as AS C63)	1965
AS 1029 first published	1971
AS 1029.1, separately published	1982
Second edition	1985

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 3602 0

PREFACE

This edition of this standard was prepared by the Association's Committee on Industrial Switchgear and Controlgear to supersede AS 1029, Part 1—1982, Low Voltage Contactors—Electromechanical (Up to and Including 1000 V a.c.).

This standard closely follows IEC 158—1 with its supplements 158—1A, 158—1B and 158—1C which cover both a.c. and d.c. electromechanical contactors.

This standard differs from the 1982 edition in the following respects:

- (a) The title and scope now reflect that it covers both a.c. and d.c. electromechanical contactors.
- (b) A number of requirements in the 1982 edition which differed from IEC 158—1 are considered to be no longer appropriate and in consequence are no longer included herein. In particular, following the breaking capacity test, contactors are no longer required to withstand the full dielectric test voltage, a condition considered too onerous for many contactors of modern design.

Where this standard deviates technically from the IEC a rule is shown in the margin alongside the clause, table or part thereof affected and such deviations are summarized in the Annex.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 Scope	5
1.2 Objects	5
1.3 Referenced Documents	5
SECTION 2. DEFINITIONS	
2.0 Application of Section	6
2.1 Definitions Concerning Contactors	6
2.2 Definitions Concerning Positions, Control and Auxiliary Circuits of a Contactor	7
SECTION 3. CLASSIFICATION	
3.1 Designation of Contactors According to the Method of Control	7
3.2 Grouping of Contactors According to the Interrupting Medium	8
3.3 Distinction According to Degree of Protection Provided by the Enclosure	8
SECTION 4. CHARACTERISTICS OF CONTACTORS	
4.1 Summary of Characteristics	9
4.2 Type of Contactor	9
4.3 Rated Values	9
4.4 Control Circuits and Air Supply Systems	13
4.5 Auxiliary Circuits	13
4.6 Protection of Contactor by a Short-circuit Protective Device	13
SECTION 5. MARKINGS	
5.1 General	15
5.2 Essential Markings	15
5.3 Other Markings	15
5.4 Terminals for External Conductors	15
SECTION 6. CONDITIONS FOR OPERATION IN SERVICE	
6.1 Normal Service Conditions	16
6.2 Shape and Symmetry of Voltages	16
6.3 Non-standard Conditions	16
6.4 Conditions of Installation	16
SECTION 7. CONDITIONS FOR CONSTRUCTION	
7.1 Mechanical Design	17
7.2 Enclosure	17
7.3 Temperature Rise	17
7.4 Dielectric Properties	19
7.5 Limits of Operation	19
SECTION 8. TESTS	
8.1 Testing	20
8.2 Verification of the Characteristics of Contactors	20
8.3 Type Tests	20
8.4 Routine Tests	25
8.5 Special Tests	25
APPENDICES	
A Information to be Supplied by the Purchaser	26
B Clearance and Creepage Distances	27
C Protection of a Contactor by a Short-circuit Protective Device	30

	<i>Page</i>
D Conventional Test Circuit for Verification of Making and Breaking Capacities	33
E R10 Series of Preferred Numbers	38
F Identification of Terminals	39
G Items Subject to Agreement between the Purchaser and the Manufacturer . .	43
ANNEX. SUMMARY OF TECHNICAL VARIATIONS BETWEEN THIS STANDARD AND IEC 158—1	44

Currently in preview, click buy full version

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
for
LOW VOLTAGE CONTACTORS

Part 1—ELECTROMECHANICAL (UP TO AND INCLUDING 1000 V a.c.
AND 1200 V d.c.)

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This standard applies to electromechanical type contactors for industrial use, intended for closing and opening electric circuits and, where combined with suitable relays, for protecting these circuits against operating overloads.

It applies only to contactors, the main contacts of which are intended to be connected to circuits where the voltage does not exceed 1000 V a.c. or 1200 V d.c.

The standard also applies to the electromechanical part of hybrid semiconductor (solid state) contactors which comply with AS 1029, Part 2 for voltages up to and including 1000 V a.c. and 1500 V d.c.

There may be arduous service conditions which are not represented by the test requirements of this standard and the use of electromechanical contactors for such purposes shall be subject to the manufacturer's recommendations (see the Note 1 to Clause 4.3.7).

NOTES:

1. For electromechanical contactors with a rated voltage exceeding 1000 V a.c., see AS 1864.
2. Contactors which are intended to provide short-circuit protection must additionally satisfy the relevant conditions specified for circuit-breakers (see AS 1930, AS 2184 and AS 3111).
3. Where contactors are used in motor circuits, reference should also be made to AS 1202.
4. Information to be supplied by the purchaser is listed in Appendix A.

1.2 OBJECTS. The objects of this standard are to state —

- (a) the characteristics of contactors;
- (b) the conditions with which contactors must comply with reference to —
 - (i) their operation and behaviour;
 - (ii) their dielectric properties;
 - (iii) the degrees of protection provided by their enclosures;
- (c) the tests intended for confirming that these conditions have been met and the methods to be adopted for these tests; and
- (d) the data to be marked on the apparatus.

NOTE: This standard does not include all the electrical safety requirements with which compliance may be necessary to secure approval for installation of contactors.

1.3 REFERENCED DOCUMENTS. The following documents are referred to in this standard:

AS 1029	Low Voltage Contactors Part 2—Semiconductor (Solid State) (Up to and Including 1000 V a.c. and 1500 V d.c.)
AS 1136	Switchgear and Controlgear Assemblies for Voltages Up to 1000 V a.c.
AS 1202	A.C. Motor Starters (Up to and Including 1000 V) Part 1—Direct-on-line (Full Voltage) Starters
AS 1364	High Voltage Alternating Current Contactors
AS 1930	Circuit-breakers for Distribution Circuits (Up to and Including 1000 V a.c. and 1200 V d.c.)
AS 1939	Classification of Degrees of Protection Provided by Enclosures for Electrical Equipment
AS 2184	Moulded-case Circuit-breakers (Up to and Including 600 V a.c. and 250 V d.c.) (Interrupting Rating 10 kA and More)
AS 3100	Approval and Test Specification for Definitions and General Requirements for Electrical Materials and Equipment
AS 3111	Approval and Test Specification for Miniature Overcurrent Circuit-breakers
AS C320	Classification of Insulating Materials for Electrical Machinery and Apparatus on the Basis of Thermal Stability in Service
SAA MP19	Report on Preferred Numbers and Their Use
BS 3781	Method for Determining the Comparative Tracking Index of Solid Insulating Material
IEC 158	Low-voltage Controlgear 158—1 Part 1—Contactors
IEC 410	Sampling Plans and Procedures for Inspection by Attributes