

AS 1170.3—1990

Australian Standard[®]

SAA Loading Code

Part 3: Snow loads

This Australian Standard was prepared by Committee BD/6, Loading on Structures. It was approved on behalf of the Council of Standards Australia on 31 October 1989 and published on 26 January 1990.

The following interests are represented on Committee BD/6:

Association of Consulting Engineers, Australia
Association of Consulting Structural Engineers, Australia
Australian Clay Brick Association
Australian Construction Services (Department of Administrative Services)
Australian Council of Local Government Associations
Australian Federation of Construction Contractors
Australian Institute of Steel Construction
Australian Mining Industry Council
Bureau of Meteorology
Bureau of Steel Manufacturers of Australia
CSIRO, Division of Building, Construction and Engineering
Department of Local Government, Qld
Electricity Supply Association of Australia
Engineering and Water Supply Department, S.A.
James Cook University of North Queensland
Master Builders' Construction and Housing Association, Australia
Monash University
National Association of Australian State Road Authorities
Public Works Department, N.S.W.
University of Melbourne
University of Newcastle

Additional interests participating in preparation of Standard:

National Parks and Wildlife Service, N.S.W.
Public Works Department, Vic.
Shire of Lighth, Vic.
Snowy Mountains Hydro-Electric Authority, N.S.W.

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 88133.

AS 1170.3—1990

Australian Standard[®]

**Minimum design loads on
structures**

Part 3: Snow loads

(known as the SAA Loading Code)

First published as AS 1170.3—1990.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 6006 1

PREFACE

This Standard was prepared by the Standards Australia Committee for Loading on Structures.

In preparing this Standard the Committee referred to the following:

- (a) ANSI A58.1–1982, *American National Standards Institute – Minimum Design Loads for Buildings and other Structures*.
- (b) *National Building Code of Canada*, 1980.
The Supplement to the National Building Code of Canada – 1980.
- (c) ISO 4355–1981 International Standard, *Bases for Design of Structures, Determination of Snow Loads on Roofs*.

Data on ground snow depths and densities were obtained mainly from the Bureau of Meteorology, Authorities, such as The Snowy Mountains Authority, and a private meteorologist.

The Committee acknowledges the assistance obtained from these sources.

The relationship between roof snow load and ground snow load was established on the basis of field observations by members of the Committee over many years, particularly years of very heavy snowfalls.

This Standard is intended to be used in establishing snow loads on roofs, balconies, walkways and other building surfaces which retain snow. It also provides guidance (see Appendix B) on the avoidance of common problems which occur mainly in alpine regions due to movement, sliding or drifting of snow.

Snow loads are difficult to assess accurately not only because the amount of snow which falls is sensitive to general and local topography but also because the amount of snow which is retained on the roof is sensitive to roof slope, roof geometry and orientation.

Designers must be alert to the extra snow loads which certain roof shapes attract, because of drifting effects. Blockages and effects of sliding and snow creep on the roof and in the environs of the building are further considerations for the designer.

Statements expressed in mandatory terms in Notes to tables and figures are deemed to be requirements of this Standard.

A Commentary (see AS 1170.3 Supplement 1) provides background material to the requirements of this Standard and includes some worked examples to illustrate its application.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 APPLICATION	4
1.3 REFERENCED DOCUMENTS	4
1.4 METHODS OF DETERMINATION OF SNOW LOADS	4
1.5 LOAD COMBINATIONS	4
1.6 NOTATION	4
SECTION 2. GEOGRAPHIC REGIONS AFFECTED BY SNOW	
2.1 REGIONS WITH SIGNIFICANT SNOWFALLS	6
2.2 DIVISION OF REGIONS	6
SECTION 3. SNOW LOAD IN SUB-ALPINE REGIONS	
3.1 DETERMINATION OF GROUND SNOW LOAD	8
3.2 SNOW WEIGHT	8
3.3 DETERMINATION OF SNOW LOAD ON BUILDING SURFACES	8
SECTION 4. SNOW LOAD IN ALPINE REGIONS	
4.1 DETERMINATION OF GROUND SNOW LOAD	13
4.2 DETERMINATION OF SNOW LOAD ON BUILDING SURFACES	15
4.3 EXPOSURE TO WIND	15
4.4 ROOF SLOPE	15
4.5 PARTIAL LOADING	15
4.6 UNBALANCED SNOW LOAD	15
4.7 DRIFTS ON LOWER ROOFS OR OTHER SURFACES	19
4.8 ROOF PROJECTIONS	22
4.9 SLIDING SNOW	23
4.10 SNOW CREEP	23
APPENDICES	
A EFFECTS OF TERRAIN ON THE DISTRIBUTION OF GROUND SNOW LOAD IN ALPINE REGIONS	24
B COMMON PROBLEMS AND THEIR AVOIDANCE	26

STANDARDS AUSTRALIA

Australian Standard
Minimum design loads on structures

Part 3: Snow loads

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Standard sets out data and procedures for determining snow loads to be used in structural design.

1.2 APPLICATION. This Standard is intended to apply to all buildings and building components, including roofs and other building surfaces, walkways and access platforms, subject to snow accumulation.

1.3 REFERENCED DOCUMENTS. The following documents are referred to in this Standard.

AS

1170 SAA Loading Code

1170.1 Part 1: Dead and live loads and load combinations

1170.2 Part 2: Wind loads

1.4 METHODS OF DETERMINATION OF SNOW LOADS. The snow load on a structure or part of a structure shall be determined by one or more of the following:

- (a) The applicable clauses of this Standard.
- (b) Reliable data and references used consistently with the clauses of this Standard coupled with extensive information of the local conditions.
- (c) Wind tunnel or similar tests which accurately simulate the local snow accumulations.

NOTE: Extensive information of local conditions should include the years of maximum snow depths (such as 1964 and 1974 in the Snowy Mountains).

1.5 LOAD COMBINATIONS. Snow loads shall be combined with dead load, live load, wind load and other loads in accordance with AS 1170.1. The most unfavourable load combination shall be used in the design of the structure or structural element being considered.

In addition to the load combinations specified in AS 1170.1, the following shall also be taken into account:

- (a) Load combinations for strength limit states -
 - (i) $1.2G + 1.5S_r + \Psi_c Q + 0.5W_u$
 - (ii) $0.8G + 1.5S_r$
- (b) Load combinations for serviceability limit states, short-term effects -
 - (i) S_r
 - (ii) $G + S_r$
 - (iii) $G + \Psi_s Q + S_r$

where

G = dead load

S_r = snow load on roof or other structural element

Ψ_c = live load combination factor used in assessing the design load for strength limit state

Q = live load

W_u = wind load for the strength limit state

Ψ_s = short-term live load factor used in assessing the design load for serviceability limit state.

1.6 NOTATION. Symbols occurring in this Standard are listed below.

Unless a contrary intention appears, the following applies:

- (a) The notation used in this Standard have the meanings ascribed to them below, with respect to the structure, or member, or condition to which a clause is applied.
- (b) The dimensional units for length, height, depth and stress in all expressions or equations shall be taken as metres (m) and kilopascals (kPa) respectively.
- (c) The SI system of units is used throughout.

b_p = dimension of the local projection normal to the direction of drifting

C_p = snow load coefficient taking into account wind, sliding, drifting and other effects

C_{pb} = snow load coefficient for balanced loading

C_{pd} = snow load coefficient for drifting snow

C_{pp} = snow load coefficient for drifting snow at roof projections

C_{pr} = snow load coefficient at the ridge of a multi-span roof with valleys

C_{ps} = snow load coefficient for sliding snow

C_{pu} = snow load coefficient for unbalanced loading

d_g = ground snow depth

d_r = snow depth on roof or other structural elements

G = dead load

h_a = height from crown level to eaves level in a curved roof

h_b = height above ground level to the point at which the roof slope on a curved roof exceeds 60°