

Australian Standard[®]

Electricity metering

**Part 3: Induction watthour
meters—Energy demand type**

This Australian Standard was prepared by Committee EL/11, Electricity Metering Equipment. It was approved on behalf of the Council of Standards Australia on 27 September 1990 and published on 11 February 1991.

The following interests are represented on Committee EL/11:

Australian Electrical and Electronic Manufacturers' Association

Confederation of Australian Industry

Electricity Supply Association of Australia

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard' which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard[®]

Electricity metering

**Part 3: Induction watthour
meters—Energy demand type**

AS 1284.3—1990 first published as part of
AS C39.3—1965.
AS C39.3—1965 revised and redesignated
AS 1284.3—1973.
AS 1284.3—1973 revised in part as AS 1284.3—1991.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 6604 3

PREFACE

This Standard was prepared by the Standards Australia Committee on Electricity Metering Equipment to supersede in part AS 1284.3—1973, *Electricity Meters, Part 3: Alternating current watthour meters of two-rate and energy demand types*.

AS 1284, (retitled) *Electricity Metering*, is published in four Parts as follows:

AS

1284.1 Part 1: General purpose induction watthour meters

1284.2 Part 2: Portable alternating current rotating standard watthour meters

1284.3 Part 3: Induction watthour meters—Energy demand type (this Standard)

1284.4 Part 4: Socket mounting system

Other Parts of AS 1284 are being drafted.

Requirements for two-rate meters formerly included in AS 1284.3—1973 have been revised and transferred to AS 1284.1—1990 where they are to be found among requirements for multi-rate meters.

 CONTENTS

	<i>Page</i>
1 SCOPE	3
2 APPLICATION	3
3 REFERENCED DOCUMENTS	3
4 DEFINITIONS	3
5 CONSTRUCTIONAL REQUIREMENTS	4
6 ELECTRICAL REQUIREMENTS	5
7 PERFORMANCE REQUIREMENTS	5
8 MARKING	6
INDEX	7

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

STANDARDS AUSTRALIA

Australian Standard
Electricity metering

Part 3: Induction watthour meters—Energy demand type

1 SCOPE This Standard specifies requirements for 50 Hz a.c. induction watthour meters provided with a demand register to indicate maximum demand.

This Standard does not apply to meters that record demand or to meters that depend upon thermal effects or are operated by pulses.

2 APPLICATION This Standard shall be read in conjunction with AS 1284.1. A meter shall comply with the appropriate requirements of AS 1284.1 except as they may be modified herein.

3 REFERENCED DOCUMENTS The following Standard is referred to in this Standard:

AS	
1284	Electricity metering
1284.1	Part 1: General purpose induction watthour meters

4 DEFINITIONS For the purpose of this Standard, the definitions below apply.

4.1 Energy demand meter—a meter with a demand register in addition to the energy register.

4.2 Demand register—the mechanism which indicates maximum demand (usually combined with the energy register).

4.3 Indicating demand register—a demand register which indicates maximum demand by means of a scale readout, a pointer register, or a digital register.

4.4 Cumulative demand register—a demand register in which the operation of the maximum demand resetting mechanism adds the prevailing maximum demand to the sum of the previous maximum demands.

4.5 Scale readout—a scale over which a single friction pointer is advanced to indicate maximum demand.

4.6 Pointer register—a counting mechanism indicating, by means of pointers and associated dials, the maximum demand.

4.7 Digital register—a counting mechanism indicating, by means of figures (on drums or by other means), the maximum demand.

4.8 Full-scale value (of a demand register)—the maximum scale capacity of the register. If a multiplying constant exists, the full-scale value will be the product of the maximum scale marking and the multiplying constant.

4.9 Demand (Mean power)—the energy divided by the time in which it is produced or absorbed.

4.10 Demand integration period—the interval of time upon which the demand measurement is based (e.g. 30 min).

4.11 Maximum demand—the highest value of the mean power during successive demand integration periods between one operation of the maximum-demand resetting mechanism and the next.

4.12 Maximum-demand resetting mechanism—a mechanism which enables the maximum-demand friction pointer or pointers to be reset to zero manually or by other means. For a cumulative demand register, it also initiates the operation which causes the prevailing maximum demand to be added to the sum of the previous maximum demands.

4.13 Driving mechanism—a mechanism which when operated by the energy meter can drive the maximum-demand pointers or drums.

4.14 Detent time—the interval of time within each demand integration period during which the demand register is disconnected for the purpose of restoring the driving mechanism.

4.15 Timing mechanism—the mechanism which measures and controls the demand-integration period of the demand register. This mechanism may be internal or external to the meter case.