

Australian Standard[®]

Electricity metering

Part 4: Socket mounting system

STANDARDS
Australia



This Australian Standard® was prepared by Committee EL-011, Electricity Metering Equipment. It was approved on behalf of the Council of Standards Australia on 14 June 2006. This Standard was published on 12 July 2006.

The following are represented on Committee EL-011:

- Australian Chamber of Commerce and Industry
 - Australian Electrical and Electronic Manufacturers Association
 - Electrical Regulatory Authorities Council
 - Electricity Engineers Association (New Zealand)
 - Energy Networks Association
 - Ministry of Economic Development (New Zealand)
 - NEMMCO
 - National Measurement Institute
-

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee.

Keeping Standards up to date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Electricity metering

Part 4: Socket mounting system

Originally as AS 1284.4—1991.
Previous edition 1994.
Third edition 2006.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 7616 7

PREFACE

This Standard was reviewed by the Australian members of the Joint Standards Australia/Standards New Zealand committee EL-011, Electricity Metering Equipment. After consultation with stakeholders in both countries Standards Australia and Standards New Zealand decided to republish this Australian Standard without technical alteration. Referenced documents have been updated to current editions.

The objective of this Standard is to provide the electricity metering industry with a dimensional and performance specification that will ensure that sockets, plug-in devices and other components of the system produced by different manufacturers are directly interchangeable and suitable for their intended purpose in terms of safety and performance.

This Standard is Part 4 of AS 1284, *Electricity metering*, which is published in Part 4 as follows:

- Part 1: General purpose induction watthour meters
- Part 4: Socket mounting system (this Standard)
- Part 10.1: Data exchange for meter reading, tariff and load control—Direct local data exchange via hand-held unit (HHU)—IEC Standard interface
- Part 10.2: Data exchange for meter reading, tariff and load control—Direct local data exchange via hand-held unit (HHU)—ANSI Standard interface
- Part 11: Single-phase multifunction watthour meters
- Part 12: Polyphase multifunction (non-demand) watthour meters (Class 1)
- Part 13: In-service compliance testing

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

CONTENTS

	Page
FOREWORD.....	4
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 APPLICATION	5
1.3 REFERENCED DOCUMENTS	5
1.4 DEFINITIONS	6
SECTION 2 SOCKET	
2.1 ARRANGEMENT.....	7
2.2 HOUSING	7
2.3 LIVE PARTS.....	7
2.4 HOUSING ASSEMBLY	8
2.5 DUST MEMBRANE	9
2.6 LOCATING PLATE.....	10
2.7 MARKINGS.....	10
2.8 SOCKET AS SUPPLIED	10
SECTION 3 PLUG-IN DEVICE.....	14
SECTION 4 RETAINING COVER	
4.1 ARRANGEMENT.....	17
4.2 MOULDING	17
4.3 SEALING SCREWS	17
4.4 DIMENSIONS.....	17
4.5 MARKINGS.....	17
SECTION 5 BLANKING PLATE	
5.1 MOULDING	19
5.2 DIMENSIONS	19
SECTION 6 COMPLETE ASSEMBLY	
6.1 SCOPE OF SECTION	20
6.2 DOUBLE INSULATION	20
6.3 ENTRY OF SEALING WIRE	20
6.4 ENTRY OF DUST AND WATER	20
APPENDICES	
A STANDARD CONNECTION ARRANGEMENTS	21
B STANDARD ARRANGEMENTS FOR MULTIPLE SOCKETS.....	27
C INFORMATION TO BE SUPPLIED WITH ENQUIRY AND ORDER	31

FOREWORD

The socket mounting system for electricity meters specified herein was developed in Australia in the mid-1970s. It was based on the North American plug-in system of the 1930s. (That system is complicated by the three-wire 120 V–0–120 V supply system.)

The basic design involves a single-element meter with three blades, and a socket with three jaws, A, N, L; the heavy current jaws (A and L) are arranged at an angle of 90° to each other in order to facilitate self-alignment of the blades and to avoid the application of torque to the current coil of the meter during insertion.

The positions of the three jaws are staggered in order that, for those meters where it is applicable, disconnection of supply can be carried out simply and safely by removing and reinserting the meter 90° anticlockwise from its 'normal' position and resealing the installation, all without touching the associated circuit wiring. No meter can be inserted 'upside-down' or in any position other than 'normal' or 'disconnected'.

However, in certain circumstances, a plug-in meter (or other device) might create a safety hazard to the installer if it were inserted in the 'disconnected' position; accordingly a 'non-rotatable' plug-in base is specified for such a meter or device to prevent insertion in other than the 'normal' position.

Staggering of jaws also facilitates factory connection of multiple sockets with straight sealed busbars, thereby achieving a significant reduction in space and in installation cost. The system allows for surface connection or back connection of wiring according to requirement.

Two additional jaws are provided for other purposes (see Appendix A). Bridging facilities are provided in the socket (see Figure 2.1) to accommodate an external shorting bridge for use in changing a meter without interrupting supply (or open-circuiting a current transformer).

The same jaw arrangement will also accept other devices for metering and load control purposes. Two sockets can be located adjacent to each other to allow a meter and a load control device to be conveniently interconnected (see Appendix B).

STANDARDS AUSTRALIA

Australian Standard
Electricity metering

Part 4: Socket mounting system

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies safety, performance and interchangeability requirements for sockets rated 500 V, 125 A, for plug-in devices, for retaining covers, and for blanking plates. This Standard also specifies standard connection arrangements (see Appendix A) and standard arrangements for multiple sockets (see Appendix B).

NOTES:

- 1 Where a socket is to be used with a device rated at more than 100 A, the socket should be wired with a minimum of 35 mm copper cable to terminals A and L.
- 2 To facilitate the specification and purchase of sockets and their components, the Standard lists information which should be supplied with enquiry and order (see Appendix C).

1.2 APPLICATION

This Standard is intended to be read in conjunction with AS 1284.1.

1.3 REFERENCED DOCUMENTS

The following documents are referred to in this Standard:

AS

- | | |
|------------|--|
| 1284 | Electricity metering |
| 1284.1 | Part 1: General purpose induction watt-hour meters |
| 60068.2.75 | Part 2.75: Environmental testing—Tests—Test Eh: Hammer tests |
| 60529 | Degrees of protection provided by enclosures (IP Code) |
| AS/NZS | |
| 3100 | Approval and test specification—General requirements for electrical equipment |
| 60695.2.11 | Part 2.11: Fire hazard testing—Glowing/hot wire based test methods—Glow-wire flammability test method for end-products |

IEC

- | | |
|-------|---|
| 60028 | International standard of resistance for copper |
|-------|---|

ISO

- | | |
|------|--|
| 75 | Plastics—Determination of temperature of deflection under load |
| 75-2 | Part 2: Plastics and ebonite |