

~~SUPERSEDED BY~~ 1299-1984

AS 1299—1981
UDC 621.316.541:622.006.5

1299

Australian Standard 1299—1981

FLAMEPROOF RESTRAINED PLUGS AND RECEPTACLES FOR USE IN COAL MINES



STANDARDS ASSOCIATION OF AUSTRALIA
Incorporated by Royal Charter



THE FOLLOWING SCIENTIFIC, INDUSTRIAL AND GOVERNMENTAL ORGANIZATIONS and departments were officially represented on the committee entrusted with the preparation of this standard:

Association of Mining Electrical and Mechanical Engineers, Australia
Australian Chamber of Commerce
Australian Coal Association
Australian Electrical and Electronic Manufacturers Association
Confederation of Australian Industry
Department of Mineral Resources, N.S.W.
Department of Mines, Queensland
Joint Coal Board
Queensland Confederation of Industry
State Energy Commission of Western Australia
State Mines Control Authority, N.S.W.
University of New South Wales
University of Queensland
University of Sydney

This standard, prepared by Committee EL/25, Electrical Equipment in Coal Mines, was approved on behalf of the Council of the Standards Association of Australia on 17 November 1980, and was published on 1 April 1981.

To keep abreast of progress in industry, Australian standards are subject to continuous review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that their standards are up-to-date. Full details of all SAA publications will be found in the Annual List of Australian Standards; these details are supplemented by listings in the SAA monthly journal 'The Australian Standard'. Information on the Annual List and 'The Australian Standard' may be obtained from any sales office of the Association, where details are also available of the current status of individual standards. Suggestions for improvements to published standards, addressed to the head office of the Association, are welcomed.

AUSTRALIAN STANDARD

FLAMEPROOF RESTRAINED PLUGS AND RECEPTACLES FOR USE IN COAL MINES

AS 1299—1981

First published	1973
Second edition	1981

PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.

ISBN 0 7262 2164 3



24 MAR 1981

PREFACE

This edition of this standard was prepared by the Association's Committee on Electrical Equipment in Coal Mines. It is intended for use in conjunction with mining regulations, and for the guidance of manufacturers, users, and statutory authorities concerned with the operation of electrical equipment in hazardous gas atmospheres.

Provision is now made for shuttle car plugs and receptacles, and a new 60 A restrained plug and receptacle, all in 660 V and 1100 V configurations. The existing 60 A and 425 A plugs and receptacles have been deleted and changes have been made to the dimensions of existing drawings to ensure interchangeability of plugs and receptacles of different makes. Fixing dimensions of receptacles have also been standardized.

Acknowledgement is made to Cable Makers Australia Pty Ltd for providing the working drawings reproduced in the standard. It should be noted that as reproduced herein Figs 3 to 10 are approximately to the same scale.

This standard requires reference to the following Australian standards:—

- AS 1147 Plastics Insulating Materials of Mouldings for Cable Connecting Devices for Use in Coal Mines
- AS 1802 Trailing Cables for Mining Purposes (Including Underground Coal Mines, Metalliferous Mines, Open-cut Mines, Quarries and Dredges)
- AS 1828 Cable Glands for Explosive Gas Atmospheres
- AS 1852 International Electrotechnical Vocabulary 1852(441)—Switchgear and Controlgear
- AS 1856 Electroplated Coatings of Silver for Engineering Applications
- AS 3147 Approval and Test Specification for PVC Insulated Electric Cables and Flexible Cables for Working Voltages up to 0.6/1.0 kV
- AS C98 Flameproof Enclosure of Electrical Equipment for Explosive Atmospheres
- AS K185 Colours for Specific Purposes

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1981

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

CONTENTS

	<i>Page</i>
SPECIFICATION	
1 Scope	4
2 Definitions	4
3 Ratings and Colour Coding	4
4 Service Conditions	4
5 Metallic Components	6
6 Contacts	6
7 Terminals	6
8 Plugs	6
9 Receptacle	7
10 Flameproof Enclosure	7
11 Clearance and Creepage Distances	7
12 Tests	7
13 Type Tests	9
14 Routine Tests	9
15 Marking	10
APPENDICES	
A Information to be Provided with Enquiry and Order	18
B Cable Gland (Slip load) Test	19
FIGURES	
1 Typical Assembly of Restrained Plug and Receptacle	5
2 Typical Assembly of Restrained Plug Coupling Device	5
3 Plug and Receptacle—660 V, 60 A	11
4 Plug and Receptacle—1100 V, 60 A	11
5 Plug and Receptacle—660 V, 125 A	12
6 Plug and Receptacle—1100 V, 125 A	13
7 Plug and Receptacle—660 V, 150 A	14
8 Plug and Receptacle—1100 V, 150 A	15
9 Plug and Receptacle—660 V, 300 A	16
10 Plug and Receptacle—1100 V, 300 A	17

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
for
FLAMEPROOF RESTRAINED PLUGS AND RECEPTACLES FOR USE IN COAL MINES

1 SCOPE. This standard specifies the dimensional and test requirements for flameproof restrained type plugs and receptacles, incorporating three power contacts, one auxiliary contact and scraping earth contact, intended for use with mining apparatus. Provision is also made for plug coupling units which enable lengths of trailing cable to be coupled together. The standard is designed to ensure interchangeability of flameproof plugs and receptacles of different makes.

The standard includes some electrical and mechanical requirements, including the provision of earthed phase barriers for protection against inter-phase faults, but does *not* purport to provide a fully detailed design.

The term 'receptacle' used in this standard is synonymous with the term 'socket' in AS 1852. The term 'receptacle' has been chosen to avoid confusion with the individual sockets within the plug.

A typical plug and receptacle assembly is shown in Fig. 1 and a typical plug coupling unit is shown in Fig. 2.

The standard provides for plug and receptacle discrimination, i.e. an arrangement whereby fitting of plugs and receptacles of different rated voltages is physically prevented from engagement.

NOTE: Attention is drawn to Appendix A, which lists information which should be supplied by the purchaser with his enquiry or order.

2 DEFINITIONS. For the purpose of this standard, the following definitions apply.

2.1 Authority—the relevant Statutory Authority responsible for the implementation of Government regulations applying to coal mines in each of the States of Australia.

2.2 Cable gland—a device to secure the end of a cable, by means appropriate to the type of cable, including provision for the making of electrical connections to the metallic covering of the cable and to the metallic sheath if present.

2.3 Contact pin—a conducting member, rigid or resilient, intended to be inserted in a socket contact of suitable form so as to make electrical contact.

2.4 Contact socket—a conducting member, rigid or resilient, intended to receive a suitable pin so as to make electrical contact.

2.5 Flameproof receptacle—that portion of a plug and receptacle having contacts consisting of pins and which is designed to receive the plug.

2.6 Flameproof restrained cable reel plug and receptacle—a special form of restrained plug and receptacle shaped to suit a right-angled entry into, and the periphery of, a cable reel drum.

2.7 Flameproof restrained coupling unit—an assembly incorporating two receptacle entries,

providing for the insertion and engagement of plugs for connecting two lengths of trailing cable.

2.8 Flameproof plug—that portion of a plug and receptacle having contacts consisting of sockets and which is attached to a trailing cable and is designed for engagement within the receptacle.

2.9 Flameproof restrained plug and receptacle—a device consisting of two portions having metallic contacts and arranged to engage and disengage with each other and also to be retained by means of a manually operated device. When their parts are properly assembled together with any associated equipment and cables, they comply with the relevant requirements of AS C98.

2.10 Phase barrier—a conductive barrier which is electrically connected to earth, and is secured in the contact insulation between the main contacts in both the plug and receptacle for the purpose of preventing inter-phase faults and of enabling current to be limited in a phase-to-earth fault.

2.11 Right hand cable reel receptacle—one that is fitted to an opposite standard drive shuttle car. (See Figs 3 and 6).

2.12 Left hand cable reel receptacle—one that is fitted to a standard drive shuttle car. (See Figs 5 and 6).

2.13 Scraping earth contact—a method employed to ensure electrical continuity of the earthing circuit between a plug and receptacle.

2.14 Trailing cable—a cable having stranded or bunched conductors, insulation, filling reinforcement or protective covering and specially designed to provide a flexible electrical connection between portable or mobile equipment and a fixed point or points.

2.15 Terminal—any device intended for the termination of a cable core conductor.

3 RATINGS AND COLOUR CODING.

3.1 Voltage. The standard voltages shall be 660 V and 1100 V.

3.2 Current. The standard currents shall be 60 A, 125 A, 150 A, and 300 A.

3.3 Colour Coding. The bodies of plugs and receptacles shall be colour coded as follows:

- (a) 660 V Orange to No 557 of AS K185.
- (b) 1100 V Blue to No 107 of AS K185.

4 SERVICE CONDITIONS.

4.1 General. Cable-coupling devices in accordance with this standard shall be suitable within the limits of their ratings for installation where the service conditions are not more severe than those stated in Clauses 4.2 to 4.4.