

AS 1349—1986

Reconfirmed 2018

Australian Standard[®]

**Bourdon tube pressure and
vacuum gauges**

[Title allocated by Defence Cataloguing Authority:
GAUGES, PRESSURE AND VACUUM
(Bourdon Tube Type) . . . NSC Gp 66]

This Australian standard was prepared by Committee MS/33, Pressure and Vacuum Gauges. It was approved on behalf of the Council of the Standards Association of Australia on 11 August 1986 and published on 5 September 1986.

The following interests are represented on Committee MS/33:

Australian Institute of Petroleum Ltd
Australian Society of Sugar Cane Technologists
Confederation of Australian Industry
Department of Defence
Electricity Supply Association of Australia
Institution of Engineers Australia
Institute of Instrumentation and Control
National Association of Testing Authorities Australia
Railways of Australia Committee

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic revision and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribers receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 1349–1986

**Bourdon tube pressure and
vacuum gauges**

RECONFIRMATION NOTICE

Major stakeholders of this publication have reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 29 August 2018.

NOTES

Currently in preview, click buy full vers.

Australian Standard[®]

**Bourdon tube pressure and
vacuum gauges**

First published	1973
Second edition	1986

Incorporating:
Amdt. 1—1987

PREFACE

This standard was prepared by the Association's Committee on Pressure and Vacuum Gauges, to supersede AS 1349–1973.

The standard was first published in 1973 and was based on BS 1780, Part 2—Bourdon Tube Pressure and Vacuum Gauges, which was rewritten to suit Australian conditions.

The preparation of this edition was undertaken for the purpose of updating the standard and, in particular, reviewing the requirements of Section 4, Performance and Testing, at the request of the National Association of Testing Authorities (NATA).

Revisions and additions contained in the one published amendment to the 1973 edition have been incorporated, and additional changes have been made in accordance with current SAA practice.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	4
1.4 UNIT OF PRESSURE	7
SECTION 2. GAUGE SIZES AND SCALE RANGES	
2.1 GAUGE SIZES	8
2.2 SCALE RANGES	8
SECTION 3. DESIGN AND CONSTRUCTION	
3.1 CASE	9
3.2 SHANK	10
3.3 BOURDON TUBE AND MOVEMENT	13
3.4 DIAL AND POINTER	13
3.5 DESIGNATION OF THE SCALE UNIT	14
3.6 SCALE MARKING	14
3.7 PROTECTION AGAINST CORROSION	15
3.8 REQUIREMENTS FOR SPECIFIC SERVICE TYPE PRESSURE GAUGES	15
3.9 GENERAL SAFETY REQUIREMENTS	16
SECTION 4. PERFORMANCE AND TESTING	
4.1 ACCURACY	17
4.2 OVERLOAD	17
4.3 TEST APPARATUS	17
4.4 TEST PROCEDURES	17
4.5 TEST REPORT AND RECORDS	17
SECTION 5. MARKING AND PACKAGING	
5.1 MARKING	18
5.2 PACKAGING	18
APPENDICES	
A NOTES ON THE CORRECTION OF DEADWEIGHT TESTERS AND MANOMETERS	19
B RECOMMENDATIONS FOR THE INSTALLATION AND USE OF PRESSURE GAUGES	21
C PURCHASING GUIDELINES	24

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard

for

BOURDON TUBE PRESSURE AND VACUUM GAUGES

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This standard specifies requirements for Bourdon tube pressure and vacuum gauges with circular concentric scales within the pressure range - 100 kPa to + 100 000 kPa, and the nominal size range (approximate dial diameter) 50 mm to 300 mm. Compound gauges (pressure and vacuum) are also included.

The gauges are graded according to accuracy, two grades being specified, viz test gauges and industrial gauges.

The gauges are generally suitable for use with fluids such as air, oil, water or steam, but special provision is made for gauges which are intended for high pressure applications, or for use with oxygen or acetylene, or with other reactive gases.

NOTES:

1. Recommendations regarding the installation and use of pressure gauges are given in Appendix B.
2. Guidelines for purchasers on specifying requirements when ordering gauges are given in Appendix C.

1.2 REFERENCED DOCUMENTS. The following standards are referred to in this standard:

AS 1110	ISO Metric Hexagon Precision Bolts and Screws
AS 1210	SAA Unfired Pressure Vessels Code
AS 1376	Conversion Factors
AS 1568	Copper and Copper Alloys-Forging Steels and Forgings
AS 1569	Copper and Copper Alloys-Seamless Tubes for Heat Exchangers
AS 1722	Pipe Threads of Whitworth Form. Part 1-Sealing Pipe Threads Part 2-Fastening Pipe Threads
AS 1835	Tubes for Pressure Purposes-Seamless Steel
AS 1836	Tubes for Pressure Purposes-Welded Steel
AS 2400	SAA Packaging Code
AS 2900.0	Quantities, Units, and Symbols-General Principles Concerning Quantities, Units, and Symbols
ANSI B2.2	Dryseal Pipe Thread
BS 3127	Specification for Ferrous and Non-ferrous Bourdon Tubing
BS 3692	Recommendations for the Design of Scales and Indexes Part 1-Instruments of Bold Presentation and for Rapid Reading Part 2-Indicating Instruments to be read to 0.33-1.25 per cent Resolution

1.3 DEFINITIONS.

1.3.1 Gauge types.

1.3.1.1 Pressure gauge-an instrument giving a visual indication, by means of a pointer relative to a scale, of the amount by which the pressure of a fluid applied to it exceeds the pressure of the surrounding atmosphere.

1.3.1.2 Vacuum gauge-an instrument giving a visual indication by means of a pointer relative to a scale, of the amount by which the pressure of a fluid applied to it is less than the pressure of the surrounding atmosphere.

1.3.1.3 Compound pressure gauge-an instrument giving a visual indication by means of a single pointer relative to a scale, of the amount by which the pressure of a fluid applied to it exceeds, or is less than, the pressure of the surrounding atmosphere. The scale is continuously graduated with zero at atmospheric pressure.

1.3.1.4 Duplex gauge-a gauge having two independent Bourdon tubes and two independent pressure connections, and a means to measure and indicate two independent pressures.

1.3.1.5 Differential gauge-a gauge having two pressure connections, and a means to measure and indicate the difference between two pressures.

1.3.1.6 Suppressed scale gauge-a gauge having a scale that starts at some point appreciably above zero.

1.3.1.7 Absolute pressure gauge-a gauge graduated to measure and indicate pressure above absolute zero pressure.

1.3.1.8 Receiver gauge-a gauge designed to measure and indicate the pneumatic signal from a pneumatic transmitter. The receiver gauge is generally calibrated in terms of the transmitter range which may include values of pressure, temperature, flow and other variables.

1.3.1.9 Retard gauge-a gauge having a scale in which either one or both ends is/are compressed.

1.3.1.10 Specific service type gauge-a gauge intended for a specific service such as for use with oxygen or acetylene.

1.3.2 Accuracy grades.

1.3.2.1 Accuracy grade-the grade into which an instrument falls by virtue of the specified limits of error with which it purports to comply.

1.3.2.2 Test gauge-a gauge of which the accuracy is such that the gauge is suitable for calibrating industrial gauges, and intended primarily for this purpose.

1.3.2.3 Industrial gauge-a gauge of which the accuracy is such that the gauge is suitable for general industrial use.