

Australian Standard[®]

Valves primarily for use in heated water systems

Part 1: Protection valves

STANDARDS
Australia



This Australian Standard® was prepared by Committee WS-026, Valves Primarily for Use in Warm and Hot Water Systems. It was approved on behalf of the Council of Standards Australia on 5 November 2003.
This Standard was published on 16 April 2004.

The following are represented on Committee WS-026:

- AUSTAP
 - Australian Association of Certification Bodies
 - Business New Zealand
 - Consumers' Federation of Australia
 - Gas Appliance Manufacturers Association of Australia
 - Housing Industry Association
 - Institute of Hospital Engineering Australia
 - Institute of Hospital Engineering Australia
 - Master Plumbers and Mechanical Contractors Association NSW
 - Metal Trades Industry Association of Australia
 - New Zealand Engineering Federation
 - New Zealand Society of Master Plumbers and Gasfitters
 - NSW Health Department
 - South Australian Health Commission
 - Water Corporation Western Australia
-

This Standard was issued in draft form for comment as Draft Standard S 02412.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through public comment.

Keeping Standards up to date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Valves primarily for use in heated water systems

Part 1: Protection valves

Originally as AS B271—1968.
Previous edition AS 1357.1—1992.
Third edition 2004.

Reissued incorporating Amendment No. 1 (October 2005).
Reissued incorporating Amendment No. 2 (February 2007).

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia
ISBN 0 7337 5630 1

PREFACE

This Standard was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee WS-026, Valves Primarily for Use in Warm and Hot Water Systems, to supersede AS 1357.1—1992, *Water supply—Valves for use with unvented water heaters, Part 1: Protection valves*.

This Standard incorporates Amendment No. 1 (October 2005) and Amendment No. 2 (February 2007). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide manufacturers with design, materials and performance requirements for protection valves.

This Standard includes Amendment No. 1 published in May 1996, Section 7 temperature relief valves and interim specification 426 for high-pressure expansion non-return valves (HPNR), Section 8.

Other standards covering heated water system valves include the following:

AS 1357.2 Vacuum relief valves, Thermosiphon arrestor valves, Inlet pressure control valves, Isolating valves.

AS 4032.1 Thermostatic mixing valves—Materials design and performance requirements

AS 4032.2 Tempering valves and end of line temperature actuated devices.

AS 4032.3 Water supply—Valves for the control of hot water supply temperatures—Requirements for field testing, maintenance or replacement of thermostatic mixing valves, tempering valves and end of line temperature control devices

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables and figures are deemed to be requirements of this Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 REFERENCED DOCUMENTS	6
1.3 DEFINITIONS	6
1.4 INSTRUMENTATION	7
1.5 MARKING	8
SECTION 2 MATERIALS	
2.1 GENERAL	9
2.2 CONTAMINATION OF WATER	9
2.3 CORROSION-RESISTANT METALLIC MATERIALS	9
2.4 COPPER	9
2.5 COPPER ALLOY	9
2.6 DEZINCIFICATION-RESISTANT (DR) COPPER ALLOY	9
2.7 STAINLESS STEEL	10
2.8 DIAPHRAGM, MATERIALS, AND VALVE SEATS	10
2.9 TEMPERATURE-SENSING PROBE	10
2.10 OTHER COMPONENT MATERIALS	10
SECTION 3 GENERAL DESIGN AND CONSTRUCTION	
3.1 GENERAL	11
3.2 STRENGTH	11
3.3 END CONNECTIONS	11
3.4 COMPONENTS AND VALVE SEATS	11
3.5 REMANUFACTURED VALVES	11
3.6 INSULATION OF TEMPERATURE/PRESSURE-RELIEF VALVES, TEMPERATURE-RELIEF VALVES, EXPANSION CONTROL VALVES AND COMBINATION HIGH-PRESSURE EXPANSION NON-RETURN VALVES	12
3.7 INSTRUCTIONS	13
SECTION 4 TEMPERATURE/PRESSURE-RELIEF VALVES	
4.1 GENERAL	14
4.2 INLET AND DRAIN CONNECTIONS AND FLOW DIMENSIONS	14
4.3 VALVE SEAT AND DISC ASSEMBLIES	16
4.4 SPRINGS PRESSURE-RELIEF FUNCTION	16
4.5 TESTING	16
4.6 EASING GEAR TEST	19
4.7 AUXILIARY PRESSURE-RELIEF DEVICE	20
4.8 PRESSURE-RELIEF FUNCTION	20
4.9 TEMPERATURE-RELIEF FUNCTION	21
4.10 MARKING	21
SECTION 5 EXPANSION CONTROL VALVES	
5.1 GENERAL	22
5.2 CONNECTIONS AND FLOW DIMENSIONS	22
5.3 VALVE SEAT AND DISC ASSEMBLIES	23
5.4 SPRINGS	23
5.5 TESTING	23
5.6 EASING GEAR	24

5.7	AUXILIARY PRESSURE-RELIEF DEVICE	24
5.8	EXPANSION-CONTROL VALVE FUNCTION	25
5.9	MARKING	26
SECTION 6 NON-RETURN VALVES		
6.1	GENERAL	27
6.2	INLET AND OUTLET CONNECTIONS.....	27
6.3	TESTING	27
6.4	FLOW RATE AND CLOSING PRESSURE	27
6.5	ENDURANCE TEST	28
6.6	ORIENTATION	28
6.7	MARKING	28
SECTION 7 TEMPERATURE-RELIEF VALVES		
7.1	GENERAL	29
7.2	INLET AND DRAIN CONNECTIONS AND FLOW DIMENSIONS	29
7.3	VALVE SEAT AND DISC ASSEMBLIES.....	31
7.4	SPRINGS.....	31
7.5	TESTING	31
7.6	EASING GEAR TEST	32
7.7	AUXILIARY PRESSURE-RELIEF DEVICE	33
7.8	TEMPERATURE-RELIEF FUNCTION	33
7.9	PRESSURE SETTING	34
7.10	MARKING	34
SECTION 8 COMBINATION HIGH PRESSURE EXPANSION NON-RETURN VALVES (HPNR)		
8.1	GENERAL	35
8.2	CONNECTIONS AND FLOW DIMENSIONS	35
8.3	VALVE SEAT AND DISC ASSEMBLIES.....	36
8.4	SPRINGS.....	36
8.5	TESTING	36
8.6	EASING GEAR.....	37
8.7	EXPANSION CONTROL VALVE FUNCTION.....	37
8.8	MARKING	38
APPENDICES		
A	MEANS FOR DEMONSTRATING COMPLIANCE WITH THIS STANDARD	39
B	REFERENCED DOCUMENTS	41
C	INSTRUMENTATION	43
D	MEASUREMENT OF NOISE EMISSION	44
E	TORQUE TEST.....	45
F	LEAKAGE TEST	47
G	EASING GEAR TEST FOR TEMPERATURE/PRESSURE-RELIEF VALVES, TEMPERATURE-RELIEF VALVES AND EXPANSION-CONTROL VALVES ...	49
H	AUXILIARY PRESSURE-RELIEF DEVICES	51
I	RATED EXPANSION CAPACITY TEST FOR TEMPERATURE/PRESSURE RELIEF VALVES AND EXPANSION CONTROL VALVES	53
J	WATER DISCHARGE CAPACITY TEST FOR TEMPERATURE AND PRESSURE-RELIEF VALVES AND TEMPERATURE-RELIEF VALVES	55
K	OPENING PRESSURE TEST AND RESEATING PRESSURE TEST FOR TEMPERATURE/PRESSURE-RELIEF VALVES AND EXPANSION-CONTROL VALVES	57

L	ENDURANCE (PRESSURE) TEST FOR TEMPERATURE/PRESSURE-RELIEF VALVES AND EXPANSION-CONTROL VALVES	60
M	OPENING AND RESEATING TEMPERATURE TESTS FOR TEMPERATURE/PRESSURE-RELIEF VALVES AND TEMPERATURE-RELIEF VALVES	62
N	ENDURANCE (TEMPERATURE RELIEF) TEST FOR TEMPERATURE/PRESSURE-RELIEF VALVES AND TEMPERATURE-RELIEF VALVES	64
O	STEAM DISCHARGE CAPACITY TEST FOR TEMPERATURE/PRESSURE-RELIEF VALVES AND TEMPERATURE-RELIEF VALVES	67
P	FLOW RATE TEST FOR NON-RETURN VALVES	70
Q	CLOSING PRESSURE TEST FOR NON-RETURN VALVES	72
R	ENDURANCE TEST FOR NON-RETURN VALVES	73
S	SAMPLING AND FREQUENCY PLANS FOR TEMPERATURE/PRESSURE-RELIEF VALVES	75
T	SAMPLING AND FREQUENCY PLANS FOR EXPANSION CONTROL VALVES	78
U	SAMPLING AND FREQUENCY PLANS FOR NON-RETURN VALVES	80
V	SAMPLING AND FREQUENCY PLANS FOR TEMPERATURE-RELIEF VALVES	82
W	SAMPLING AND FREQUENCY PLANS FOR COMBINATION HIGH-PRESSURE EXPANSION NON-RETURN VALVES (HPNR)	84

STANDARDS AUSTRALIA

Australian Standard

Valves primarily for use in heated water systems

Part 1: Protection valves

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out requirements for the design, construction, testing and performance of the following types of valves, within the range of DN 15 to DN 50:

- (a) Temperature/pressure-relief valves.
- (b) Expansion-control valves.
- (c) Non-return valves.
- (d) Temperature-relief valves.
- (e) Combination high-pressure expansion non-return valve (HPNR).

The valves specified in this Standard are primarily intended for use in warm and hot water systems that are required to operate at—

- (a) continuous operating temperatures not exceeding 85°C;
- (b) temperatures under emergency conditions, not exceeding 99°C; and
- (c) continuous working pressure not exceeding 1400 kPa.

For valves used with water heaters which are intended to operate at temperatures above 99°C (e.g. hot water boilers), see AS 1271.

Means for demonstrating compliance with this Standard are given in Appendix A.

1.2 REFERENCED DOCUMENTS

The documents referred to in this Standard are listed in Appendix B.

1.3 DEFINITIONS

For the purpose of this Standard, the definitions given in AS/NZS 3500.0 and those below apply.

1.3.1 Auxiliary pressure-relief device

Pressure-operated device forming part of an expansion control valve, temperature relief valve or temperature/pressure relief valve which in the event of blockage of the drain outlet provides—

- (a) expansion relief (expansion-control valves);
- (b) safety relief (temperature-relief valves); or
- (c) expansion and safety relief (temperature/pressure-relief valves).