

Australian Standard[®]

Design for access and mobility

**Part 4: Tactile ground surface
indicators for the orientation of
people with vision impairment**

This Australian Standard was prepared by Committee ME/64, Access for People with Disabilities. It was approved on behalf of the Council of Standards Australia on 20 December 1991 and published on 16 April 1992.

The following interests are represented on Committee ME/64:

Access Australia
ACROD
Australian Chamber of Manufactures
Australian Council on the Ageing
Australian National Council of and for the Blind
Australian Uniform Building Regulations Coordinating Council
Building Owners and Managers Association of Australia
Department of Administrative Services—Australian Construction Service
Department of Housing, New South Wales
Department of Local Government, Queensland
Master Builders Construction and Housing Association, Australia
National Committee of Independent Living Centres
Royal Australian Institute of Architects
Royal Melbourne Institute of Technology
South Australian Department of Housing and Construction
Telecom Australia

Additional interests participating in preparation of Standard:

Association for the Blind, Victoria
Royal Blind Society, New South Wales
Royal Society of the Blind, South Australia
VICROADS

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 91099.

Australian Standard[®]

Design for access and mobility

Part 4: Tactile ground surface indicators for the orientation of people with vision impairment

First published as AS 1428.4—1992

PREFACE

This Standard was prepared by the Standards Australia Committee on Access for People with Disabilities.

The ground surface indicators proposed in this Standard are designed to give warning of hazards, and directional information to pedestrians who are blind or who have impaired vision, through contact by foot or cane with the ground surface.

The design and installation requirements have been based on research on the ability of people who are blind or who have vision impairments to locate indicators and identify patterns on them, to be published in a report titled *A performance evaluation of selected tactile tiles under consideration for use by the vision impaired in Australia* (see Foreword).

CONTENTS

	<i>Page</i>
FOREWORD	3
1 SCOPE	4
2 REFERENCED DOCUMENTS	4
3 DEFINITIONS	4
4 MATERIALS	4
5 DESIGN REQUIREMENTS	4
6 INSTALLATION REQUIREMENTS	5
APPENDICES	
A RAISED PAVEMENT MARKERS	16
B TACTILE GROUND SURFACE INDICATORS—TYPICAL LAYOUT DETAILS	18

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

FOREWORD*

Blind pedestrians are subject to a wide range of possible dangers and inconveniences when travelling alone. Fortunately, many of these can be avoided through the use of communication systems which do not depend on vision.

Auditory information allows for communication at a distance, and can readily replace visual clues in some situations (e.g. audible traffic signals can substitute for visual 'Walk' and 'Don't Walk' signals). Still, there are many situations in which auditory information is either impractical or inadequate.

Tactile information is another satisfactory alternative for communication in selected cases. Blind people who use long canes can profit from tactile information which is detectable either by their canes or underfoot, and blind people who do not use canes can still profit from underfoot information.

In Japan, several types of tactile tiles have been installed in thousands of locations, and these tiles are used to communicate a variety of messages. As a group, these tiles are usually called 'braille tiles' (although they have nothing to do with the symbol system commonly called 'braille'). Some other Oriental and European countries have also installed braille tiles in selected locations.

However, despite the fact that braille tiles have been installed in many locations over the past 15 years, there are at least three reasons why evaluation of their usefulness is important before recommendations concerning installation of new locations are made:

- (a) Study of the value of the tiles in communicating with blind pedestrians in any location has been quite limited.
- (b) 'Braille tile' is a generic term which represents several different specific styles of tile, some of which may be more valuable than others in some applications.
- (c) The orientation and mobility training and habits of blind pedestrians in different parts of the world may contribute to different levels of performance by blind pedestrians with contact braille tiles.

A performance evaluation of selected tactile tiles under consideration for use by the vision impaired in Australia presents the results of several studies of the performance of a group of blind volunteers who attempted to detect selected tactile tiles, and their opinions relative to these tiles. The purpose of the study was to provide objective information on the probable value of specific tiles in particular installations. The three types of tiles evaluated were dome tiles, pathway tiles and braille road rivets.

* From the introduction to *A performance evaluation of selected tactile tiles under consideration for use by the vision impaired in Australia*, A.F. Peck, Boston College; M. Tauchi, Japan National Rehabilitation Centre; T. Murakami, Tokyo Metropolitan Rehabilitation Centre and M. Okhura, Seikei University.

STANDARDS AUSTRALIA

Australian Standard
Design for access and mobility

Part 4: Tactile ground surface indicators for the
orientation of people with vision impairment

1 SCOPE This Standard specifies requirements for the design and installation of tactile indicators for use on ground or floor surfaces to assist the mobility of people with vision impairment.

NOTE: Guidance on the type and installation of raised pavement markers to delineate pedestrian crossing areas are included in Appendix A and on the general installation layout of tactile ground surface indicators in Appendix B.

2 REFERENCED DOCUMENTS The following documents are referred to in this Standard:

AS

- | | |
|-----------|---|
| 1428 | Design for access and mobility |
| 1428.1 | Part 1: General requirements—Buildings |
| 1428.2 | Part 2: Enhanced and additional requirements—Buildings and facilities |
| 1683 | Methods of test for elastomers |
| 1683.4 | Method 4: Density of vulcanized rubber |
| 1683.11 | Method 11: Tension testing of vulcanized rubber |
| 1683.12 | Method 12: Tear resistance of vulcanized rubber |
| 1683.15.2 | Method 15.2: Durometer hardness |
| 1683.21 | Method 21: Rubber – Vulcanized – Determination of abrasion resistance using a rotating cylindrical device |
| 1683.23 | Method 23: Rubber – Vulcanized – Determination of resistance to liquids |
| 1683.24 | Method 24: Rubber – Vulcanized – Determination of resistance to ozone cracking – Static strain test |
| 1742 | Manual of uniform traffic control devices |
| 1742.10 | Part 10: Pedestrian control and protection |

ASTM

- | | |
|-------|---|
| D 573 | Test method for rubber – Deterioration in an air oven |
| D 575 | Test methods for rubber properties in compression |

3 DEFINITIONS For the purpose of this Standard, the definitions given in AS 1428.1 and those below apply.

3.1 Tactile indicators – patterned modules, which may be individual tiles, or strips of modules.

3.2 Directional pattern (elongated pattern) – a pattern that indicates the direction of travel to be taken.

3.3 Warning pattern (dot pattern) – a pattern that indicates a potential hazard or a change of direction.

4 MATERIALS

4.1 Tactile indicators for outdoor applications Tactile indicators for outdoor applications shall have a low rate of degradability, shall not be susceptible to fading by UV light, or to chipping, and shall be slip-resistant when wet or dry.

4.2 Tactile indicators made from natural or synthetic rubbers Tactile indicators made from natural or synthetic rubber shall comply with the test criteria shown in Table 1.

5 DESIGN REQUIREMENTS

5.1 Tactile indicators warning of hazards Tactile indicators warning of hazards shall be Type A as shown in Figure 1 or Type B as shown in Figure 2.

NOTE: Type B is preferable for use in wet areas.

5.2 Tactile indicators for directional guidance Tactile indicators for directional guidance shall be Type C as shown in Figure 3.