

Australian Standard[®]

**Methods for fire tests on building
materials, components and
structures**

**Part 4: Fire resistance tests of
elements of building construction**

This Australian Standard was prepared by Committee BD/18, Fire Tests. It was approved on behalf of the Council of Standards Australia on 3 October 1997 and published on 5 December 1997.

The following interests are represented on Committee BD/18:

Australian Building Codes Board
Australian Chamber of Commerce and Industry
Australian Fire Authorities Council
Australian Institute of Building
Australian Wool Testing Authority
Building Research Association of New Zealand
Bureau of Steel Manufacturers of Australia
Cement & Concrete Association of Australia
CSIRO—Division of Building Construction and Engineering
Fire Protection Association of Australia
National Association of Forest Industries
New Zealand Fire Protection Association
Plastics and Chemicals Industries Association
Scientific Services Laboratory
Society of Fire Protection Engineers NZ
Testing interests (Australia)

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard[®]

**Methods for fire tests on building
materials, components and
structures**

**Part 4: Fire-resistance tests of
elements of building construction**

Originated as part of AS A30—1935.
Previous edition AS 1530.4—1990.
Fourth edition 1997.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee BD/18, Fire Tests, to supersede AS 1530.4—1990.

This Standard is the result of a consensus among the representatives on the Joint Committee that it be produced as an Australian Standard.

The test method follows the basic principles and procedures contained in ISO 834: 1975, *Fire-resistance tests—Elements of building construction*. Relatively minor departures from the ISO recommendations have been made only where specific performance requirements for elements of building construction have been traditionally acceptable in Australia.

This edition addresses furnace control and furnace thermocouples so as to achieve uniformity with ISO 834.

Technical changes in this edition have been made to Sections 1, 2, 5, 6, 8 and 10, and changes of an editorial nature have been made to bring the Standard into line with current Standards Australia style.

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 PRINCIPLE	6
1.3 APPLICATION	6
1.4 REFERENCED DOCUMENTS	7
1.5 DEFINITIONS	7
1.6 LINEAR DIMENSIONS	8
SECTION 2 GENERAL REQUIREMENTS	
2.1 FURNACE	9
2.2 MEASUREMENT OF TEMPERATURE	9
2.3 MEASUREMENT OF TIME	12
2.4 MEASUREMENT OF DEFLECTION	12
2.5 MEASUREMENT OF EMITTED RADIANT HEAT FLUX	12
2.6 RECORDING OF TEMPERATURE	12
2.7 TEST SPECIMEN	12
2.8 LOADING AND RESTRAINT	13
2.9 TEST PROCEDURE	14
2.10 OBSERVATIONS	17
2.11 CRITERIA OF FAILURE	18
2.12 TEST RESULTS	18
2.13 DETERMINATION OF FIRE-RESISTANCE	19
2.14 REPORTING OF RESULTS	19
SECTION 3 WALLS AND PARTITIONS	
3.1 APPLICATION OF SECTION	20
3.2 TEST SPECIMEN	20
3.3 INSTRUMENTATION	20
3.4 LOADING AND RESTRAINT	20
3.5 TEST PROCEDURE	20
3.6 OBSERVATIONS	21
3.7 CRITERIA OF FAILURE	21
SECTION 4 FLOORS, ROOFS, FLOOR/CEILING SYSTEMS AND ROOF/CEILING SYSTEMS	
4.1 APPLICATION OF SECTION	22
4.2 TEST SPECIMEN	22
4.3 INSTRUMENTATION	22
4.4 LOADING AND RESTRAINT	25
4.5 TEST PROCEDURE	25
4.6 OBSERVATIONS	25
4.7 CRITERIA OF FAILURE	25
4.8 TEST RESULTS—INCIPIENT SPREAD OF FIRE	26
4.9 TEST REPORT	26

SECTION 5 COLUMNS

5.1	APPLICATION OF SECTION	27
5.2	TEST SPECIMEN—SIZE	27
5.3	INSTRUMENTATION	27
5.4	LOADING AND RESTRAINT	27
5.5	TEST PROCEDURE—HEAT EXPOSURE	28
5.6	OBSERVATIONS	28
5.7	CRITERIA OF FAILURE—STRUCTURAL ADEQUACY	28
5.8	DETERMINATION OF FIRE-RESISTANCE	28

SECTION 6 BEAMS, GIRDERS AND TRUSSES

6.1	APPLICATION OF SECTION	29
6.2	TEST SPECIMEN	29
6.3	INSTRUMENTATION	29
6.4	LOADING AND RESTRAINT	30
6.5	TEST PROCEDURE	30
6.6	OBSERVATIONS	30
6.7	CRITERIA OF FAILURE—STRUCTURAL ADEQUACY	30
6.8	DETERMINATION OF FIRE-RESISTANCE	30

SECTION 7 DOORSETS, SHUTTER ASSEMBLIES AND DAMPER ASSEMBLIES

7.1	APPLICATION OF SECTION	32
7.2	TEST SPECIMEN	32
7.3	INSTRUMENTATION	32
7.4	TEST PROCEDURE	33
7.5	OBSERVATIONS	33
7.6	CRITERIA OF FAILURE	34
7.7	DETERMINATION OF FIRE-RESISTANCE	35
7.8	TEST REPORT	35

SECTION 8 GLAZING

8.1	APPLICATION OF SECTION	36
8.2	TEST SPECIMEN	36
8.3	INSTRUMENTATION	36
8.4	TEST PROCEDURE	36
8.5	OBSERVATIONS	36
8.6	CRITERIA OF FAILURE—INTEGRITY	36
8.7	DETERMINATION OF FIRE-RESISTANCE	36
8.8	TEST REPORT	36

SECTION 9 AIR DUCTS

9.1	APPLICATION OF SECTION	37
9.2	TEST SPECIMEN	37
9.3	POSITIONING OF THERMOCOUPLES	37
9.4	PROCEDURE	38
9.5	OBSERVATIONS	38
9.6	CRITERIA OF FAILURE	39
9.7	TEST REPORT	39

Page

SECTION 10 ELEMENTS PENETRATED BY SERVICES

10.1	APPLICATION OF SECTION	40
10.2	TEST SPECIMEN	40
10.3	POSITIONING OF THERMOCOUPLES	41
10.4	TEST PROCEDURE	41
10.5	OBSERVATIONS	41
10.6	CRITERIA OF FAILURE	42
10.7	TEST REPORT	42
APPENDIX A RADIANT HEAT FLUX MEASUREMENTS		43

Currently in preview, click buy full version

STANDARDS AUSTRALIA

Australian Standard

Methods for fire tests on building materials, components and structures

Part 4: Fire-resistance tests of elements of building construction

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE This Standard applies to heating conditions, test procedures, and criteria for the determination of fire-resistance of an element of building construction. In most cases, a single test, carried out in accordance with this Standard, establishes the fire-resistance for the element of construction concerned.

In addition to providing information on which the fire-resistance of an element of construction can be assessed, the test report includes information which may be of use to the designer. (Records of temperature at critical times may be used by a designer to assess the fire-resistance of a variant of the tested prototype flexural member where the procedure for such an assessment is defined in the appropriate design code.)

In certain cases, the test methods described herein provide information for the determination of—

- (a) resistance to the incipient spread of fire through ceiling systems;
- (b) safe distances for the spacing of combustible materials from elements that provide a separating function;
- (c) radiant heat flux emitted from door sets, shutter assemblies, damper assemblies and glazing; and
- (d) the free cross-sectional area of air ducts to provide functional operation while providing fire-resistance.

1.2 PRINCIPLE A representative specimen of an element of construction is conditioned and then exposed to heat under controlled conditions in a furnace which is operated to satisfy a specified time/temperature curve. In order to minimize the effect of variation in ambient temperature on the outcome of the test, the heating curve is expressed in terms of temperature increments above ambient rather than actual temperature. Where it is not possible to model the element or system of construction satisfactorily with one specimen, it may be necessary to test more than one specimen. Observations are made on the performance of the specimen while it is subjected to thermal and, where applicable, physical loading. The elapsed times at which various failures occur are recorded.

1.3 APPLICATION

1.3.1 Fire hazard assessment The results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions.

Each test shall be performed in accordance with the general requirements of Section 2 and with the following Sections, as appropriate:

- (a) Section 3—Walls and partitions.
- (b) Section 4—Floors, roofs, floor/ceiling systems and roof/ceiling systems.