

Australian Standard®

---

**Automatic fire detection and alarm systems**

**Part 5: Manual call points**

---

**STANDARDS AUSTRALIA** 



This Australian Standard was prepared by Committee FP/2, Automatic Fire Detection and Alarm Systems. It was approved on behalf of the Council of Standards Australia on 10 September 1990 and published on 11 February 1991.

---

The following interests are represented on Committee FP/2:

Attorney-Generals Department  
Australian Assembly of Fire Authorities  
Australian Association of Rural Fire Authorities  
Australian Electrical and Electronic Manufacturers Association  
Australian Fire Protection Association  
Australian Uniform Building Regulations Coordinating Council  
Board of Fire Commissioners, New South Wales  
Civil Aviation Authority  
Commonwealth Fire Board  
Confederation of Australian Industry  
CSIRO, Division of Building, Construction and Engineering  
Department of Administrative Services  
Fire Protection Industry Association of Australia  
Insurance Council of Australia  
Telecom Australia

---

*Revisions to Australian Standards.* To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

*Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.*

*Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.*

---

Australian Standard®

---

**Automatic fire detection and alarm  
systems**

**Part 5: Manual call points**

---

First published as part of AS 2036—1977.  
AS 2036—1977 revised and redesignated in part as  
AS 1603.5—1991.

PUBLISHED BY STANDARDS AUSTRALIA  
(STANDARDS ASSOCIATION OF AUSTRALIA)  
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY NSW

ISBN 0 7262 6570 5

## PREFACE

This Standard was prepared by the Standards Australia Committee on Automatic Fire Detection and Alarm Systems, to supersede AS 2036—1977, *Manually operated fire alarm call points*.

This Standard differs from the 1977 edition by the inclusion of environmental tests and a section on assessment of compliance.

The various components of automatic fire detection and alarm systems are being specified in the following Standards:

- |                                       |            |
|---------------------------------------|------------|
| (a) Heat detectors                    | AS 1603.1. |
| (b) Point type smoke detectors        | AS 1603.2. |
| (c) Flame detectors                   | AS 1603.3. |
| (d) Control and indicating equipment  | AS 1603.4. |
| (e) Manual call points                | AS 1603.5. |
| (f) Fire alarm bells                  | AS 1603.6. |
| (g) Beam type optical smoke detectors | AS 1603.7. |
| (h) Sampling systems                  | AS 1603.8. |

Specifications for the design, installation and maintenance of fire detection and alarm equipment, and the testing of actuating devices have been published as follows:

### AS

1670 *Automatic fire detection and alarm systems—System design, installation, and commissioning*

1851 *Maintenance of fire protection equipment*

1851.8 Part 8: *Automatic fire detection and alarm systems*

2362 *Automatic fire detection and alarm systems—Methods of test for actuating devices*

### © Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the Head Office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

	<i>Page</i>
<b>SECTION 1. SCOPE AND GENERAL</b>	
1.1 SCOPE .....	4
1.2 APPLICATION .....	4
1.3 REFERENCED DOCUMENTS .....	4
1.4 DEFINITIONS .....	4
<b>SECTION 2 DESIGN, CONSTRUCTION AND MARKING</b>	
2.1 DESIGN .....	5
2.2 CONSTRUCTION .....	5
2.3 ENCLOSURES .....	5
2.4 MARKING .....	5
<b>SECTION 3 PERFORMANCE REQUIREMENTS</b>	
3.1 GENERAL .....	7
3.2 INSULATION RESISTANCE .....	7
3.3 VOLTAGE STABILITY .....	7
3.4 STATIC DISCHARGE .....	7
3.5 ELECTROMAGNETIC INTERFERENCE .....	7
3.6 IMPULSE VOLTAGE WITHSTAND .....	7
3.7 HIGH-FREQUENCY DISTURBANCE .....	7
3.8 LOW-TEMPERATURE AND HEAT .....	7
3.9 CORROSION .....	8
3.10 VIBRATION .....	8
3.11 IMPACT .....	8
3.12 WEATHERING .....	8
3.13 COVER FRANGIBILITY .....	8
3.14 STRENGTH OF SCREW THREADS AND FININGS .....	8
3.15 FUNCTIONAL TEST .....	8
<b>SECTION 4 ASSESSMENT OF COMPLIANCE</b>	
4.1 GENERAL .....	9
4.2 INFORMATION FOR THE TESTING ORGANIZATION .....	9
4.3 POINT OF SALE INFORMATION .....	9
4.4 TEST SCHEDULE AND CRITERIA OF ACCEPTANCE .....	9
4.5 REPORTING .....	9

## STANDARDS AUSTRALIA

## Australian Standard

## Automatic fire detection and alarm systems

## Part 5: Manual call points

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE** This Standard specifies requirements for the design and performance of manually operated call points for use in fire detection and alarm systems.

**1.2 APPLICATION** This Standard applies to manual call points installed in accordance with AS 1670 and connected to control and indicating equipment complying with AS 1603.4.

**1.3 REFERENCED DOCUMENTS** The following documents are referred to in this Standard:

## AS

1603 Automatic fire detection and alarm systems

1603.4 Part 4: Control and indicating equipment

1670 Automatic fire detection and alarm systems—System design, installation, and commissioning

1939 Classification of degrees of protection provided by enclosures for electrical equipment

2362 Automatic fire detection and alarm systems—Methods of test for actuating devices

2362.4 Method 4: Voltage stability test

2362.6 Method 6: Static discharge test

2362.7 Method 7: Electromagnetic interference test

2362.8 Method 8: Impulse voltage withstand test

2362.9 Method 9: High-frequency disturbance test

2362.10 Method 10: Low-temperature test

2362.11 Method 11: Damp heat test

2362.12 Method 12: Dry heat test

2362.13 Method 13: Corrosion test

2362.15 Method 15: Vibration test

2362.16 Method 16: Impact test

2362.23 Method 23: Weathering test

2362.24 Method 24: Frangibility test

2484 Fire—Glossary of terms

2484.1 Part 1: Fire tests

2484.2 Part 2: Fire protection and firefighting equipment

2700 Colour standards for general purposes

3000 SAA Wind Rules

3100 Approval and test specification—Definitions and general requirements for electrical materials and equipment

**1.4 DEFINITIONS** For the purpose of this Standard, the definitions given in AS 2484.2 and that below apply.

**1.4.1 Manual call point**—a manually actuated mechanism to operate electrical contacts or circuits to initiate an alarm state signal.