

Australian Standard™

**The use of ventilation and  
airconditioning in buildings**

**Part 3: Smoke control systems for large  
single compartments or smoke  
reservoirs**



This Australian Standard was prepared by Committee ME-062, Ventilation and Airconditioning. It was approved on behalf of the Council of Standards Australia on 22 December 2000 and published on 17 December 2001.

---

The following interests are represented on Committee ME-062:

Airconditioning and Mechanical Contractors Association of Australia  
Air-conditioning and Refrigeration Equipment Manufacturers Association of Australia  
Australian Fire Authorities Council  
Australian Buildings Code Board  
Australian Industry Group  
Australian Institute of Building  
Australian Institute of Building Surveyors  
Australian Institute of Refrigeration Air conditioning and Heating  
Chartered Institution of Building Services Engineers  
Department of Contract and Management Services, W.A.  
F.P.A. Australia  
Institution of Refrigeration Heating and Airconditioning Engineers, New Zealand  
enHealth Council  
Plastics and Chemicals Industries Association Incorporated  
Property Council of Australia  
Thermal Insulation Contractors Association of Australia

---

#### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at [www.standards.com.au](http://www.standards.com.au) and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.com.au](mailto:mail@standards.com.au), or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

---

Australian Standard™

**The use of ventilation and  
airconditioning in buildings**

**Part 3: Smoke control systems for large  
single compartments or smoke  
reservoirs**

First published as AS 1668.3—2001.

**COPYRIGHT**

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd  
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 3733 1

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee ME-062, Ventilation and Airconditioning.

The Standard does not identify those buildings in which smoke control systems are required. This is covered in the Building Code of Australia (BCA).

The objective of this document is to provide a standardized methodology for the design of smoke control systems, utilizing exhaust from above the hot layer, for use by system owners, regulators, designers and installers.

In the preparation of this Standard, consideration has been given to the following—

- (a) British Standard Institute, Draft for development DD 240: Part 1:1997, Fire safety engineering in buildings, Part 1: Guide to the application of fire safety engineering principles.
- (b) BS 7346 Parts 1–3 inclusive, Performance of fans, vents and smoke curtains commensurate with likely fire impact (consolidated into this Standard).
- (c) CIBSE, Technical Memoranda TM19, Relationships for Smoke Control Calculations (1995).
- (d) Building Research Establishment Report, Design principles for smoke ventilation in enclosed shopping centres (1990).
- (e) Building Research Establishment Report: Sprinkler Operation and the Effect of Venting: Studies Using a Zone Model.
- (f) Building Research Establishment Report: Design Principles for Smoke Ventilation in Enclosed Shopping Centres.
- (g) Building Control Commission, Smoke Management in Large Spaces in Buildings.
- (h) Fire Brigade Intervention Model, pre-publication version 2.1, November 1997, Australasian Fire Authorities Council.
- (i) Micro-economic Reform, Fire Regulation—Building Regulation Review Task Force May 1991. The concept of a 'Time Line' and the impact of resources to combat a fire has been considered.
- (j) Fire Code Reform Centre, Fire Engineering Guidelines.
- (k) The N.F.P.A. 923, 'T' squared fire concept has also been utilized in the development of this Standard.
- (l) Adelaide University, C.S.I.R.O. and South Australian Metropolitan Fire Service Data: recorded whilst fire and smoke testing within Australian buildings.

The term 'informative' has been used in this Standard to define the application of the appendix to which they apply. An 'informative' appendix is only for information and guidance.

*This Standard incorporates a Commentary on some clauses. The Commentary directly follows the relevant Clause, is designated by 'C' preceding the clause number and is printed in italics in a panel. The Commentary is for information only and does not need to be followed for compliance with the Standard.*

## CONTENTS

	<i>Page</i>
FOREWORD .....	5
SECTION 1 GENERAL	
1.1 SCOPE .....	6
1.2 DESIGN PARAMETERS .....	6
1.3 PRINCIPLES .....	7
1.4 APPLICATION.....	7
1.5 REFERENCED DOCUMENTS .....	9
1.6 DEFINITIONS.....	10
1.7 NEW DESIGNS AND INNOVATIONS.....	12
SECTION 2 SEQUENTIAL DESIGN PROCESS	
2.1 SCOPE OF SECTION.....	13
2.2 KEY INPUT DESIGN PARAMATERS .....	13
2.3 SYSTEM SELECTION.....	13
2.4 EQUIPMENT SIZING .....	13
2.5 MAKE-UP AIR.....	13
2.6 DETAILED DESIGN.....	13
2.7 CONTROL AND ACTUATION.....	13
SECTION 3 MECHANICAL SMOKE CONTROL	
3.1 SCOPE OF SECTION.....	14
3.2 GENERAL .....	14
3.3 EXHAUST CAPACITY.....	14
3.4 TEMPERATURE/DURATION COMPENSATION.....	14
3.5 SMOKE EXHAUST FANS .....	14
SECTION 4 BUOYANCY-DRIVEN SMOKE CONTROL	
4.1 SCOPE OF SECTION.....	15
4.2 SYSTEM COMPONENTS .....	15
4.3 VENT SELECTION .....	15
4.4 VENTS .....	15
SECTION 5 SMOKE RESERVOIRS AND EXHAUST OPENING PERIMETER	
5.1 SCOPE OF SECTION.....	19
5.2 SIZE OF SMOKE RESERVOIRS.....	19
5.3 DEPTH .....	19
5.4 CONSTRUCTION .....	20
5.5 RETRACTABLE SMOKE CURTAINS .....	20
5.6 CEILINGS .....	21
5.7 MINIMUM EXHAUST OPENING PERIMETER.....	21
SECTION 6 MAKE-UP AIR REQUIREMENTS	
6.1 SCOPE OF SECTION.....	29
6.2 GENERAL .....	29
6.3 BUOYANCY-DRIVEN SYSTEMS.....	29
6.4 MECHANICAL SMOKE EXHAUST SYSTEMS .....	30
6.5 MAKE-UP AIR FROM INTERCONNECTED VOLUMES .....	30

## SECTION 7 GENERAL SYSTEM REQUIREMENTS

7.1	SCOPE OF SECTION.....	32
7.2	WIRING.....	32
7.3	SYSTEM COMPONENTS .....	32
7.4	VIBRATION.....	32
7.5	NOISE.....	32
7.6	NON-ELECTRICAL CONTROL EQUIPMENT .....	33
7.7	LOCATION OF EXTERNAL OPENINGS AND VENTS.....	33

## SECTION 8 CONTROL

8.1	SCOPE OF SECTION.....	35
8.2	AUTOMATIC INITIATION OF SMOKE CONTROL.....	35
8.3	OPERATION OF SMOKE CONTROL .....	35
8.4	MANUAL OVERRIDE FACILITY .....	36
8.5	SYSTEM PLAN.....	37

## SECTION 9 COMMISSIONING

9.1	SCOPE OF SECTION.....	38
9.2	GENERAL .....	38
9.3	PRE-COMMISSIONING PROCEDURES.....	38
9.4	COMMISSIONING .....	38
9.5	EMERGENCY POWER .....	39

## APPENDICES

A	DEVELOPMENT OF KEY INPUT DESIGN PARAMETERS .....	40
B	DESIGN FIRE .....	44
C	FIRE CONTROL TIME.....	51
D	HOT LAYER PARAMETERS.....	60
E	PRINCIPLES OF SMOKE CONTROL AND SYSTEM SELECTION.....	64
F	APPLICATION OF STANDARD.....	67
G	EXAMPLE OF APPLIED DESIGN METHODOLOGY.....	75
H	GENERAL DESIGN INFORMATION.....	83
I	BUILDING GEOMETRY .....	85
J	WIRING SYSTEMS RATING.....	86

## FOREWORD

The intent of this Standard is to provide a structured prescriptive method for the design of smoke control systems in large single compartments or smoke reservoirs. Systems designed in accordance with this Standard are required to have a performance graded to the characteristics of a particular risk.

The outcome of the methodology employed by this Standard will be a relative grading of the interactions of fire load, building characteristics and fire intervention systems. As with other fire Standards (e.g. AS 1530 series of Standards) this Standard does not predict system performance under actual building fire conditions.

Systems are designed to operate under prescribed interior fire conditions influenced by such factors as enclosure volume, fire growth rate and active suppression systems. The period of time the system is required to operate is affected by the safety risk and resources available to fight the fire.

## STANDARDS AUSTRALIA

## Australian Standard

## The use of ventilation and airconditioning in buildings

## Part 3: Smoke control systems for large single compartments or smoke reservoirs

## SECTION 1 GENERAL

## 1.1 SCOPE

This Standard sets minimum requirements for the design of smoke control systems in large single compartments in which smoke accumulates in a smoke reservoir. It sets minimum requirements considered necessary to meet the system design objectives in terms of continuous operation over a specified time period under a specified fire condition.

The design information given in this Standard is based on axisymmetric plumes. Compartments and smoke reservoirs are designed separately and spill plumes between compartments/reservoirs are not considered.

This Standard is not appropriate in situations where a stable buoyant hot layer does not exist.

## NOTES:

- 1 Smoke control in multi-compartment buildings is covered in AS/NZS 1668.1.
- 2 This Standard should only be applied to areas with greater than 3 m floor to ceiling or upper bounding layer height.
- 3 AS 1851.5 and AS/NZS 1851.6 outline management procedures for maintaining smoke and heat vents and the fire and smoke control features of air-handling systems.

## 1.2 DESIGN PARAMETERS

This Standard specifies minimum requirements for the design of mechanical and buoyancy-driven smoke control systems relying on the removal of smoke from a buoyant hot layer within a smoke reservoir. The method of system design is based on key input design parameters. These key input design parameters include —

- (i) total fire heat output ( $\dot{Q}_c$ );
- (ii) volumetric exhaust flow rate ( $\dot{V}$ );
- (iii) hot layer temperature ( $T_L$ );
- (iv) hot layer depth ( $d$ ); and
- (v) system duration time ( $t_d$ ).

Such design parameters are required before system design is undertaken. They may be developed for a particular building from consideration of a Fire Engineering Design Brief (FEDB) or from the application of the information and calculations contained in this Standard. Design parameters will vary depending on the objectives of the smoke control system.

NOTE: Guidance on the selection/development of these design parameters is provided in the Fire Engineering Guidelines or in Appendix A.