



**Fire detection, warning, control and
intercom systems—System design,
installation and commissioning**

Part 1: Fire

This Australian Standard® was prepared by Committee FP-002, Fire detection, Warning, Control and Intercom Systems. It was approved on behalf of the Council of Standards Australia on 12 October 2015.

This Standard was published on 14 December 2015.

The following are represented on Committee FP-002:

- Association of Hydraulic Services Consultants Australia
 - Australasian Fire and Emergency Service Authorities Council
 - Australian Building Codes Board
 - Australian Chamber of Commerce and Industry
 - Australian Industry Group
 - Australian Institute of Building Surveyors
 - CSIRO
 - Deafness Forum of Australia
 - Department of Human Services, Vic.
 - Engineers Australia
 - Fire Protection Association Australia
 - National Electrical and Communications Association
 - National Fire Industry Association
 - Property Council of Australia
 - Society of Fire Safety
-

This Standard was issued in draft form for comment as DR AS 1670.1:2015.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

**Fire detection, warning, control and
intercom systems—System design,
installation and commissioning**

Part 1: Fire

Originally as part of AS CA15—1961.
Previous edition AS 1670.1—1995.
AS 1670.1—1995 and AS 1670.2—1997 revised,
amalgamated and designated as AS 1670.1—2004.
Second edition AS 1670.1:2015.
Reissued incorporating Amendment No. 1 (November 2017).

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

PREFACE

This Standard was prepared by the Standards Australia Committee FP-002, Fire Detection, Warning, Control and Intercom Systems, to supersede AS 1670.1—2004.

This Standard incorporates Amendment No. 1 (November 2017). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

The objective of this revision is to adopt a number of AS 7240 Standards which have been published since 2004, to increase flexibility of design and installation and to simplify the design and installation requirements to meet the National Construction Code.

Many of the Australian equipment Standards referenced in this Standard are intended to be removed from a future revision of this standard. The Standards to be removed are listed in Clause 1.3.

Statements expressed in mandatory terms in notes to Figures and Tables are deemed to be requirements of this Standard.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendices to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

This Standard incorporates commentary on some of the clauses. The commentary directly follows the relevant clause, is designated by 'C', preceding the clause number and is printed in italics in a box. The commentary is for information only and does not need to be followed for compliance with the Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	5
1.2 APPLICATION	5
1.3 NORMATIVE REFERENCES	5
1.4 DEFINITIONS.....	8
1.5 ABBREVIATIONS	11
1.6 MEASUREMENTS	14
1.7 SYSTEM DESIGN	15
SECTION 2 SYSTEM CONFIGURATION	
2.1 EQUIPMENT	17
2.2 DESIGNATED ENTRY POINT	18
2.3 ZONE LIMITATIONS—DETECTION ZONES	19
2.4 NETWORKED FDCIE	21
2.5 DISTRIBUTED PARTS OF FDCIE	21
2.6 TRANSMISSION PATHS FAULTS	21
SECTION 3 INSTALLATION REQUIREMENTS	
3.1 GENERAL.....	23
3.2 ALARM ACKNOWLEDGMENT FACILITY (AAF).....	23
3.3 ALARM VERIFICATION FACILITY (AVF).....	23
3.4 ALARM DELAY FACILITY (ADF).....	24
3.5 ALTERATIONS TO EXISTING INSTALLATIONS.....	25
3.6 CONTROL OF ANCILLARY DEVICES	25
3.7 DETECTOR ALARM INDICATION.....	25
3.8 EXTERNAL ALARM INDICATION	25
3.9 FIRE DETECTION CONTROL AND INDICATING EQUIPMENT (FDCIE).....	26
3.10 ZONE BLOCK PLAN	27
3.11 CO FIRE DETECTOR LABELLING	27
3.12 FIRE SUPPRESSION SYSTEM ALARMS	27
3.13 FIRE SUPPRESSION SYSTEM CONTROL	28
3.14 EQUIPMENT ENCLOSURE	28
3.15 MANUAL CALL POINT (MCP)	28
3.16 POWER SUPPLY EQUIPMENT (PSE)	28
3.17 REMOVE INDICATORS FOR FIRE DETECTORS	31
3.18 THIS HAS BEEN LEFT BLANK INTENTIONALLY	31
3.19 SMOKE AND FIRE DOOR CONTROL	31
3.20 ELECTRIC LOCK RELEASE.....	32
3.21 SUPPRESSION SYSTEM MONITORING DEVICES.....	32
3.22 OCCUPANT WARNING	32
3.23 WIRE-FREE TRANSMISSION PATHS	34
3.24 CABLING SYSTEMS	34
3.25 TRANSMISSION PATH SUPERVISION.....	35
3.26 TRANSMISSION PATH PROTECTION.....	36
3.27 LOCATION OF DETECTORS.....	36
3.28 LOCATIONS WHERE DETECTORS ARE NOT REQUIRED	41
3.29 COMBINATION DETECTORS.....	41

SECTION 4 HEAT DETECTORS	
4.1	SPACING AND LOCATION OF POINT-TYPE HEAT DETECTORS 42
4.2	LINEAR HEAT DETECTORS..... 47
SECTION 5 SMOKE AND CARBON MONOXIDE (CO) FIRE DETECTORS	
5.1	SPACING AND LOCATION OF POINT-TYPE DETECTORS 48
5.2	ASPIRATING SMOKE DETECTORS..... 56
SECTION 6 FLAME DETECTORS	
6.1	LOCATION..... 58
6.2	SPACING..... 58
SECTION 7 SMOKE CONTROL SYSTEMS	
7.1	GENERAL..... 59
7.2	SYSTEM OBJECTIVES..... 59
7.3	CONSULTATION BETWEEN PARTIES..... 59
7.4	AUTOMATIC INITIATION OF SMOKE CONTROL SYSTEMS..... 60
7.5	AUTOMATIC SMOKE DETECTION FOR SYSTEM CONTROL..... 61
7.6	MISCELLANEOUS SYSTEMS..... 67
7.7	SUPPLY AIR SYSTEMS..... 69
7.8	KITCHEN EXHAUST HOOD SYSTEMS..... 70
7.9	SHUTDOWN SYSTEMS—OPERATION IN FIRE MODE..... 71
7.10	ZONE PRESSURIZATION SYSTEMS..... 71
7.11	HOT LAYER SMOKE CONTROL SYSTEM..... 71
7.12	ANCILIARY SMOKE/FIRE CONTROL EQUIPMENT OPERATION..... 72
7.13	FIRE ISOLATED EXIT PRESSURIZATION SYSTEMS..... 72
7.14	LIFT SHAFT PRESSURIZATION SYSTEM..... 72
7.15	FIRE FAN CONTROL PANEL (FFCP)..... 75
7.16	EQUIPMENT ENCLOSURE..... 79
7.17	SYSTEM INTERFACE..... 79
7.18	TRANSMISSION PATHS..... 81
7.19	DOCUMENTATION..... 81
APPENDICES	
A	GUIDANCE FOR THE SELECTION OF DETECTORS 83
B	WIRING SYSTEMS..... 101
C	EXAMPLES OF POWER SOURCE CAPACITY CALCULATIONS 103
D	FIRE ALARM SYMBOLS..... 105
E	SYSTEM DESIGNER'S STATEMENT..... 108
F	STANDARD FORM OF INSTALLER'S STATEMENT FOR AUTOMATIC FIRE DETECTION AND ALARM SYSTEM 110
G	SYSTEM COMMISSIONING STATEMENT..... 111
H	SOUND PRESSURE LEVEL MEASUREMENT 112
I	ASD SENSITIVITY CLASSES..... 113
J	COMMISSIONING..... 114
K	RECOMMENDED ORIENTATION OF DUCT SAMPLING SMOKE DETECTOR PROBES 120
BIBLIOGRAPHY..... 122	

STANDARDS AUSTRALIA

Australian Standard**Fire detection, warning, control and intercom systems—System design, installation and commissioning****Part 1: Fire**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out requirements for the design, installation and commissioning of fire detection and alarm systems comprising components complying with the requirements of the appropriate product Standards. Specific requirements suppression for special hazards systems are outside the scope of this standard.

NOTES:

- 1 Where detection and control and indicating equipment forms part of a smoke control system in accordance with AS/NZS 1668.1, specific requirements are specified in Section 7.
- 2 Where detection and control and indicating equipment forms part of a special hazard system in accordance with AS 4214 series, the additional requirements are covered in AS 1670.5 Fire—Special Hazards.
- 3 Commissioning requirements are set out in Appendix I.
- 4 Maintenance requirements for fire detection and alarm equipment are given in the relevant sections of AS 1851.

1.2 APPLICATION

All fire detection and alarm systems shall comply with the requirements of Section 2 and Section 3, Section 4, Section 5, Section 6 and Section 7.

This standard requires that detection be provided throughout all areas of the building; however where systems are installed to solely meet the requirements of the NCC refer to the NCC for areas to be protected.

1.3 NORMATIVE REFERENCES

The following are the normative reference documents in this Standard:

NOTE: Documents referenced for informative purposes are listed in the Bibliography.

AS

1603	Automatic fire detection and alarm systems
1603.1	Part 1: Heat detectors
1603.2	Part 2: Point type smoke detectors
1603.3	Part 3: Heat alarms
1603.5	Part 5: Manual call points
1603.7	Part 7: Optical beam smoke detectors
1603.8	Part 8: Multi-point aspirated smoke detectors
1603.11	Part 11: Visual warning devices
1603.13	Part 13: Duct sampling units
1603.14	Part 14: Point type carbon monoxide (CO) fire detectors
1603.17	Part 17: Warning equipment for people with hearing impairment