

Australian Standard[®]

SAA Gas Pipeline Code

This standard, prepared by Committee ME/38, Gas and Liquid Petroleum Piping Systems, was approved on behalf of the Council of the Standards Association of Australia on 23 January 1981, and was published on 1 July 1981.

The following scientific, industrial and governmental organizations and departments were officially represented on the committee entrusted with the preparation of this standard:

Australasian Corrosion Association
Australasian Institute of Mining and Metallurgy
Australian Gas Association
Australian Institute for Non-destructive Testing
Australian Institute of Energy
Australian Institute of Petroleum
Australian Liquefied Petroleum Gas Association
Australian Petroleum Exploration Association
Australian Pipelines Industry Association
Australian Welding Institute
Australian Welding Research Association
Bureau of Steel Manufacturers of Australia
Department of Industrial Relations, N.S.W.
Department of Minerals and Energy, Victoria
Department of Mines and Energy, S.A.
Department of Mines, Queensland
Department of Mines, W.A.
Energy Authority of New South Wales
Institution of Engineers Australia
Institute of Petroleum, C.I.P.
Metal Trades Industry Association of Australia
National Association of Australian State Road Authorities
New South Wales Institute of Technology
Pipelines Authority
Pipelines Authority of South Australia
Railway of Australia Committee
Snowy Mountains Engineering Corporation

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This standard was issued in part in draft form for public review as DR 79058.

Australian Standard[®]

**Gas Transmission
and Distribution Systems**

known as the

SAA Gas Pipeline Code

First published (as AS CB28)	1972
AS 1697 first published	1975
Second edition	1979
Third edition	1981

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 2203 8

PREFACE

This edition of this standard was prepared by the Association's Committee on Gas and Liquid Petroleum Piping Systems. This edition includes an additional section, i.e. Section 12—Corrosion Mitigation, which replaces and expands previous requirements which were specified in Clause 3.4. Related Clauses 2.9 and 2.10 covering material requirements have also been revised and further minor changes, including editorial updating, have been made. The items which have been revised in this edition are listed in the 'Annex' following the Index. It should be noted that Appendix F to the 1975 edition was deleted by Amendment No 3, but the original references to the other Appendices have been retained in order to facilitate reference to them.

The purpose of this standard is to provide guidance on safety requirements for design, construction, operation and maintenance of gas transmission and distribution systems.

The standard sets out requirements for good engineering practice based on known experience and on appropriate existing standards, both Australian and overseas. In its preparation close attention was given to the American National Standard Code for Pressure Piping—Gas Transmission and Distribution Piping Systems, ANSI B3 1.8—the Canadian Standard for Gas Transmission and Distribution Systems, CSA Z184; the Institution of Gas Engineers Recommendations on Transmission and Distribution Practice; the Institute of Petroleum Model Code of Safe Practice, Part VI—Petroleum Pipelines, and Part VIII—Pipeline Operations in Marine Areas; the Department of Transportation—Office of Pipeline Safety, U.S.A., Federal Register Vol. 35, No 10, Part II—Transporting of Natural and Other Gases, Pipeline; the American Petroleum Institute Codes,

particularly API 1104 and other standards. Due acknowledgment is made of the assistance provided by these sources.

Although safety is the basic consideration of this standard other requirements will also control the specifications for any pipeline and these must be considered. The standard is not a design handbook and, although certain sections contain specific requirements, it does not replace the need for appropriate experience and competent engineering judgement. Fundamental engineering principles should be followed, and materials or practices not specifically approved or prohibited in this standard should be qualified for use as described in the applicable sections.

Attention is drawn to the requirements of both Commonwealth and State legislation and to guides and codes issued by statutory authorities and local government bodies pertaining to pipelines; and this standard should be regarded as complementary to such requirements where these are applicable.

The standard does not deal with, and is not intended to supplant, any matter of personnel safety with respect to work practices or such matters as the safe use of equipment and machinery in construction, which may be required by law or which are current industrial practice.

In relation to materials and components, this standard makes reference to a wide range of Australian, British and American standards. Many of these standards require the reporting of results of tests. Such reporting should be in the form of approved test certificates. Listings of relevant standards are given in Appendices A and B.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>		<i>Page</i>
SECTION 1. SCOPE AND GENERAL REQUIREMENTS		4.4 Reinforcement of Multiple Openings	37
1.1 Scope	5	4.5 Extruded Outlets	37
1.2 Safety	5	4.6 Expansion and Flexibility	38
1.3 Classification of Gas Transmission and Distribution Systems	5	4.7 Combined Stress Calculations	38
1.4 Notation and Definitions	7	4.8 Supports and Anchorage for Exposed Piping	39
1.5 Standards and Specifications	10	4.9 Anchorage for Buried Pipe	39
1.6 Interpretation	10	SECTION 5. WELDING	
SECTION 2. MATERIALS AND COMPONENTS		5.1 General	40
2.1 General	11	5.2 Safety in Welding	40
2.2 Qualification Categories of Materials and Components	11	5.3 Welding Equipment	40
2.3 Qualifying Procedures—General	11	5.4 Electrodes, Fluxes, Filler Metals and Gas Mixtures	40
2.4 Qualifying Procedures for Identified Used Steel Pipe Complying with a Specification Covered by this Standard	11	5.5 Prohibition of Welding	41
2.5 Qualifying Procedures for New or Used Steel Pipe Not Complying with a Specification Covered by this Standard	11	5.6 Definitions and Terms	41
2.6 Pipe Specifications	13	5.7 General Provisions for Welding	41
2.7 Fracture Toughness	13	5.8 Preheating	44
2.8 Accessories and Fittings	15	5.9 Post-weld Heat Treatment	48
2.9 External Protective Coating	16	5.10 Sour Gas Operation	48
2.10 Internal Protective Lining	16	5.11 Qualification of Welding Procedure	48
2.11 Cast and Ductile (Nodular or Spheroidal Graphite) Iron	16	5.12 Qualification Testing of Welded Joints	51
2.12 Copper and Copper Alloy	16	5.13 Welder Qualification	56
2.13 Plastics	16	5.14 Inspection and Testing of Production Welds	61
2.14 Jointing Materials	16	5.15 Non-destructive Testing Methods	61
2.15 Materials for Insulating Joints	16	5.16 Standards of Acceptability—Non-Destructive Testing	62
2.16 Restrictions on Use of Materials and Components	17	5.17 Rectification of Welds	66
2.17 Galvanic Anodes	17	5.18 Welding or Cutting on Steel Pipelines Containing Gas	67
SECTION 3. DESIGN		5.19 Attachment of Electrical Connections	68
3.1 Design of Steel Pipelines and Mains	18	SECTION 6. CONSTRUCTION AND INSTALLATION	
3.2 Control and Limiting of Gas Pressure	27	6.1 General	71
3.3 Pipes, Vaults and Kiosks	29	6.2 Installation of Pipelines, Mains and Services	71
3.4 External and Internal Corrosion—Division 2 Systems	30	6.3 Safe Working with Gas	73
3.5 Instrument, Control and Sampling Piping	32	SECTION 7. INSPECTION AND TESTING	
3.6 Valves	32	7.1 Extent of Inspection and Testing	75
3.7 Compressor Stations	33	7.2 Inspection and Inspectors	75
SECTION 4. FABRICATION DETAILS		7.3 Testing After Construction	75
4.1 General	35	7.4 Inspection and Testing—Division 1 Systems	75
4.2 Fittings and Components Other Than Standard	35	7.5 Inspection and Testing—Division 2 Systems	77
4.3 Reinforcement of Welded Branch Connections	35	7.6 Records	78
		7.7 Pressure-limiting and Pressure-relief Devices	78

SECTION 8.	OPERATION AND MAINTENANCE		12.3	Rate of Corrosion	88
8.1	General	79	12.4	Corrosion Mitigation Methods . . .	89
8.2	Maintenance of Pressure-limiting and Pressure-regulating Stations	79	12.5	Internal Corrosion Mitigation . . .	89
8.3	Pit and Vault Maintenance	79	12.6	External Corrosion Mitigation . . .	89
8.4	Prevention of Accidental Ignition	79	12.7	Installation of Galvanic Anodes . .	91
8.5	Valve Maintenance	79	12.8	Timing of Application of Corrosion Mitigation	91
8.6	Abandoning of Distribution or Trans- mission Facilities	79	12.9	Inspection for the Detection of Corrosion	91
8.7	Operation and Maintenance — Divis- ion 1 Systems	80	12.10	Corrosion Defects	92
8.8	Operation and Maintenance — Divis- ion 2 Systems	82	12.11	Records	92
8.9	Corrosion—Division 1 Systems	83			
SECTION 9.	ODORIZING				
9.1	Requirement	84	APPENDICES*		
9.2	Samples and Records	84	A	List of Nominated Standards and Specifications (Clause 1.5.2)	93
SECTION 10.	LIQUEFIED PETROLEUM GAS (LP GAS) SYSTEMS		B	List of Reference Standards (Clause 1.5.4)	96
10.1	Definition	85	C	Figures Relating to Weld Reinforce- ment (Section 4)	97
10.2	Application of Standard	85	D	Flexibility and Stress Intensification Factors (Clause 4.6.3)	104
10.3	Requirements Specific to LP Gas	85	E	Markers	106
SECTION 11.	CHANGES IN MAXIMUM OPERATING PRESSURE OF EXISTING SYSTEMS		G	Plastics Pipe Insertion Methods — Methods and Services	108
11.1	General	86	H	Identification and Addresses of Standards-issuing and Other Bodies	109
11.2	Increasing the Maximum Operating Pressure	86	I	Recommended Welding Sequence for Hot Tap Fittings	110
SECTION 12.	CORROSION MITIGATION— DIVISION 1 SYSTEMS		K	Fracture Toughness for Steel Trans- mission Pipelines and Mains	111
12.1	General	88	L	Assessment of Corroded Division 1 Pipelines	113
12.2	Qualification of Personnel	88	INDEX		121
			ANNEX		125

* See statement in Preface regarding Appendix F.

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard
for
GAS TRANSMISSION AND DISTRIBUTION SYSTEMS

SECTION 1. SCOPE AND GENERAL REQUIREMENTS

1.1 SCOPE. This standard sets out minimum safety requirements and makes recommendations for the design, fabrication, installation, inspection, testing, operation and maintenance of gas transmission and distribution systems in which the pipes are manufactured from steel, cast iron, copper and plastics (UPVC and PE), and qualify for use in terms of the relevant Section herein. This includes dual phase flow in natural gas pipelines.

Gas transmission and distribution systems within the scope of this standard comprise all pipelines, mains and gas service pipes up to the consumer's meter inlet within the limits defined by Fig. 1.1. This standard also covers the conditions of use of elements of these piping systems, including but not limited to pipe, fittings, flanges, bolting, gaskets, regulators, pressure vessels, pulsation dampers and pressure-relief devices.

This standard does not apply to the following:

- (a) Design and fabrication of pressure vessels covered by AS 1210 or other approved pressure vessel codes; or to LP gas installations covered by AS 1596.
- (b) Pipe or bottle type holders or containers.
- (c) Piping beyond the consumer's meter inlet which is governed by the gas supply authority's installation rules.
- (d) Petroleum processing plants, gas manufacturing plants, industrial plants or mines.
- (e) Vent piping to operate at substantially atmospheric pressure for waste gas collection.
- (f) Well-head assemblies, including control valves, and flow lines between well-head and trap or separator, or casing and tubing in gas or oil wells.
- (g) Manufacture of proprietary items of equipment, apparatus or instruments.
- (h) Petroleum and other liquid transportation piping systems or liquid slurry lines.

It is also not intended that this standard be applied retroactively to existing installations in so far as design, fabrication, installation and testing at the time of construction are concerned. Further it is not intended that this standard be applied retroactively to established operating pressures of existing installations except as provided for in Section 11.

However, provisions of this standard apply to operating and maintenance procedures of existing installations, and to existing installations when they are modified to operate under conditions within the scope of this standard.

1.2 SAFETY. The requirements and recommendations of this standard are considered to be adequate to ensure the safety of the general public and all persons engaged in pipeline construction and operation,

under conditions usually encountered in gas transmission and distribution systems to the extent that safety is affected by—

- (a) basic design;
- (b) quality of materials and workmanship;
- (c) testing requirements; and
- (d) maintenance and operation.

Extra protection should be provided where necessary, particularly to prevent damage from unusual conditions such as may arise at road, rail or river crossings, bridges, areas of heavy traffic, long self-supported spans, from vibration, weight of special attachments or the possibility of ground subsidence or any other abnormal forces.

Existing industrial safety regulations pertaining to work areas, safety devices and safe work practices are not supplanted by this standard.

1.3 CLASSIFICATION OF GAS TRANSMISSION AND DISTRIBUTION SYSTEMS.

1.3.1 Division 1 Systems. A gas pipeline, main or service having—

- (a) a hoop stress level equal to or greater than 0.2 (see Clause 1.3.4 for the determination of hoop stress level); or
- (b) a maximum operating pressure greater than 1050 kPa;

is classified as a Division 1 system.

1.3.2 Division 2 Systems. A gas pipeline, main or service having—

- (a) a hoop stress level less than 0.2 (see Clause 1.3.4 for determination of hoop stress level); and
- (b) a maximum operating pressure of 1050 kPa or less;

is classified as a Division 2 system.

A gas pipeline, main or service manufactured from cast-iron, copper, unplasticized polyvinyl chloride (UPVC) or polyethylene (PE) is classified as a Division 2 system.

1.3.3 Pressure Classification with Division 2 Systems.

1.3.3.1 Low pressure. Low pressure means a gas pressure equal to or less than 7 kPa.

1.3.3.2 Medium pressure. Medium pressure means a gas pressure exceeding 7 kPa but not exceeding 200 kPa.

1.3.3.3 High pressure. High pressure means a gas pressure exceeding 200 kPa.