

Australian Standard®

**Reeling, trailing and feeder cables
used for mining—Repair and testing**

AS 1747—1993
Reeling, trailing and feeder cables used
for mining—Repair and testing
Professional Package 32A) 40pp HH
Specifies requirements for the repair and
testing of cables used in underground coal
mines, metalliferous mines, open-cut
mines, quarries and dredges.
Committee EL3: Supersedes AS 1747—1989: Draft
for Comment DR 92187: Publication date 1993-10-11:
ISBN 0 7262 8359 2.



STANDARDS AUSTRALIA



This Australian Standard was prepared by Committee EL/3, Electric Wire and Cables. It was approved on behalf of the Council of Standards Australia on 12 May 1989 and published on 11 September 1989.

The following interests are represented on Committee EL/3:

Australian Electrical and Electronic Manufacturers Association
Civil Aviation Authority (Commonwealth)
Confederation of Australian Industry
Department of Defence
Department of Mineral Resources, New South Wales
Electrical Contractors Association of Australia
Electrical Regulatory Authorities
Electricity Supply Association of Australia
Railways of Australia Committee

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard®

**Reeling, trailing and feeder cables
used for mining—Repair and testing**

First published as AS 1747—1975.
Second edition 1980.
Third edition 1989.

PREFACE

This Standard was prepared by Standards Australia's Committee on Electric Wires and Cables to supersede AS 1747—1980, *Repair and testing of trailing cables and feeder cables used for mining*. It provides standard procedures for the repair of trailing cables and feeder cables used in underground coal mines and other mining applications, and establishes requirements for the repair of cables, that will ensure the repaired cable is returned to a condition as near as possible to the original design.

This Standard is in metric units, but the methods given herein will also be applicable for the repair of imperial dimensioned cables.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the Head Office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
FOREWORD	5
SECTION 1. SCOPE, REFERENCE DOCUMENTS AND DEFINITIONS	
1.1 SCOPE	6
1.2 REFERENCED DOCUMENTS	6
1.3 DEFINITIONS	6
SECTION 2. EVALUATION BEFORE REPAIR AND HISTORY RECORD	
2.1 REQUIREMENTS	8
2.2 HISTORY RECORD	8
2.3 DETAILS OF CABLE TO BE RECORDED	8
2.4 VISUAL EXAMINATION	8
2.5 PRE-REPAIR TESTS	8
2.6 PRACTICABILITY OF REPAIR	8
SECTION 3. REPAIR PROCEDURES FOR CABLES	
3.1 COMPATIBILITY OF CABLES TO BE JOINED	9
3.2 USE OF CLEANING SOLVENTS	9
3.3 JOINING BY FERRULES	9
3.4 JOINING BY WELDING OR SOLDERING	9
3.5 JOINING PILOT CONDUCTOR (all types of cable)	9
3.6 JOINING POWER CONDUCTORS OF ALL REELING AND TRAILING CABLES	9
3.7 JOINING POWER CONDUCTORS OF FEEDER CABLES	13
3.8 JOINING EARTH CONDUCTORS (EXCLUDING EARTH SCREENS)	13
3.9 REPLACEMENT OF INSULATION OR COVERING OVER CONDUCTORS	13
3.10 JOINING INDIVIDUAL METALLIC OR COMPOSITE EARTH SCREENS	18
3.11 REPLACEMENT OF SEMICONDUCTIVE ELASTOMERS	18
3.12 REPAIR OF INNER SHEATH	18
3.13 JOINING BRIDGE ARMOUR	18
3.14 REPLACEMENT OF SHEATH (Inner or Outer Sheath)	22
3.15 VULCANIZING	22
SECTION 4. REPAIR OF PLUGS	
4.1 EXAMINATION	24
4.2 PLUG REPLACEMENT	24
4.3 COMPOUNDS	24
4.4 FLAMEPROOFING	24
SECTION 5. TESTING	
5.1 GENERAL	25
5.2 TEST EQUIPMENT	25
5.3 HIGH VOLTAGE FAULT LOCATION TEST	25
5.4 HIGH VOLTAGE PROOF TEST	25
5.5 CONTINUITY AND PHASE ROTATION TESTS	25
5.6 PARTIAL BREAK TEST	25
5.7 SYMMETRICAL LOAD TEST	25
5.8 TESTS FOR INTEGRITY OF OUTER SHEATH	26
5.9 INSULATION RESISTANCE TEST	26
5.10 SHEATH HARDNESS	26

SECTION 6. IDENTIFICATION OF REPAIRS

6.1	METHOD OF MARKING	27
6.2	INFORMATION TO BE MARKED	27

APPENDICES

A	TYPICAL CABLE HISTORY RECORD	28
B	REQUIREMENTS FOR CLEANING SOLVENTS	29
C	REQUIREMENTS FOR FERRULES	30
D	REQUIREMENTS FOR SOLDER AND FLUX	30
E	REPAIR MATERIALS AND TAPES	31
F	REQUIREMENTS FOR TEST EQUIPMENT	33
G	ROUTINE TESTS ON TEST EQUIPMENT	35

Currently in preview, click buy full version

FOREWORD

Preparation of the first edition of this Standard (AS 1747—1975) was prompted by a need to formalize the practice of repairing trailing cables and feeder cables for use in underground coal mines so that some uniformity of practice could be established. As avoidance of premature failure of repaired cables is of paramount importance this Standard contains a definite bias towards existing repair practices used in underground coal mines.

It was the intention of the Committee, that practices that are essential only for underground coal mines should not be imposed upon other sections of the mining industry where they are not warranted. Some requirements of the Standard may be unnecessarily stringent for other than underground coal mining applications.

Where on-site or temporary repairs are undertaken, it is realized that it will not be practicable to carry out all the requirements of the Standard, e.g. testing.

The Standard specifies the use of ferrules, which are subsequently soldered, for joining bunches that may be parts of conductors, conductors as a whole, pliable armouring, and collective metallic or composite screens. Ferrules are also specified as one of the methods for the joining of individual metallic or composite screens. Except in the case of pliable armour, (see Clause 3.13), the Standard does not permit dry crimp joints in any cable but approaches may be made to regulatory authorities for specific recognition of other techniques.

Vulcanizing by the use of a heated pressure moulding machine is the only method acceptable in an underground coal mining operation. Alternative methods are no doubt satisfactory in surface applications, but it is considered that the bonding obtained between original material and repair material by vulcanizing is far superior to that obtained by any other method available at this time. Nevertheless, Clause 3.15 indicates that alternative methods may be employed for surface applications subject to the approval of the relevant Regulatory Authority.

Testing procedures contained in the Standard are those procedures which are considered essential for ensuring that repairs made to cables are of the highest possible quality. It is recognized, however, that some of the tests may be inappropriate in surface applications. The test methods and equipment specified in this Standard are in line with the present state of the art, but it is not in any way intended that development in these fields should be impeded by the need to comply with the existing provisions of this Standard. As new developments occur Standards Australia should be notified so that the matter can be put before the Committee with the view to modifying the Standard to keep pace with technology.

STANDARDS AUSTRALIA

Australian Standard

Reeling, trailing and feeder cables used for mining—Repair and testing

SECTION 1. SCOPE, REFERENCE DOCUMENTS
AND DEFINITIONS

1.1 SCOPE. This Standard sets out requirements for the repair and testing of cables used in underground coal mines. The requirements of this Standard may apply also to the repair of cables used elsewhere, e.g. metalliferous mines, open cut mines, quarries and dredges.

The Standard establishes sound practice for the repair and testing of—

- (a) reeling and trailing cables used for underground coal mines, metalliferous mines, open-cut mines, quarries and dredges; and
- (b) feeder cables used for underground coal mines and having insulation and sheath of elastomer.

Except for pliable armour, the Standard limits repairs to the use of soldered connections only.

The Standard also details the repair of plugs fitted to the cables and to the test equipment used for testing cable.

NOTE: The Standard applies particularly to reeling and trailing cables complying with AS 1802, AS 2802 and the former AS C81; and to feeder cables complying with AS 1972 and the former AS C412, but is not restricted in application to such cables.

Where type or code numbers are referred to in the Standard for trailing cables, the numbers are as specified in AS 1802, AS 2802 and the former AS C81.

1.2 REFERENCED DOCUMENTS. The following documents are referred to in this Standard:

- AS
- 1299 Electrical equipment for coal mines—Flame-proof restrained plugs and receptacles
 - 1300 Electrical equipment for coal mines—Bolted flameproof cable coupling devices
 - 1593 Electrical equipment for explosive atmospheres—Increased safety apparatus—Type of protection e
 - 1660 Methods of test for electric cables, cords and conductors
 - 1802 Reeling and trailing electric cables for underground coal mining purposes
 - 1972 Cables for use below ground in coal mines (other than the trailing cables)
 - 2290 Electrical equipment for coal mines—Maintenance and overhaul
 - 2308 Safe storage and handling information cards for hazardous material
 - 2302 Reeling and trailing electric cables for mining and general use (other than underground coal mining)—Elastomeric flexible cables for working voltages 1.1/1.1 kV up to and including 33/33 kV.
 - C81 Superseded by AS 1802
 - C412 Superseded by AS 1972

BS

- 219 Specification for soft solders
- 2719 Methods of use and calibration of pocket type rubber hardness meters

1.3 DEFINITIONS. For the purpose of this Standard, the following definitions apply:

1.3.1 Reeling and trailing cable—a cable having multiple stranded conductors, insulation incorporating conductor and insulation screens where appropriate, filling, reinforcement where appropriate, and protective covering(s), and specially designed to provide a flexible electrical connection between portable or mobile equipment and a point of supply.

1.3.2 Feeder cable—a cable intended primarily for use between a transportable substation and associated equipment (e.g. gate-end box or distribution centre, where the cable is required to be moved frequently).

1.3.3 Individually screened cable—a cable in which the insulation of each power core is separately enclosed in a conducting layer.

1.3.4 Collectively screened cable—a cable in which the insulation of all conductors is collectively enclosed in a conductive layer.

1.3.5 Conductor screen—a non-metallic semiconductive layer over a power conductor.

1.3.6 Insulation screen—a non-metallic semiconductive layer over insulation of a power core.

1.3.7 Composite screen—a screen comprising copper wires or stranded or bunched copper wires applied in one direction and interwoven in the opposite direction with polyethylene terephthalate, or equivalent, yarn.

1.3.8 Power core—a power conductor with insulation and, when appropriate, the semiconductive conductor and insulation screen, but not including any other protective covering.

1.3.9 Earth conductor—a conductor, metallic or composite earth screen included in the cable for the purpose of providing earth continuity.

1.3.10 Pilot core—a conductor with insulation or covering which is installed either in the centre of a cradle separator (central pilot core) or in the outer interstices between the power cores (interstitial pilot core), or is otherwise laid up in the cable for use in conjunction with a pilot protection system.

1.3.11 Covered conductor—a pilot or earth conductor having elastomeric insulation of a specified radial thickness which differs from that required by the voltage rating of the cable, or an interstitial earth conductor with its semiconductive covering.