

Australian Standard[®]

**Water supply—Float control valves for
use in hot and cold water**

STANDARDS
Australia



This Australian Standard® was prepared by Committee WS-001, Water Fittings. It was approved on behalf of the Council of Standards Australia on 15 April 2004. This Standard was published on 7 July 2004.

The following are represented on Committee WS-001:

- Australasian Institute of Mining and Metallurgy
 - Australian Coal Association
 - Australian Coal Preparation Society
 - Australian Institute of Energy
 - Coalfield Geology Council of New South Wales
 - CSIRO, Energy Technology
 - Department of Natural Resources and Mines, Qld
 - Minerals Council of Australia
 - National Association of Testing Authorities, Australia
 - National Generators Forum
 - University of Newcastle
 - University of New South Wales
 - University of Queensland
-

This Standard was issued in draft form for comment as DR 03484.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

**Water supply—Float control valves for
use in hot and cold water**

Original edition AS 1910—1976.
Previous edition AS 1910—1994.
Third edition 2004.
Reissue incorporating Amendment No. 1 (July 2006).

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 6073 2

PREFACE

This Standard was prepared by the Standards Australia Committee WS-001, Water Fittings, to supersede AS 1910—1994.

This Standard incorporates Amendment No. 1 (July 2006). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

Changes to this edition are as follows:

- (a) Inclusion of metal and plastic materials.
- (b) Testing based on performance.

Acoustic requirements have not been addressed until further research on testing procedures and methods is available.

The term 'normative' has been used in this Standard to define the application of the appendix to which it applies. A 'normative' appendix is an integral part of a Standard.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	4
1.4 DESIGNATION OF NOMINAL SIZE	4
1.5 PERMANENT DISTORTION	4
SECTION 2 MATERIALS	
2.1 SCOPE OF SECTION	5
2.2 COPPER	5
2.3 COPPER ALLOY	5
2.4 DEZINCIFICATION-RESISTANT (DR) COPPER ALLOY	5
2.5 STAINLESS STEEL	5
2.6 PLASTICS MATERIALS	5
2.7 OTHER COMPONENT MATERIALS	6
2.8 CONTAMINATION OF WATER	6
SECTION 3 DESIGN	
3.1 SCOPE OF SECTION	7
3.2 END CONNECTORS	7
3.3 SCREW THREADS	7
3.4 FABRICATED COMPONENTS	7
3.5 WATERWAY AND FLOW CAPABILITY	8
3.6 REQUIREMENTS FOR FLOAT	8
3.7 PROVISION FOR ADJUSTMENT	8
3.8 MARKING	8
SECTION 4 PERFORMANCE REQUIREMENTS	
4.1 GENERAL	9
4.2 SHUT-OFF ABILITY	9
4.3 STRENGTH OF VALVE ASSEMBLY	9
4.4 ENDURANCE	9
4.5 WORKMANSHIP	9
APPENDICES	
A MEANS FOR DEMONSTRATING COMPLIANCE WITH THIS STANDARD	10
B LIST OF REFERENCED DOCUMENTS	13
C SHUT-OFF TEST	15
D TEST FOR STRENGTH OF VALVE ASSEMBLY	17
E ENDURANCE TEST	19

STANDARDS AUSTRALIA

Australian Standard**Water supply—Float control valves for use in hot and cold water**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for active float control valves for use in water supply systems where the normal working temperature does not exceed 95°C and the continuous working pressure extends up to a maximum of 1.4 MPa for a range of nominal sizes from DN 6 to DN 80.

This Standard does not cover WC cistern flushing valves.

NOTE: WC cistern flushing valves are covered in all parts of AS 1172.

Means of demonstrating compliance with this Standard are set out in Appendix A.

1.2 REFERENCED DOCUMENTS

Documents referred to in this Standard are listed in Appendix B.

1.3 DEFINITIONS

For the purpose of this Standard the definitions given in AS/NZS 3500.0 apply.

1.4 DESIGNATION OF NOMINAL SIZE

The nominal size shall be related to the inlet connection of the valve.

1.5 PERMANENT DISTORTION

Permanent distortion for the purpose of the tests in this Standard, is limited to permanent distortion which is obvious to the eye without resorting to dimensional checks.